




# Water Asset Management Plan

2025- 2034

---

**Waimate District Council**





## Quality Record Sheet

### Waimate District Council

#### Water AMP

2025-2034

Issue Information	
Issue Purpose	Final
Issue Date	22 January 2025
Version Number	4

Authorisation	
Waimate District Council	Dan Mitchell
Updated by:	Waugh Infrastructure Management Limited Dan Mitchell (Waimate District Council) Paul Roberts (Waimate District Council)
Update reviewed by:	WDC & Waugh Infrastructure Management
Date	22 January 2025
Report Number	64 073-1032

## Quality Information

Document:	Water Asset Management Plan 2024
Reference:	Version 4
Date:	22 January 2025
Prepared by:	Waimate District Council
AMP Development Process:	
Project Sponsor:	Dan Mitchell (Asset Group Manager)
AMP Authors:	Waugh Infrastructure Management Limited Waimate District Council
Project Team:	
Lifecycle:	Dan Mitchell
Population Projections:	Rationale Consultants Limited
Financial:	Dan Mitchell
Date Adoption by Council:	15 October 2024
Copies	

## Revision History

Revision	Revision Date	Details	Authorised	
			Name/Position	Signature
2.0	20/03/18	Full update (inc. revised financials)	Dan Mitchell	
3.0	30/11/20	Updated draft AMP		
3.1	24/04/21	Finalise draft AMP	Paul Roberts	
3.4	25/05/21	Audit recommendations added	Dan Mitchell	
3.5	11/08/21	Update post LTP submissions	Dan Mitchell	
3.6	20/09/24	Update for 2024 LTP	Dan Mitchell	
3.7	20/09/24	Working Version Update for 2024 LTP	Dan Mitchell	
3.8	25/09/2024	Final Draft 2024	Dan Mitchell	
3.9	09/10/24	Final Draft for Approval	Dan Mitchell	
3.10	15/10/24	Final Adopted	Dan Mitchell	
4	22/01/2025	Final Adopted (Inflated Budgets)	Dan Mitchell	

## Table of Contents

<b>1.0</b>	<b>EXECUTIVE SUMMARY</b> .....	<b>12</b>
1.1	WHAT ARE WE DOING? .....	13
1.2	WHY ARE WE DOING IT? .....	13
1.3	WHERE ARE WE HEADED? .....	14
1.4	HOW WILL WE GET THERE? .....	15
1.5	WHAT WILL IT COST? .....	16
1.6	HOW WELL ARE WE DOING AND HOW WELL DO WE MEASURE PROGRESS? .....	19
1.7	WHAT RESOURCES DO WE HAVE AND WHAT RESOURCES DO WE NEED? .....	20
1.8	WHO PAYS FOR IT? .....	21
<b>2.0</b>	<b>INTRODUCTION</b> .....	<b>22</b>
2.1	PURPOSE OF THE AMP.....	22
2.2	TIME PERIOD OF THIS PLAN.....	23
2.3	ASSETS INCLUDED IN THIS AMP .....	23
2.4	RELATIONSHIP WITH OTHER PLANS .....	24
2.5	HOW THIS AMP WILL BE USED .....	24
2.6	WATER SUPPLY ACTIVITY OBJECTIVES.....	25
2.7	COUNCIL’S AM POLICY – APPROPRIATE LEVEL .....	25
2.8	KEY STAKEHOLDERS .....	27
2.9	PROGRESS IN DEVELOPMENT OF ASSET MANAGEMENT .....	30
2.10	AMP INFORMATION.....	30
2.11	AMP FORMAT.....	30
<b>3.0</b>	<b>GUIDING PRINCIPLES, LEGISLATION, POLICY AND RELATIONSHIPS</b> .....	<b>32</b>
3.1	NATIONAL STRATEGIES AND PLANS .....	32
3.2	KEY LEGISLATION AND REGULATION– IMPLICATIONS FOR ASSET MANAGEMENT .....	35
3.3	RELEVANT REGULATIONS AFFECTING THIS ACTIVITY .....	37
3.4	STANDARDS, CODES OF PRACTICE AND GUIDELINES .....	37
3.5	REGIONAL PLANS .....	39
3.6	WAIMATE DISTRICT COUNCIL STRATEGIES, PLANS AND BYLAWS .....	42
<b>4.0</b>	<b>DESCRIPTION OF THE WATER SERVICE</b> .....	<b>46</b>
4.1	WAIMATE DISTRICT OVERVIEW .....	46
4.2	DESCRIPTION OF ACTIVITY.....	46
4.3	SUMMARY OF WATER ASSETS .....	48
4.4	WATER RETICULATION .....	49
4.5	WATER SERVICE LINES AND WATER POINTS.....	52
4.6	WATER FACILITIES .....	54
4.7	WATER PUMPING STATIONS .....	57
4.8	RESERVOIRS .....	58
4.9	ASSET DATA CONFIDENCE AND INTEGRITY .....	58
4.10	ENVIRONMENTAL EFFECTS .....	60
4.11	ASSESSMENT OF WATER SERVICES .....	65
4.12	CRITICALITY .....	66
<b>5.0</b>	<b>LEVELS OF SERVICE</b> .....	<b>70</b>
5.1	COMMUNITY OUTCOMES .....	70
5.2	LEVEL OF SERVICE CONSULTATION.....	72
5.3	RULES FOR PERFORMANCE MEASURES.....	72
5.4	WATER LEVELS OF SERVICE .....	73
5.5	PERFORMANCE GAPS.....	80
<b>6.0</b>	<b>GROWTH AND DEMAND MANAGEMENT</b> .....	<b>82</b>



6.1	WAIMATE DISTRICT GROWTH .....	82
6.2	POPULATION DEMOGRAPHIC CHANGES.....	84
6.3	PROJECTS THAT WILL HAVE AN IMPACT ON DISTRICT POPULATION .....	88
6.4	WATER SUPPLY DEMAND DRIVERS.....	89
6.5	WATER USAGE TRENDS IN WAIMATE DISTRICT .....	90
6.6	LEGISLATIVE CHANGES .....	92
6.7	DEMAND MANAGEMENT.....	92
<b>7.0</b>	<b>RISK MANAGEMENT.....</b>	<b>104</b>
7.1	WDC RISK MANAGEMENT FRAMEWORK .....	104
7.2	WATER RISK ASSESSMENTS.....	107
7.3	RISK MANAGEMENT FOCUS AREAS WITHIN COUNCIL .....	113
7.4	MANAGING WATER SAFETY RISKS.....	127
7.5	SIGNIFICANT NEGATIVE EFFECTS .....	136
7.6	CAPITAL PROGRAMME DELIVERY RISKS .....	137
<b>8.0</b>	<b>LIFECYCLE MANAGEMENT PLAN .....</b>	<b>138</b>
8.1	ASSET LIFECYCLE .....	138
8.2	LIFECYCLE MANAGEMENT - AN OVERVIEW .....	139
8.3	MANAGEMENT PROGRAMME.....	139
8.4	OPERATIONS AND MAINTENANCE PLAN .....	142
8.5	RENEWAL AND REPLACEMENT PLAN .....	150
8.6	ASSET DEVELOPMENT PLAN .....	163
8.7	DISPOSAL PLAN.....	167
<b>9.0</b>	<b>FINANCIAL SUMMARY.....</b>	<b>170</b>
9.1	FINANCIAL STRATEGY .....	170
9.2	DEVELOPMENT CONTRIBUTIONS .....	170
9.3	DEPRECIATION .....	170
9.4	VALUATIONS.....	171
9.5	HOW WE FUND OUR ACTIVITY.....	174
9.6	10 YEAR LTP FINANCIAL PROJECTIONS AND BUDGET FORECASTS .....	175
9.7	KEY FINANCIAL FORECASTS ASSUMPTIONS AND UNCERTAINTIES .....	196
<b>10.0</b>	<b>PROCESSES AND ASSET MANAGEMENT PRACTICES .....</b>	<b>198</b>
10.1	ORGANISATION STRUCTURE .....	199
10.2	AMP REVIEW AND MONITORING .....	200
10.3	BUSINESS PROCESSES.....	201
<b>11.0</b>	<b>IMPROVEMENT PLAN .....</b>	<b>210</b>
11.1	ASSET MANAGEMENT IMPROVEMENT PROCESS .....	210
11.2	IMPROVEMENT PROGRAMME.....	210
<b>APPENDIX A</b>	<b>INDIVIDUAL SYSTEM DESCRIPTION &amp; OVERVIEW .....</b>	<b>219</b>
A.1	WAIMATE URBAN SCHEME .....	220
A.2	CANNINGTON MOTUKAIKA WATER SCHEME.....	235
A.3	HOOK WAITUNA WATER SCHEME.....	247
A.4	LOWER WAIHAO WATER SCHEME.....	260
A.5	OTAIO MAKIKIHI WATER SCHEME.....	272
A.6	WAIHAORUNGA WATER SCHEME.....	283
A.7	WAIKAKAHI WATER SCHEME.....	295
<b>APPENDIX B</b>	<b>WSP: MINOR PROJECTS AND OPERATIONAL IMPROVEMENTS.....</b>	<b>307</b>
<b>APPENDIX C</b>	<b>SIGNIFICANT FORECASTING ASSUMPTIONS .....</b>	<b>317</b>
<b>APPENDIX D</b>	<b>RISK SUMMARY TABLE .....</b>	<b>327</b>

**APPENDIX E MAJOR LEGISLATION DETAILS ..... 339**  
**APPENDIX F REFERENCES..... 349**

**Table of Figures**

Figure 2-1: Level of Asset Management..... 27  
 Figure 2-2: Water AMP Compliance Status (2012 & 2014)..... 27  
 Figure 2-3: Asset Management Process..... 31  
 Figure 4-1: Scheme Location and Area..... 47  
 Figure 4-2: Water Components - Replacement Cost ..... 49  
 Figure 4-3: Summary of Pipe Materials..... 49  
 Figure 4-4: Summary of Pipe Length vs Diameter..... 50  
 Figure 4-5: Pipe Length by Remaining Life ..... 51  
 Figure 4-6: Water Resource Consent Expiry Summary Chart ..... 60  
 Figure 4-7: Waimate Urban Water Supply Criticality and Lengths Distribution ..... 67  
 Figure 4-8: Waimate Urban Water Supply Criticality Map..... 67  
 Figure 5-1: Customer and Technical Levels of Service ..... 79  
 Figure 5-2: Levels of Service Contribution to Four Wellbeings ..... 80  
 Figure 5-3: Key Research Survey Trends ..... 81  
 Figure 6-1: Comparison between the 2020 projections and the 2023 predictions ..... 83  
 Figure 6-2: Population Projections (Usually Resident Population) ..... 84  
 Figure 6-3: Age distribution of Waimate District’s population in 2053 ..... 85  
 Figure 6-4: Waimate District’s population by Age – 2013, 2018, 2022 (Source: NZ Stats)..... 86  
 Figure 6-5: Waimate District Household numbers and type..... 87  
 Figure 6-6: Waimate District Population Projections 2013-2053 ..... 88  
 Figure 6-7: Waimate Urban Water Supply Demand ..... 91  
 Figure 6-8: Water Loss Trends..... 95  
 Figure 7-1: WDC Risk Management Process Diagram..... 105  
 Figure 7-2: DWQAR Water Supply Categorisation ..... 128  
 Figure 7-3: DWQAR Applicable Rules ..... 129  
 Figure 8-1: The Asset Lifecycle ..... 138  
 Figure 8-2: Lifecycle Management Programmes ..... 139  
 Figure 8-3: Water Supplies Operations & Maintenance Costs..... 149  
 Figure 8-4: Cast Iron Pipe Failure ..... 153  
 Figure 8-5: Water Renewals - 100 Years ..... 156  
 Figure 8-6 : 100 Year Water Supply Renewals by Key Asset Component Type ..... 157  
 Figure 8-7: Water Supply Renewals Profile - 30 Year..... 157  
 Figure 8-8: 30 Year Water Renewals by Asset Group ..... 159  
 Figure 8-9: Water Renewals Planning Chart ..... 160  
 Figure 8-10: 10 Year Renewals Programme Chart Summary ..... 162  
 Figure 8-11: 10 Year Water Capital Budget Forecast Summary Charts ..... 166  
 Figure 9-1: 3 Waters 2024 Valuation ..... 171  
 Figure 9-2: 2024 Water Valuation Summary Chart..... 172  
 Figure 9-3: 2024 Valuation Summary Chart by Water Supply ..... 172  
 Figure 9-4: Summary of 10 Year Maintenance & Operations and Capital (Including Renewals) Forecasts ..... 176  
 Figure 9-5: 10 Year Water Capex and Opex Summary ..... 177  
 Figure 9-6: Detailed Capital Expenditure: Waihaorunga (figures are inflated)..... 187  
 Figure 9-7: Detailed Capital Expenditure: Waikakahi (figures are inflated)..... 189  
 Figure 9-8: 3 Waters 2024-34 Renewals and Capital Projects ..... 194  
 Figure 9-9: 3 Waters 2024-34 Capital Programme..... 195  
 Figure 10-1: Council Management Structure ..... 199  
 Figure 10-2: Water and Waste Unit Structure ..... 199

Figure 10-3: Council Data Systems .....	201
---	-----

## Table of Tables

Table 1-1: WDC Community Outcomes .....	13
Table 1-2: 2024-2034 Budget Forecasts.....	16
Table 1-3: Significant Water Capital Projects.....	17
Table 1-4: Community Outcomes .....	19
Table 1-5: Drinking Water Quality Assurance Rule Compliance .....	20
Table 1-6: Water Physical Assets Summary .....	21
Table 2-1: Council Water Schemes.....	23
Table 2-2: Summary of Water Scheme Assets Replacement Costs .....	24
Table 2-3: Activity Management Plan Enactment.....	25
Table 2-4: Waimate District Stakeholders.....	28
Table 2-5: Key Elements of AMP .....	31
Table 3-1: Other Key Government/Industry Direction .....	33
Table 3-2: Legislation and Regulation Affecting the Water Services .....	36
Table 3-3: National Environmental Standards and Guidelines .....	38
Table 3-4: Regional and Iwi Plan Documents .....	40
Table 3-5: Key Actions to meet 2025 Goals .....	41
Table 4-1: Waimate Community Profile.....	46
Table 4-2: Summary of Water Assets .....	48
Table 4-3: Summary of Pipe Length vs. Diameter .....	50
Table 4-4: Length of Service Line by Pipe Material .....	52
Table 4-5: Point Water Assets .....	53
Table 4-6: Waimate District Council Water Treatment Plants.....	55
Table 4-7: Water Treatment Plant Capacity and Production .....	56
Table 4-8: Description of Pump Stations.....	57
Table 4-9: Reservoir Storage Capacity .....	58
Table 4-10: Data Confidence .....	59
Table 4-11: Water Resource Consent Expiry Dates.....	60
Table 4-12: Water Resource Consents.....	62
Table 4-13: Public and Private Water Supplies .....	65
Table 4-14: Quality and Adequacy .....	65
Table 5-1: Waimate District Council Community Outcomes 2024-34 and Water Services Rationale .....	71
Table 5-2: Waters Services Consultation Processes (Historical and Proposed).....	72
Table 5-3: Water Services Levels of Service .....	74
Table 5-4: Level of Service Performance Gaps.....	81
Table 6-1: Summary of the Four Growth Scenarios .....	83
Table 6-2: Average age of District Population.....	85
Table 6-3: Water Demand Drivers.....	90
Table 6-4: Water Demand .....	92
Table 6-5: Demand Management Strategies .....	92
Table 6-6: July 2015 Leak Detection Survey Leak Counts and Estimated Water Loss .....	94
Table 6-7: Waimate Urban – Model Recommendations .....	96
Table 6-8: Otaio Makikihi – Model recommendations .....	97
Table 6-9: Lower Waihao – Model recommendations.....	98
Table 6-10: Waihaorunga – Model recommendations .....	99
Table 6-11: Waikakahi - Model recommendations.....	99
Table 6-12: Cannington Motukaiaka – Model Recommendations .....	100
Table 7-1: Risk Summary Table (Showing Significant or High Risks only) .....	109
Table 7-2: COVID 19 Chain of events .....	113

## Table of Contents

Table 7-3: Climate Change Risk to Council .....	121
Table 7-4: Waimate District Council Water Supplies Under Consideration for Fluoridation .....	132
Table 7-5: WSP Improvement Programme .....	133
Table 7-6: DWSNZ Compliance Upgrades .....	134
Table 7-7: Negative Effects – Water Activity.....	136
Table 8-1: Management Strategies .....	140
Table 8-2: O&M Strategies .....	143
Table 8-3: Priority Response Times .....	144
Table 8-4: Alarm Priority .....	144
Table 8-5: Council Utilities Staff Qualifications .....	145
Table 8-6: Operations and Maintenance Budget Forecasts.....	148
Table 8-7: Renewal Strategies: Existing and Future .....	151
Table 8-8: 3 Waters Asset Data Confidence.....	155
Table 8-9: Water Supply Key Asset Base Life Information .....	155
Table 8-10: 30 Year Renewal Expenditure Forecasts by Supply– All Assets .....	158
Table 8-11: Ten Year Water Renewals Budget Forecast Summary.....	161
Table 8-12: Development Strategies.....	163
Table 8-13: 10 Year Water Capital Budget Forecast Summary .....	165
Table 8-14: Disposal Strategies .....	167
Table 9-1: 2024 Water Valuation Summary.....	172
Table 9-2: 2024 Valuation Summary by Water Supply .....	172
Table 9-3: Assessment of Confidence Levels .....	173
Table 9-4: Water Funding Sources .....	174
Table 9-5: 10 Year LTP Budget Forecasts .....	176
Table 9-6: Detailed Maintenance & Operational Expenditure Forecasts: Cannington / Motukaika (figures are inflated) .....	178
Table 9-7: Detailed Capital Expenditure Forecasts: Cannington/Motukaika (figures are inflated) .....	179
Table 9-8: Detailed Maintenance & Operational Expenditure Forecasts: Hook/Waituna (Figures are inflated).....	180
Table 9-9: Detailed Capital Expenditure Forecasts: Hook / Waituna (Figures are inflated) .....	181
Table 9-10: Detailed Maintenance & Operational Expenditure Forecasts: Lower Waihao (figures are inflated) .....	182
Table 9-11: Detailed Capital Expenditure: Lower Waihao (figures are inflated) .....	183
Table 9-12: Detailed Maintenance & Operational Expenditure: Otaio / Makikihi (figures are inflated).....	184
Table 9-13: Detailed Capital Expenditure: Otaio / Makikihi (figures are inflated).....	185
Table 9-14: Detailed Maintenance & Operational Expenditure: Waihaorunga (figures are inflated) .....	186
Table 9-15: Detailed Maintenance & Operational Expenditure: Waikakahi (figures are inflated) .....	188
Table 9-16: Detailed Maintenance & Operational Expenditure: Waimate Urban (figures are inflated).....	190
Table 9-17: Detailed Capital Expenditure: Waimate Urban (figures are inflated).....	191
Table 9-18: Detailed Maintenance & Operational Expenditure: Cattle Creek (figures are inflated) .....	192
Table 9-19: Detailed Maintenance & Operational Expenditure: Downlands (figures are inflated) .....	192
Table 9-20: Detailed Maintenance & Operational Expenditure: Hakataramea (figures are inflated) .....	193
Table 9-21: Detailed Capital Expenditure: Downlands (figures are inflated).....	193
Table 9-21: Detailed Capital Expenditure: Cattle Creek (figures are inflated).....	193

Table 9-22: 3 Waters 2024 -2034 Renewals and Capital Summary .....	194
Table 9-23: 3 Waters 2024-34 Capital Programme .....	195
Table 9-24: Financial Forecast Confidence Level .....	196
Table 9-25: Confidence Grades .....	196
Table 9-26: Accuracy Ratings.....	197
Table 10-1: Timetable for Audit and Review.....	200
Table 10-2: Methodologies for the Ongoing Implementation and Updating of AMPs.....	200
Table 10-3: Univerus Assets Functionality and Utilisation by Council .....	202
Table 10-4: GIS Data.....	202
Table 10-5: Scheme SCADA Details .....	205
Table 11-1: Recent AM Improvements Completed.....	211
Table 11-2: AM Improvement Programme .....	212
Table 11-3: Timetable for Audit and Review.....	218
Table 11-4: Water Services LGA 2002 Clauses .....	341

### Table of Appendix Figures

Appendix Figure 1: Scheme Components .....	228
Appendix Figure 2: Water Pipes Diameter Range .....	229
Appendix Figure 3: Water Pipes Material Length .....	229
Appendix Figure 4: Water Pipes Install Year .....	230
Appendix Figure 5: Remaining Life of all Assets – Long Term.....	230
Appendix Figure 6: Water Pipes Replacement (Length) – Long Term .....	231
Appendix Figure 7: Water Pipes Replacement Value – Long Term.....	231
Appendix Figure 8: Water Pipes Replacement (Length) - 1 to 30 Years .....	232
Appendix Figure 9: Water Pipes Replacement Value 1 to 30 Years.....	232
Appendix Figure 10: 30 Year Renewal Profile .....	233
Appendix Figure 11: Waimate Urban Water Scheme .....	234
Appendix Figure 12: Scheme Components .....	239
Appendix Figure 13: Water Pipes Diameter Range .....	239
Appendix Figure 14: Water Pipes Length and Material .....	240
Appendix Figure 15: Water Pipes Install Year (10 Year Groups) .....	240
Appendix Figure 16: Remaining Life of all Assets – Long Term.....	241
Appendix Figure 17: Water Pipes Replacement (Length) – Long Term .....	241
Appendix Figure 18: Water Pipes Replacement Value – Long Term.....	242
Appendix Figure 19: Water Pipes Replacement (Length) - 1 to 30 Years .....	242
Appendix Figure 20: Water Pipes Replacement Value - 1 to 30 Years.....	243
Appendix Figure 21: 30 Year Renewal Programme.....	244
Appendix Figure 22: Cannington Motukaika Schematic .....	245
Appendix Figure 23: Cannington Motukaika Scheme Plan .....	246
Appendix Figure 24: Scheme Components .....	251
Appendix Figure 25: Water Pipes Diameter Range .....	252
Appendix Figure 26: Water Pipes Material Length .....	252
Appendix Figure 27: Water Pipes Install Year (10 Year Groups) .....	253
Appendix Figure 28: Remaining Life of all Assets – Long Term.....	254
Appendix Figure 29: Water Pipes Replacement (Length) – Long Term .....	254
Appendix Figure 30: Water Pipes Replacement Value – Long Term.....	255
Appendix Figure 31: Water Pipes Replacement (Length) - 1 to 30 Years .....	255
Appendix Figure 32: Water Pipes Replacement Value 1 to 30 Years.....	256
Appendix Figure 33: 30 Year Renewal Profile .....	257
Appendix Figure 34: Hook Waituna Schematic.....	258
Appendix Figure 35: Hook Waituna Scheme Plan.....	259

## Table of Contents

Appendix Figure 36: Scheme Components .....	264
Appendix Figure 37: Water Pipes Diameter Range .....	264
Appendix Figure 38: Water Pipes Material Length .....	265
Appendix Figure 39: Water Pipes Install Year (10 Year Groups) .....	265
Appendix Figure 40: Remaining Life of all Assets – Long Term .....	266
Appendix Figure 41: Water Pipes Replacement (Length) – Long Term .....	266
Appendix Figure 42: Water Pipes Replacement Value – Long Term .....	267
Appendix Figure 43: Water Pipes Replacement (Length) – 1 to 30 Years.....	267
Appendix Figure 44: Water Pipes Replacement Value 1 to 30 Years.....	268
Appendix Figure 45: 30 Year Replacement Profile.....	269
Appendix Figure 46: Lower Waihao Schematic.....	270
Appendix Figure 47: Lower Waihao Scheme Plan.....	271
Appendix Figure 48: Scheme Components .....	275
Appendix Figure 49: Water Pipes Diameter Range .....	276
Appendix Figure 50: Water Pipes Material Length .....	276
Appendix Figure 51: Water Pipes Install Year (10 Year Groups) .....	277
Appendix Figure 52: Remaining Life of all Assets – Long Term .....	277
Appendix Figure 53: Water Pipes Replacement (Length) – Long Term .....	278
Appendix Figure 54: Water Pipes Replacement Value – Long Term.....	278
Appendix Figure 55: Water Pipes Replacement (Length) - 1 to 30 Years .....	279
Appendix Figure 56: Water Pipes Replacement Value 1 to 30 Years.....	279
Appendix Figure 57: 30 Year Replacement Profile.....	280
Appendix Figure 58: Otaio Makikihi Schematic.....	281
Appendix Figure 59: Otaio Makikihi Scheme Plan.....	282
Appendix Figure 60: Scheme Components .....	287
Appendix Figure 61: Water Pipes Diameter Range .....	287
Appendix Figure 62: Water Pipes Material Length .....	288
Appendix Figure 63: Water Pipes Install Year (10 Year Groups) .....	288
Appendix Figure 64: Remaining Life of all Assets – Long Term .....	289
Appendix Figure 65: Water Pipes Replacement (Length) – Long Term .....	289
Appendix Figure 66: Water Pipes Replacement Value – Long Term.....	290
Appendix Figure 67: Water Pipes Replacement (Length) - 1 to 30 Years .....	290
Appendix Figure 68: Water Pipes Replacement Value 1 to 30 Years.....	291
Appendix Figure 69: 30 Year Replacement Profile.....	292
Appendix Figure 70: Waihaorunga Schematic .....	293
Appendix Figure 71: Waihaorunga Scheme Plan .....	294
Appendix Figure 72: Scheme Components .....	299
Appendix Figure 73: Water Pipes Diameter Range .....	299
Appendix Figure 74: Water Pipes Material Length .....	300
Appendix Figure 75: Water Pipes Install Year (10 Year Groups) .....	300
Appendix Figure 76: Remaining Life of all Assets – Long Term .....	301
Appendix Figure 77: Water Pipes Replacement (Length) – Long Term .....	301
Appendix Figure 78: Water Pipes Replacement Value – Long Term.....	302
Appendix Figure 79: Water Pipes Replacement (Length) - 1 to 30 Years .....	302
Appendix Figure 80: Water Pipes Replacement Value 1 to 30 Years.....	303
Appendix Figure 81: 30 Year Replacement Programme .....	304
Appendix Figure 82: Waikakahi Schematic .....	305
Appendix Figure 83: Waikakahi Scheme Plan .....	306

**Table of Appendix Tables**

Appendix Table 1: Plant Replacement Value 1 to 30 Years .....	233
Appendix Table 2: Plant Replacement Value 1 to 30 Years .....	243
Appendix Table 3: Plant Replacement Value 1 to 30 Years .....	256
Appendix Table 4: Lower Waihao Plant Replacement Value 1 to 30 Years .....	268
Appendix Table 5: Waihaorunga Plant Replacement Value 1 to 30 Years.....	292
Appendix Table 6: Waikakahi Plant Replacement Value 1 to 30 Years.....	304
Appendix Table 7: Scheme Improvement Schedule - Minor Projects and Operational Improvements .....	308
Appendix Table 8: Significant Forecasting Assumptions 2025 -2034.....	318

## 1.0 EXECUTIVE SUMMARY

<p><b>WATER</b></p> 	<p>The water activity is a core Council activity that contributes towards the provision of good quality infrastructure and helps ensure public health and safeguards the environment. The water system comprises treatment facilities, pipes, pump stations and other assets that represent a significant council investment over many years.</p>
<p><b>FOCUS</b></p> 	<p><b>New Capital and Growth</b> – to improve water treatment across the district and comply with the Water Services Act, Drinking Water Standards and Drinking Water Quality Assurance Rules.</p> <p>-to provide capacity to meet the required standards, future demand and support the expansion of development areas as identified by Council.</p> <p><b>Renewals</b> – develop and implement a renewals strategy; including condition and criticality assessments. Ensure appropriate budgets are available to replace aging and/or deteriorating assets and align renewals with other infrastructure upgrades/renewals.</p> <p><b>3 Waters Regulation</b> – will have a significant impact on the way the water service is delivered, managed, operated, maintained, monitored and reported on. There will be an increased holistic approach to 3 Waters management.</p> <p><b>3 Waters Reform</b> - Ongoing response to Government Water Services reform programme, ‘Local Water Done Well’.</p>
<p><b>COMPLIANCE</b></p>	<p><b>Resource Consents</b> - Council has a number of water related resource consents and aims to achieve compliance with all resource consent conditions. Regular compliance monitoring and reporting is undertaken.</p>
<p><b>SERVICE DELIVERY</b></p> 	<p><b>Service Delivery</b> - the water activity is delivered via a combination of in-house resources and contracted services with the operation and maintenance activities undertaken by inhouse resources. Operation and maintenance costs will increase:</p> <ul style="list-style-type: none"> <li>• To ensure compliance with DWSNZ &amp; DWQAR</li> <li>• To ensure compliance with Resource Consents</li> <li>• As a result of expanding asset base</li> <li>• Increased community expectations</li> </ul>
<p><b>PERFORMANCE</b></p>	<p><b>Performance</b> - a comprehensive performance monitoring and reporting framework ensures that legislative requirements and other KPIs are regularly assessed and reported on.</p>
<p><b>RISK &amp; RESILIENCE</b></p>	<p>The ability to deliver capital projects on time may be affected by the skills shortage and availability of construction contractors.</p> <p><b>Understand</b> our communities, the hazards and risks and acknowledge that failure will occur.</p> <p><b>Ensure</b> early detection and recovery through connecting communities, supporting community organisations and robust infrastructure assets.</p>



## 1.1 What are we doing?

We protect public health and the environment by supplying water to the District's population through the operation of seven individual water supplies. These water supplies consist of:

- Waimate Urban
- Cannington Motukaika
- Hook Waituna
- Lower Waihao
- Otaio Makikihi
- Waihaorunga
- Waikakahi

Council supports this service by:

- Providing, operating and maintaining of water infrastructure in compliance with New Zealand legislation and standards
- Responding to call outs and service disruptions quickly and efficiently
- Planning for future development and needs

## 1.2 Why are we doing it?

Council has a legal obligation under the Health Act 1956 to improve, promote, and protect public health within the District. The Water Services Act 2021 places a further obligation on Council to comply with the Drinking Water Standards for New Zealand and the Drinking Water Quality Assurance Rules. In terms of the Local Government Act 2002 the continued operation of Water Supplies is required unless specific approval is sought to withdraw from the activity (in whole or part). The Council sees the provision of reliable and safe drinking water to the community as a major contribution to the District's economy and to residents' wellbeing.

Council's water supply activity contributes primarily to the following community outcomes:

**Table 1-1: WDC Community Outcomes**

Community outcome	How it contributes
<b>Thriving Community</b> A District that provides infrastructure for economic activity	The timely provision of utility services is essential to supporting growth
<b>Safe and Healthy People</b> A place where people are safe in their homes, work and public spaces Our services, infrastructure and environment enhance quality of life	Protecting the communities from drinking water-related health issues and providing firefighting capability  We have reliable, efficient and well planned water, wastewater, stormwater and solid waste infrastructure that meet the needs of residents  A resilient and adaptive community in a changing environment
<b>Sustainable District and Environment</b> We value the natural environment, biodiversity and landscapes	Water is used efficiently and in a sustainable manner

Council identified a number of significant negative effects that the water activity may have on the wellbeing of the community and the environment. Council developed appropriate mitigation measures to eliminate or minimise these effects.

### 1.3 Where are we headed?

Council's strategic goals for water over the next ten years is:

- To ensure that adequate water schemes are provided and maintained for the wellbeing of the public both now and in the reasonably foreseeable future
- To ensure that the long-term operation and maintenance of the water treatment facilities are environmentally sustainable
- To demonstrate responsible management in the operation, maintenance, renewal and disposal of Council owned water assets

There are a number of key issues facing Council over the next ten years and beyond:

- Continue compliance with the Water Services Act and investment in assets and resources to meet the Drinking Water Standards for New Zealand
- Central Government's 3 Waters Review and reform programme which has changed from 'Affordable Water' to 'Local Water Done Well' focussing on:
  - Repealing Water Services Entities legislation
  - Water quality i.e. safe, reliable drinking water
  - Water Services Infrastructure investment including Water Infrastructure Regulator
  - Improved management of wastewater and stormwater services
  - Financially sustainable water services
- Development of a plan on how Council will transition to a new water services model that meets water quality and infrastructure investment rules, while being financially sustainable in the long term
- Compliance with drinking water regulatory framework, including but not limited to:
  - strengthened Water Safety Plans, with an a multi-barrier approach to ensuring drinking water safety
  - identifying and managing risks, source protection, treatment and reticulation
  - maintaining disinfection residuals in the reticulation
  - boundary backflow prevention
  - storage management
  - fluoridation
  - increased accountability
  - competency framework
- Increased costs as a result of:
  - operation and maintenance costs
  - monitoring costs
  - training and qualification requirements
- Increased focus on ageing and failing infrastructure
- Maintaining appropriate data and monitoring systems
- Ensure adequate in-house staff resource capacity and capability
- Progressively increase resilience of the water supply service
- Climate change impacts
- Investigating and implementing improved efficiencies
- Ongoing affordability of the water supply
- Managing water demand
- Capital works totalling \$11.3m over the LTP period for Water Assets
- Renewal works totalling \$8.2m over the LTP period for Water Assets

The main focus for Council over the past number of years has been to improve water treatment throughout the district to comply with the Water Services legislation. Achieving compliance with

the legislation and Water Services Regulations will continue during the first two years of this Plan. Achieving compliance requires significant capital works to upgrade the treatment process at a number of water treatment plants in the District and is estimated to cost \$6.2million over the first two years.

Operation and maintenance costs of the upgraded water treatment plants are expected to be significantly higher than current due to the more sophisticated treatment plants and increased monitoring of water supplies necessary to comply with the Regulations and Rules.

Council will continue to investigate options to ensure the ongoing affordability of the water supply through innovation in governing, operating and maintaining the water supplies.

In addition to the need to comply with the Water Services legislation, there is an ongoing need to improve maintenance and development of the water network to meet future demand. The continued development and implementation of a robust asset renewal plan is an ongoing area of focus.

The District's future development relies heavily on the availability of water and the responsible management, distribution and protection of existing and future water sources.

Additional information on the effect of climate change on water supplies is expected to be available over the next decade. The Council will consider the impact that climate change may have on the security of supplies when additional information is available and there is greater certainty on the impact that this may have locally.

The water system represents a significant community investment. With age, asset condition and service potential reduce, and an important aspect of asset management is determining the right time and right level of renewals investment in order to maintain the agreed levels of service over the long term. Council will continue implementing the appropriate intervention strategies i.e. a combination of maintenance, repair and renewal activities to maintain the service.

#### **1.4 How will we get there?**

Council plans to maintain current levels of service for the life of this plan, unless legislation, consent conditions, or community expectations change. Over the next ten years Council plans to:

- Maintain consumer access to safe water
- Continue to invest in the implementation of Drink Water Standards and Drinking Water Quality Assurance Rules (DWQAR), and water safety upgrades to ensure a continuous supply of safe water
- Continue to monitor and respond to the Government's new Water Regulatory Framework
- Continue to develop and implement a robust water safety management framework
- Continue maintenance and renewal of the water network to meet the needs of current and future consumers
- Plan for future development and needs
- Protect the environment through resource consent compliance
- Consult with the community on issues such as health and legislative compliance issues

This vision is supported by a detailed water asset management plan.

### 1.5 What Will it Cost?

The table below summarises the 2024-2034 water budget forecasts:

**Table 1-2: 2024-2034 Budget Forecasts**


Year	Operating Expenditure	Capital (LOS/Growth/REN)	Total
Enhanced AP 2024/25	3,704,407	2,655,950	6,360,357
2025/26	4,145,964	11,110,650	15,256,614
2026/27	4,630,584	740,211	5,370,795
2027/28	4,830,560	1,591,933	6,422,493
2028/29	4,957,225	2,222,957	7,180,182
2029/30	5,089,135	1,076,078	6,165,213
2030/31	5,266,105	1,036,595	6,302,700
2031/32	5,328,636	1,612,425	6,941,061
2032/33	5,419,058	1,826,868	7,245,925
2033/34	5,560,729	2,458,627	8,019,356
<b>10 Year Total</b>	<b>48,932,403</b>	<b>26,332,294</b>	<b>75,264,698</b>

Significant projects (greater than \$500,000 over 10 year period) and their funding sources are summarised in the following table and chart:

**Table 1-3: Significant Water Capital Projects**

Significant Capital Projects	Year	10 Year Total
<b>Additional Capacity</b>		<b>3,092,000</b>
531076024 - Urban Water - Booster Bakers/Court/Hunts/Fitzmaurice Road	2025	<b>540,000</b>
531076025 - Urban Water - Extension Bakers/Court/Hunts/Fitzmaurice Road	2028 – 29	<b>1,136,000</b>
531076028 - Urban Water - Te Kiteroa Main, Booster and Reservoir	2025 – 26	<b>1,416,000</b>
<b>Level of Service</b>		<b>2,976,145</b>
513076022 - Hook / Waituna - PVC Tavistock Hook supply link	2026	<b>2,390,900</b>
531076034 - Urban Water - Pressure management High Street rising mains	2027 - 29	<b>585,245</b>
<b>Renewals</b>		<b>8,635,571</b>
513076001 - Hook / Waituna - Renewals	2025 – 34	<b>611,789</b>
515076002 - Otaio / Makikihi - Renewals	2025 – 34	<b>1,189,222</b>
517076001 - Waikakahi - Renewals	2025 – 34	<b>1,191,041</b>
531076001 - Urban Water - Rising main renewals	2025 – 34	<b>5,643,518</b>
<b>Renewal/Level of Service</b>		<b>7,975,465</b>
511076002 - Cannington - Drinking Water compliance upgrade	2026	<b>1,200,000</b>
511076009 - Cannington - 80mm Line "Slip Line" (700m x 125mm PE)	2033 – 34	<b>653,939</b>
513076005 - Hook / Waituna - Drinking water compliance upgrade	2025 – 26	<b>1,429,100</b>
515076005 - Otaio / Makikihi - Makikihi township mains renewal	2026 – 29 & 2032	<b>592,426</b>
516076003 - Waihaorunga - Drinking water compliance upgrade	2026	<b>1,200,000</b>
517076003 - Waikakahi - Drinking water compliance upgrade	2026	<b>2,900,000</b>
<b>Total</b>		<b>22,679,182</b>

The chart following provides an overview of the 2024 LTP Capital Programme:





## 1.6 How well are we doing and how well do we measure progress?

Council will continue to report on the non-financial performance measures, in accordance with 261B of the Local Government Act 2002, as this covers the key expectations in terms of the delivery of the service.

Council have reviewed and updated its systems and processes to ensure alignment and compliance with these rules.

The linkage between community outcomes, levels of service and performance measurement is shown in the following table:

**Table 1-4: Community Outcomes**

Community Outcomes	Level of Service	Performance Measure
<b>Safe and Healthy People</b> A place where people are safe in their homes, work and public spaces Our services, infrastructure and environment enhance quality of life	Safe drinking water	DWSNZ Compliance (NFPM1)
	Customer satisfaction	Number of complaints (NFPM4)
		Average consumption of drinking water (NFPM 5)
<b>Thriving Community</b> A District that provides infrastructure for economic activity	Fault response	Response & Resolution times (NFPM3)
<b>Sustainable District and Environment</b> We value the natural environment, biodiversity and landscapes	Maintenance of the reticulation	Real water losses from reticulation (NFPM2)

Council had to report on non-financial performance measures in its Annual Report from 2015/16. However, the new Water Services Regulatory framework makes the Water Services (Drinking Water Standards for New Zealand) Regulations 2022 and Drinking Water Quality Assurance Rules compulsory.

During November 2022, the Water Services Regulator (Taumata Arowai) introduced new Drinking Water Quality Assurance Rules (as they relate to bacteria and protozoa). From 15 November 2022 Councils have to report against the Drinking Water Quality Assurance Rules as they relate to bacteria and protozoa.

The new Drinking Water Quality Assurance Rules have similar standards to the former Drinking Water Standards for New Zealand 2005 provided by the Ministry of Health.

**Table 1-5: Drinking Water Quality Assurance Rule Compliance**

Water Supply	Treatment	Bacteriological Compliance	Protozoal Compliance	Chemical Compliance	Cyanobacterial Compliance	Radiological Compliance
Cannington/Motukaika	Chlorine	Non-compliant**	Non-compliant*	Complies	Complies*	Not assessed
Hook/Waituna	Chlorine	Minor non compliance	Non-compliant*	Complies	Complies*	Not assessed
Lower Waihao	Chlorine	Minor non compliance	Non-compliant*	Complies	Complies*	Not assessed
Otaio/Makikihi	UV & Chlorine	Compliant	Non-compliant*	Complies	Not assessed (Deep bore)	Compliant
Waihaorunga	Chlorine	Non-compliant**	Non-compliant*	Complies	Minor non compliance	Not assessed
Waikakahi	Chlorine	Compliant	Non-compliant*	Complies	Minor non compliance	Not assessed
Waimate	UV & Chlorine	Minor non compliance	Non-compliant*	Complies	Not assessed (Deep bore)	Compliant

\*Non-compliant- WDC reported non-compliance in DWO Annual Compliance Survey  
 \*\*Not assessed - Treatment plant / Source not in use during the 2021/2022 compliance year  
 +Complies – WDC did not indicate risk of cyanotoxins in supply in relevant WSP risk tables – further investigation required  
 ++Non-compliant – E. coli transgression. Samples collected does not meet criteria A1.4 of DWSNZ  
 Note 1: DWA leniency – where (minor) technical non-compliances occurred, the audit team will note the occurrences and recommend compliance, however this is to be seen as a recommendation only.  
 Waimate Urban (G01525) bore has been granted secure bore status in November 2017. Over the 2021/2022 compliance period, no E. coli was detected in the bore in accordance with Section 4.4.4 of DWSNZ 2005:2018

## 1.7 What resources do we have and what resources do we need?

### People

The Water and Wastes Unit has seven full time equivalent staff, including operational staff. The Water and Wastes Unit provides management and engineering expertise to the Asset Group. The Unit utilises Council inhouse unit and contractors to maintain, renew, and construct assets through various contractual agreements. The Unit augments its skill base through the engagement of specialist consultants as required to undertake specific projects and works. The Water and Wastes Unit is modestly resourced, but the outcomes of the new regulatory framework and Government 3 Waters Review will place even greater demands on already stretched resources.

It is likely that a shortage of technically skilled people to design, construct and manage water assets will continue to have an impact on this activity in future years. This is a global issue which is also affecting other local authorities.

### Physical Assets

Council manages seven public water supply systems. These systems consist of treatment facilities, pipes, pump stations and other assets.



**Table 1-6: Water Physical Assets Summary**

Item	Units
Length of water mains =	910 km
Length of water laterals	22 km
Number of valves/hydrants =	809/367
Number of pump stations =	18

The latest valuation, June 2024, estimates the replacement value of the water supply system to be \$57.5m.

### **1.8 Who pays for it?**

This activity is funded by targeted rates from properties that have access to water supply systems.

## 2.0 INTRODUCTION

*This section sets out the scope and objectives of this Asset Management Plan (AMP), describes the interrelationships with other planning documents of the Waimate District Council (Council), shows the AMP framework and describes the asset management progress.*

### 2.1 Purpose of the AMP

The purpose of this AMP is to outline and to summarise in a coordinated manner the Council's long-term management approach (more commonly called Asset Management) for the provision and maintenance of Water Services throughout the District.

This AMP demonstrates how Council will:

- Detail the extent and quality of services demanded (or required) by the community and legislation now and in the future
- Have clear linkage to community agreed outcomes and the agreed Levels of Service
- Prudently manage the acquisition, maintenance, operation, renewal and disposal of water assets in ways that optimise the value of services delivered to the community
- Assess the risks of failing to deliver levels of service for its activities and provide appropriate means of mitigating those risks
- Justify short, medium, and long term funding requirements
- Manage the risk of asset failure
- Provide adequate funding to manage the assets according to assessed priorities
- Proactively improve knowledge of its assets

This AMP is intended to be read in conjunction with the enhanced 2024/25 Annual Plan and 2025-2034 LTP and fulfils requirements of the Local Government Act 2002 (and amendments), Schedule 10.

#### **Asset Management**

The overall objective of Asset Management is to:

*Deliver the required Level of Service to existing and future customers in the most cost-effective manner.*

## 2.2 Time Period of this Plan

This Plan unusually covers a nine year period 2025-2034 due to the following:-

The Water Services Acts Repeal Act was enacted in February 2024, and includes a number of transitional arrangement(s) for local authorities. The Act will include transitional arrangements for local authorities to include water services provision in their 2024-34 long-term plans, including: an

*...provisions allowing local authorities to defer their 2024-2034 long-term plan by a year, replaced by an 'enhanced' annual plan for the 2024/25 financial year. A council must make a decision to do so by 30 April 2024, and if it does not, it may be authorised to defer its plan by Order in Council.*

Based on this, Council decided to defer the 2024-34 Long-term Plan for one year and consulted on a 2024-25 Enhanced Annual Plan with the additions laid out in the new legislation and adopts a Long-Term Plan (2025-34) by 30 June 2025.

The financial budget forecasts in this AMP cover:

- 2024/25 Enhanced Annual Plan budgets
- 2025/26 -2033/34 LTP budgets

## 2.3 Assets Included in This AMP

The Council is responsible for one urban scheme and six rural water schemes. The rural schemes also supply the small communities of Studholme, Glenavy, Morven and Makikihi.

**Table 2-1: Council Water Schemes**

Scheme	Year Installed	Population served	Water mains (kms)	Replacement Costs
Waimate Urban	1906	3416	68.5	\$30,104,603
Cannington Motukaika	1973	90	54.7	\$1,233,767
Hook Waituna			256.2	\$6,586,371
- Studholme (25m <sup>3</sup> /day)	1973	962		
Lower Waihao			132.2	\$6,286,235
- Glenavy (200m <sup>3</sup> /day)	1978	700		
- Morven (50m <sup>3</sup> /day)				
Otaio Makikihi			158.9	\$6,451,049
- Makikihi (100m <sup>3</sup> /day)	1969	422		
Waihaorunga	1977	99	65.4	\$1,403,428
Waikakahi	1973	344	174.3	\$5,329,281
SCADA				\$123,188
<b>Total</b>			<b>910.1</b>	<b>\$57,517,921</b>

*Water main lengths and Replacement costs from 3 Waters Infrastructure Valuation as at 30 June 2024*

There are three other rural schemes within the Waimate District:

- The Downlands water scheme is operated and managed by the Timaru District Council and provides water to properties within the Waimate District including St Andrews. The Council has a 14% stake holding in the scheme but has no direct involvement in the scheme apart from the collection of water rates on those properties.

- The Hakataramea Valley and Cattle Creek rural water schemes are within the Waimate District. Therefore, they have not been included in this AMP as they are administered and operated privately by an incorporated society.

### Replacement Cost of the Water Services Assets

In 2013 a major review of insurances was undertaken with adjustments to values on a practical basis as determined by Council staff. All figures were agreed and ratified by Council by way of formal resolution when recommendations regarding insurance levels and values were discussed in detail.

The replacement cost of the Water Services assets, owned by Council are shown below:

**Table 2-2: Summary of Water Scheme Assets Replacement Costs**

Valuation Category	Asset Description	Units	Quantity	ORC
Plant	Treatment Plants	No	10	\$8,499,209
	Booster Stations	No	11	
	Bores	No	5	
	Reservoirs	No	13	
Point Assets	Valves	No	809	\$5,787,878
	Hydrants	No	367	
	Manifold & meter	No	2007	
	Manifold only	No	4	
	Meters	No	48	
	Tobies	No	62	
Lines	Mains	km	910.1	\$43,230,834
	Services	km	22.2	
	Phone & Power Cables	km	0.9	
<b>TOTAL</b>				<b>\$57,517,921</b>
<i>Asset Quantities from Univerus Assets and Replacement costs from 3 Waters Infrastructure Valuation as at 30 June 2024</i>				

## 2.4 Relationship with Other Plans

The AMP relates to the LTP and other key Council plans, documents, policies and processes. These are mainly driven by legislation and obligations that central government, through legislation, devolved to local authorities. The community outcomes guide the strategic and day to day decision making for the Council.

## 2.5 How This AMP will be Used

### 2.5.1 Development of an Asset Management Culture

The ongoing development and successful implementation of asset management requires an organisational culture of asset management from both 'bottom-up' and 'top-down'. To be successful the asset management culture needs to be consistently modelled and supported by the Chief Executive and senior managers in conjunction with the elected Council.

It also needs to align with and reflect the LTP and strategies. These requirements are supported in the new ISO 55000 standard for asset management. This process has been reinforced by the establishment of the Council's Asset Management Policy in 2009 and the AMP Policy process included in Section 2.7.

## 2.5.2 Roles and Responsibilities of Council Staff

The roles and responsibilities of Council staff have been defined to enable the AMP to remain relevant and current. The table below details how this will be carried out within Council:

**Table 2-3: Activity Management Plan Enactment**

	Item	How is this done
1	Organisational culture of asset management developed	Asset Management Policy 2023
2	Council Staff understand the reasons for the AMPs and the implications for the long term use of them	On department basis
3	The AMPs are adopted/accepted by staff	Adopted by Council
4	Council staff understand what is in the AMPs and how it could affect their day to day work including their responsibilities and reporting requirements as detailed in the different sections within the AMP	Training Programme
5	Understand all the reporting requirements for Levels of Service and Internal Benchmarking	Training Programme and Implementation of LGA 2002 amendments

## 2.5.3 Resourcing of Asset Management Programmes

To be effective asset management programmes must be adequately resourced and therefore require ongoing budget to deliver identified improvements and keep AMPs and processes current with evolving practice. For asset management to be successful in Waimate District there must be a commitment recognised across the organisation. This commitment must translate into budget, human resources, and management accountability.

## 2.5.4 Implementation

This AMP includes improvement and expenditure programmes that will be implemented with the objective of achieving community outcomes and delivering the stated Levels of Service for the Water Services activity.

## 2.6 Water Supply Activity Objectives

The sustainable use of a safe water supply is fundamental to the health of all people and to the protection of the natural environment.

In fulfilling Council's responsibilities to ensure that occupied buildings are sanitary the Local Government Act and the Health Act require the Council to continue to provide the reticulated water services that it owns and maintain its capacity (section 130 of LGA).

The Council provides drinking water to all urban areas and significant section of the plains rural area. These services provide an effective way to protect public health and to protect the natural environment.

## 2.7 Council's AM Policy – Appropriate Level

The WDC has an adopted Asset Management Policy. The purposes of the policy are to:

- satisfy the requirements outlined in the 2020 IIMM, Section 2.1.5

- determine the appropriate level of sophistication for asset management of infrastructure activities (Roading, Utilities (Water, Stormwater & Wastewater), Solid Waste, Community Property, and Parks & Reserves) to be managed
- ensure that Council's service delivery is optimised to deliver the purpose of local government (as defined in the Local Government Act 2002), agreed community outcomes and levels of service, manage related risks, and optimise expenditure over the entire lifecycle of the service delivery, using appropriate assets and non-asset solutions as required

### **2.7.1 Objective of the Asset Management Policy**

The objective of the Council's Asset Management Policy is to ensure that Council's service delivery is optimised to deliver agreed community outcomes and Levels of Service, manage related risks, and optimise expenditure over the entire lifecycle of the service delivery, using appropriate assets and levels of management as required. The delivery of service is required to be sustainable in the long term and deliver on Council's economic, environmental, social, and cultural objectives.

The Asset Management Policy requires that the management of assets be in a systematic process to guide planning, acquisition, operation and maintenance, renewal and disposal of the required assets.

The Council's Asset Management Policy sets the appropriate level of asset management practice for Council's Utilities, Community Facilities and Transportation.

### **Asset Management Policy Principles**

The following principles will be used by Council to guide asset management planning and decision making:

- Effective consultation to determine appropriate Levels of Service
- Ensuring service delivery needs form the basis of asset management
- Integration of asset management within and across Council utilising corporate, financial, business and budgetary planning using activity management plans and Council's LTP to demonstrate this
- Integration of asset management within Council's strategic, tactical and operational planning frameworks
- Informed decision making taking a lifecycle management and inter-generational approach to asset planning
- Transparent and accountable asset management decision making
- Sustainable management providing for present needs whilst sustaining resources for future generations


### **Policy Linkages to Other Plans**

This Asset Management Policy links to Council's LTP and the Water Services asset management. An approach where planning is based around communities of interest is favoured, as this aims to promote an integrated management regime and encourage efficiencies across the District's Water Services.

### **Structured Assessment of Asset Management Practice**

Council has undertaken a structured assessment of the appropriate level of asset management practice for the Water assets in August 2009. This structured assessment follows the guidance provided in Section 2.2.4 of the International Infrastructure Management Manual (IIMM) 2006. The results of this assessment were that the Water was considered Core.

Figure 2-1: Level of Asset Management



### Review of Policy

This Asset Management Policy 316 has been adopted by Council on 15 August 2023.

### Asset Management Implementation Strategy

Council staff has completed a detailed analysis of appropriate asset management practice within the guidance offered by this Policy. This analysis has examined asset description, Levels of Service, managing growth, risk management, asset lifecycle decision making, financial forecasts, planning assumptions and confidence levels, improvement programmes, use of qualified persons and Council commitment to asset management planning.


### Appropriate Practice Policy

Develop a long term improvement programme to achieve the Council’s appropriate practice policy.

### 2.7.2 Water AMP Compliance Status

The assessment on the Water AMP in 2014 indicates a minor change in the management of the assets has occurred since the 2012 assessment was carried out. The long term programme to achieve the appropriate AM level, as shown in Section 10, will assist in this process.

Figure 2-2: Water AMP Compliance Status (2012 & 2014)



### 2.8 Key Stakeholders

Key stakeholders are those who have significant specific involvement with the assets and/or the service facilitated by the assets and describes their particular main interests and is limited to the main issues for key stakeholder groups. ‘Public Service providers’ include schools, dentists, doctors, hospitals, and other government organisations. ‘Asset Managers’ are those District Council staff

## Section 2: Introduction

(engineers and others) whose responsibility it is to manage the services made possible by the assets covered in this AMP.

The key stakeholders and the outcomes that they require for the Water Activity are detailed in the table below. Different issues will require different levels of consultation; from a broad approach to specific and limited to those directly affected. This is indicated under Consultation Range (Broad \*\*\*, Moderate \*\*, Limited \*).

**Table 2-4: Waimate District Stakeholders**

Key Stakeholder		Consultation Range	Desired Stakeholder Outcome(s)
External	Council customers and resident population	***	Reliable service that meets strategic and sustainable drivers
	Canterbury Regional Council	**	Resource use is sustainable as directed in the RMA 1991
	Local Government New Zealand or Central Government	*	Ensure that Local Government Act is complied with (via Auditor-General)
	Department of Conservation	*	Enhance conservation value of natural waterways (i.e. rivers/streams)
	Local Iwi/Ngai Tahu	*	Enhance waterways and Mahinga kai, cultural/spiritual values
	Taumata Arowai	**	Compliance with regulator requirements
	Local Businesses/Industries	**	Water services to suit commercial needs and expansion, at affordable cost
	Wider Community	*	Enhance landscape and aesthetic values of farmland and plains
	Ministry of Health	*	Water quality is suitable, consistently assured, does not spread diseases
Internal	Waimate District Council	***	Maximise the four aspects of wellbeing through provision of the Water Services Activity
	Elected Officials	***	Owner of assets, responsible for sustainable service levels under the LGA 2002 (2012 amendment)
	Council committees	*	As per delegated authority from Council
	Executive	***	Compliance with regulations, service reliability, quality and economy
	Asset Managers	*	As above plus policy, planning and implementation of infrastructure and service management activities (e.g. operations, demand management, maintenance, construction). Safety. Effective corporate support for decision-making, service management, procurement, finance, communications, IT, staff and other resources
	Planners	*	AMP support for LTPs. Infrastructure support for current/future district activities
	Finance	**	Proper accounting for assets and for services consumed by asset management activities
Customer Services	*	Systems which minimise and resolve complaints/enquiries about service	



Key Stakeholder	Consultation Range	Desired Stakeholder Outcome(s)
Information Services	*	Clarity of technical and budget requirements for systems and support

### 2.8.1 Rural Water Scheme Committees

Each rural water scheme (except Lower Waihao) has a local advisory committee elected every three years at a specially convened public meeting. The purpose of the committee is to consult with its community and relay local concerns and preferences to the Council. The committees have terms of reference, which provide direction on their governance role. The terms of reference have been reviewed but require ratification by Council.

While committees play a significant role in the management of the Water Services, ultimate responsibility, and hence risk, lies with Council as both the owner of the asset and the Water Supplier.

### 2.8.2 Relationships with Other Bodies and Organisations

#### Tangata Whenua - kaitiakitanga, tikanga

For Maori, linking the past, present and the future is an important concept of life. There is much value in learning from the past in planning for the future. Kaitiakitanga – safeguarding our future (guardianship) and Tikanga (protocols) are two powerful concepts embodied in Maori culture.

Council will seek to understand and exercise the principles of Kaitiakitanga so those who follow can enjoy what we enjoy today and seek to establish the right Tikanga that will enable us to deliver Water Services in an integrated and sustainable way.

#### Canterbury Regional Council - Environment Canterbury (ECan)

Environment Canterbury is delegated responsibility for management of the water resources within the District and achieves this through Regional Plans. These plans provide a framework for the sustainable environmental management of Canterbury's physical and natural resources. The change of use of land, taking of water, diverting of water, disposal of water, and discharge to air, require resource consents. Therefore, Council must liaise with Environment Canterbury in obtaining and complying with consents in relation to the Water Services Activity.

#### Water New Zealand

Water NZ provides a forum for the exchange of ideas between those involved in the 'water industry'. Water NZ also manages projects such as the development of national codes of practice. In recent times, Water NZ has taken on the role of lobbyist to Government on water issues.

#### ENGINEERING NEW ZEALAND, ĀPŌPŌ, IPWEA NZ, LGNZ, [TAITUARĀ](#)

Each of these organisations provides peer support and exchange of information to foster appropriate practice and share/manage issues that arise.

### 2.8.3 Community and Public Health

Community and Public Health (CPH) have an interest in ensuring the public health of communities on behalf of the Ministry of Health. With respect to the Waters assets this role is predominantly concerned with the quality of drinking water the Council supplies to its consumers, and the disposal of wastewater effluent where this could compromise community health.

CPH is the agency through which annual audits of the performance of Council's drinking water supplies against drinking water standards are implemented and through which applications for capital assistance from government for upgrades can be made. They are the regulator of Councils' water supplies under both the Health Act 1956 and the Health (Drinking Water) Amendment Act 2007.

### **2.8.4 Other Organisations**

Council has a consultative relationship with other organisations including:

- Fish and Game, Central South Island
- Irrigation New Zealand
- Meridian
- Federated Farmers

## **2.9 Progress in Development of Asset Management**

### **2.9.1 Background**

Asset management in New Zealand has developed over the last 20 years in response to the requirement to justify and improve the level of investment in and management of community driven infrastructure. Council's asset management has mirrored this development to the point that it will be at the appropriate level within six to nine years.

This is a seventh generation AMP for the rural schemes and an eighth generation AMP for the urban scheme with the first AMP being produced in 2002.

### **2.9.2 Key Advances in the 2023 AMP**

The following matters represent the most significant changes to this AMP, over the period 2011-2023

- Data – Systems and Quality
- Asset Data Capture
- Asset Data Quality
- Complaints resolution
- Criticality Assessment
- Condition Assessments
- Government and Industry Direction

### **2.10 AMP Information**


The information for this Water AMP has been derived from the following sources:

- 2024 Valuation (June 2024)
- [2021 AMP](#)
- Council reports and staff knowledge

### **2.11 AMP Format**

A top down approach has been taken to develop the AMP, using existing data followed by data improvement. The structure of this plan mirrors the logical process followed for asset management planning as shown below:

**Figure 2-3: Asset Management Process**



### 2.11.1 Key Elements of this Asset Management Plan

The key elements of this AMP are shown in the table below:

**Table 2-5: Key Elements of AMP**

Section	Content
<b>Section 1:</b> Summary	Describe the challenges and aspirations faced by the Water activity and inform of the strategic direction for the short term and long term.
<b>Section 2:</b> Introduction	Sets out the purpose of this AMP, indicates the key stakeholders, describes the asset management progress over the last 15 years and shows the plan framework.
<b>Section 3:</b> Legislation and policy	Details the legislative, policy and planning environment
<b>Section 4:</b> Description of the Water Services Activity	Covers the rationale for ownership of the Water assets and the description of assets covered under this AMP.
<b>Section 5:</b> Levels of Service	The Levels of Service for the Water activity are defined and the performance measures by which the service levels will be assessed.
<b>Section 6:</b> Growth and Demand	Provides details of growth forecasts, which affect the management, and utilisation of the Water assets.
<b>Section 7:</b> Risk Management	Details the Risk Management Processes utilised by Council for assessing and managing risk within the Water activity.
<b>Section 8:</b> Lifecycle Management	Outlines what is planned to manage and operate the assets at the agreed levels of service while optimising lifecycle costs.
<b>Section 9:</b> Financial	Identifies the financial requirements resulting from all the information presented in the previous sections.
<b>Section 10:</b> AM Practices and Processes	Outlines the information available on the assets, information systems used, and process used to make decisions on how the asset will be managed. It also provides details on planning for monitoring the performance of the AMP.
<b>Section 11:</b> Improvement Plan	This section details the improvements to Asset Management within Council that will lead to an increase in confidence in the management of the assets.

### 3.0 GUIDING PRINCIPLES, LEGISLATION, POLICY AND RELATIONSHIPS

#### 3.1 National Strategies and Plans

##### 3.1.1 3 Waters Reform - Local Water Done Well

“Local Water Done Well” is the Coalition Government’s plan for managing water services delivery and infrastructure following the repeal of Water Services Reform legislation (3 Waters) in February 2024. The "Local Water Done Well" policy framework aims to address concerns about New Zealand’s water quality and water services’ infrastructure investment, while keeping control over water services and assets local.

Following the 2023 elections, the new Government repealed legislation relating to 3 Waters service delivery, replacing it with its Local Water Done Well policy. Local Water Done Well policies include:

- Establishing a regulator to oversee water infrastructure, ensuring sustainability, fair pricing, and quality standards,
- Implementing new financial rules, requiring self-funding water services, revenue to cover maintenance, and sufficient borrowing for growth, and
- Within a year of repealing the 10-entity model, councils have to submit alternative service delivery models (Water Service Delivery Plans) to the Minister for approval. There is flexibility for councils to choose a model and governance structure that works best for them.

The new water services legislation includes:

- The **Water Services Acts Repeal Act (enacted in February 2024)** repealed the previous Government’s water services legislation and restored continues council ownership and control of water services.
- The **Local Government Water Services Preliminary Arrangements Act** was enacted on 2 September 2024. Key areas included in this Act are:
  - Requirements for councils to develop Water Services Delivery Plans (within 12 months of the Bill being enacted).
  - Requirements for those councils to include in those Plans baseline information about their water services operations, assets, revenue, expenditure, pricing, and projected capital expenditure, as well as necessary financing arrangements, as a first step to future economic regulation.
  - Streamlined consultation and decision-making processes for setting up council-controlled organisations that deliver water services, and joint local government arrangements, both of which are currently provided for in the Local Government Act.
  - Provisions to enable new, financially sustainable model for Watercare
  - Interim changes to the Water Services Act that means the Te Mana o te Wai hierarchy of obligations in the National Policy Statement for Freshwater Management (NPS-FM) will not apply when Taumata Arowai sets wastewater standards.
- The proposed **Local Government Water Services Bill** will establish the enduring settings for the new water services system.

At this time Council is responding to the new legislative requirements and is in the process of investigating water service delivery options and preparing a Water Service Delivery Plan. Council will continue to monitor and respond to further development with the Government’s Local Water Done Well programme.

### 3.1.2 Other Government/Industry Direction

The table below summarises other key government and industry direction:

**Table 3-1: Other Key Government/Industry Direction**

Source	Direction
Matters arising from our audits of the 2021-31 long-term plans OAG July 2022	<p>Councils are moving to address historical underinvestment in their infrastructure.</p> <p>Many councils made tangible progress in collecting better condition and performance information about their critical assets.</p> <p>Councils set rates at higher levels than they may have previously to fund the increasing costs that they expect to face.</p> <p>Councils provided more discussion about climate change in their long-term plans, including what they were doing to adapt to, and mitigate the risks from, the impacts of climate change on their communities.</p> <p>Councils discussed the uncertainty created by the current significant reforms – 3 Waters reforms, the reform of the Resource Management Act, and the future for Local Government review. These reforms are making the operating context for councils challenging.</p>
Consulting matters: Observations on the 2021-31 consultation documents (OAG December 2021)	<p>Waimate District Council was part of 31 Council who received an unmodified audit opinion with “emphasis of matter” paragraph in respect of the uncertainty over the 3 Waters reforms only</p>
Local Government NZ	<p>In recent years LGNZ have been working on a number of projects and released a number of related papers:</p> <p><b>Housing</b> is a significant issue for our communities’ social and economic futures. Unaffordable housing is having a negative impact on local economies, discretionary household expenditure and social well-being. ‘The case for councils being community housing providers’ – a background paper outlining options to support councils playing more of a role in meeting social housing needs</p> <p><b>Climate change</b> - leading and championing policy to deal with the impacts of climate change is a key policy priority for LGNZ. Climate change poses an unprecedented level of risk and adapting to and mitigating the impacts of climate change is a new priority focus for councils.</p> <p>The report ‘Community engagement on climate change adaptation (Case Studies) documents the challenges three Councils faced and focus on the process of engagement itself.</p> <p><b>Localism</b> - Local government is calling for a shift in the way public decisions are made by advocating for greater self-government at the local and an active programme of devolution and decentralisation.</p>

Source	Direction
<p>Vulnerable: the quantum of local government infrastructure exposed to sea level rise Local Government NZ January 2019</p>	<p>This project has two intended outputs.</p> <ul style="list-style-type: none"> <li>The first is to research the current quantity and value of infrastructure (roads, 3 Waters and buildings) exposed to sea level rise at four increments; 0.5, 1.0, 1.5 and 3.0 metres, and to quantify replacement value.</li> </ul> <p>The second and more important output of this research is to provide responses to rising sea levels. This study intentionally avoids specific and local costs, and targets discussion at a regional and national level in order to highlight trends and general areas of high and low priority. It raises questions about how to improve procurement, appropriately share management of risk, and communicate with stakeholders about priorities.</p>
<p>Water NZ Competency Framework Water NZ</p>	<p>This document explores the workforce skills and capabilities for an effective, efficient, accountable, and resilient 3 Waters sector in New Zealand. It describes what people should be able to do and what they need to know to competently undertake their work. It is a work in progress and includes the following roles.</p> <ul style="list-style-type: none"> <li>Drinking Water Treatment Operators</li> <li>Wastewater Treatment Operators</li> <li>Drinking Water Distribution Operators (to be developed)</li> <li>Wastewater Network Operator (to be developed)</li> </ul>

### 3.1.3 Infrastructure Commission, Te Waihanga

The New Zealand Infrastructure Commission – Te Waihanga – was established in 2019 as an Autonomous Crown Entity to carry out two broad functions – strategy and planning and procurement and delivery support on infrastructure investment.

InfraCom - Te Waihanga will work with central and local government, the private sector, iwi and other stakeholders, to develop a 30-year infrastructure strategy to replace the National Infrastructure Plan.

‘Rautaki Hanganga o Aotearoa 2022 – 2052 New Zealand Infrastructure Strategy’ was published during 2022. The strategy is focused on five objectives i.e. the things we need to do as a nation to achieve the vision of a thriving New Zealand.

1. Enabling a net-zero carbon emissions Aotearoa through rapid development of clean energy and reducing the carbon emissions from infrastructure.
2. Supporting towns and regions to flourish through better physical and digital connectivity and freight and supply chains.
3. Building attractive and inclusive cities that respond to population growth, unaffordable housing and traffic congestion through better long-term planning, pricing and good public transport.
4. Strengthening resilience to shocks and stresses by taking a coordinated and planned approach to risks based on good-quality information.
5. Moving to a circular economy by setting a national direction for waste, managing pressure on landfills and waste-recovery infrastructure and developing a framework for the operation of waste-to-energy infrastructure.

### 3.1.4 National Policy Statement for Freshwater Management (NPSFM)

The Government has commenced the process to replace the National Policy Statement for Freshwater Management. This process is expected to take between 18 to 24 months.

#### Te Mana o te Wai

The NPSFM gave effect to *Te Mana o te Wai*, this is a concept that refers to the fundamental importance of water and recognises that protecting the health of freshwater protects the health and well-being of the wider environment. Notwithstanding the changes to the NPSFM, the concept of *Te Mana o te Wai* remains relevant to all freshwater management as it helps underpin the protection and improvement of our rivers, streams, lakes and other waterbodies and aims to ensure:

- Te Hauora o te Wai - the health and well-being of the water
- Te Hauora o te Tangata - the health and well-being of people
- Te Hauora o te Taiao - the health and well-being of the environment

Changes to the Water Services Act that means the Te Mana o te Wai hierarchy of obligations in the National Policy Statement for Freshwater Management (NPSFM) will not apply when Taumata Arowai sets wastewater standards.

### 3.1.5 National Policy Statement on Urban Development Capacity

The National Policy Statement on Urban Development Capacity 2020 (NPS-UDC) sets out the objectives and policies for providing development capacity under the Resource Management Act 1991.

The amended NPS-UDC came into effect on 20 August 2020 and has been described by the government as “the core issue of increasing land supply”.

The NPS-UDC directs local authorities to provide sufficient development capacity in their resource management plans for housing and business growth to meet demand.

Development capacity refers to the amount of development allowed by zoning and regulations in plans that is supported by infrastructure. This development can be “outwards” (on greenfield sites) and/or “upwards” (by intensifying existing urban environments).

Development infrastructure means the extent they are controlled by a local authority or council-controlled organisation, network infrastructure for water supply, wastewater, or stormwater, and land transport.

## 3.2 Key Legislation and Regulation– Implications for Asset Management

Legislation is established by Central Government and must be complied with at Local Government Level. Significant legislation and regulations affecting the Waters activities are provided in Table 3-2, Council must comply with any relevant legislation enacted by Parliament. Commentary related to some of the key legislation is provided below.

Different legislation has differing levels of impact on the Water Services activities; this is indicated under the Impact Range (Broad \*\*\*, Moderate \*\*, Limited \*).

**Table 3-2: Legislation and Regulation Affecting the Water Services**

Legislation & Regulation	Water Services Range
Building Act 2004 (and amendments)	*
Civil Defence Emergency Management Act 2002	***
Climate Change (Emissions Trading and Renewable Preference) Act 2008	*
Climate Change Response Act 2002 (and amendments)	**
Energy Efficiency and Conservation Act 2000	*
Environmental Protection Authority Act 2011	*
Epidemic Preparedness Amendment Act 2010	*
Fire and Emergency New Zealand Act 2017	**
Health (Drinking Water) Amendment Act 2007	***
Health Act 1956	***
Health and Safety at Work Act 2015	***
Heritage New Zealand Pouhere Taonga Act 2014	*
Infrastructure (Amendments Relating to Utilities Access) Act 2010	**
Local Government Act 2002 (and amendments)	***
Local Government Act 1974 (and amendments)	**
Local Government Rating Act 2002 (and amendments)	**
Local Government Rating Act 1979	*
Ngai Tahu Claims Settlement Act 1998	*
Public Works Act 1981 (and amendments)	*
Reserves Act 1977 (and amendments)	*
Resource Management Act 1991 (and amendments)	***
Taumata Arowai – the Water Services Regulator Act 2020	***
Water Services Act 2021 (parts repealed and updated in 2024)	***
Water Services Acts Repeal Act 2024	***
Local Government Water Services Preliminary Arrangements Act 2024	***
Local Government Water Services Bill	***
Utilities Access Act 2010	***
Water Services (Drinking Water Standards for New Zealand) Regulations 2022	***
Drinking Water Quality Assurance Rules 2022	***



### **3.2.1 Major Legislation Details**

The legislation that has or will have the most effect on the Water services is expanded in Appendix E.

## **3.3 Relevant Regulations Affecting this Activity**

### **3.3.1 The Drinking Water Quality Assurance Rules 2022**

The Drinking Water Quality Assurance Rules have been prepared by the Water Services Regulator (Taumata Arowai) in accordance with section 49 of the Water Services Act 2021. The Rules set out minimum compliance requirements to ensure that water provided to consumers is safe to drink.

Drinking water suppliers may use or undertake additional measures, including the management of risks specifically identified in relation their supplies.

### **3.3.2 Local Government (Financial Reporting and Prudence) Regulations 2014**

Applies to a local authority's financial statements in its annual plan, long-term plan, and annual report. It requires Council to review the required content for long term plans to ensure that they remain fit for purpose, particularly:

- the current suite of mandatory performance measures
- the disclosure requirements for financial and infrastructure strategies
- disclosures required under the Local Government (Financial Reporting and Prudence) Regulations 2014 and
- how assumptions are disclosed in long term plans

## **3.4 Standards, Codes of Practice and Guidelines**

National environmental standards, design standards (AS/NZS ISO), Codes of Practice and Guidelines provide technical direction. National Standards must be complied under the direction of relevant legislation.

### **3.4.1 National Environmental Standards**

National environmental standards are regulations issued under the Resource Management Act 1991 (RMA). They prescribe technical standards, methods and other requirements for environmental matters.

Local and regional councils [or local government] must enforce these standards (or they can enforce stricter standards when the standard provides for this). In this way, national environmental standards ensure consistent minimum standards are maintained throughout all New Zealand's regions and Districts.

### **3.4.2 National Environmental Standard for Sources of Human Drinking Water (2008)**

The 'National Environmental Standard for Sources of Human Drinking Water' is intended to reduce the risk of contaminating drinking water sources such as rivers and groundwater. It does this by requiring regional councils to consider the effects of activities on drinking water sources in their decision making - resource consents and regional plans. Specifically, councils will be required to:

- Decline discharge or water permits that are likely to result in community drinking water becoming unsafe for human consumption following existing treatment.

- Be satisfied that permitted activities in regional plans will not result in community drinking water supplies being unsafe for human consumption following existing treatment.
- Place conditions on relevant resource consents requiring notification of drinking water suppliers if significant unintended events occur (e.g. spills) that may adversely affect sources of human drinking water.

### 3.4.3 AS/NZS Standards

The Code for Subdivision and Development AS/NZS 4404 is the principle document defining design requirements. Wherever possible, relevant AS/NZS standards are used as the basis for determining standards of design and construction.

Standards and guidelines relevant to the Water Services are shown in Table 3-3 below.

**Table 3-3: National Environmental Standards and Guidelines**

Year Released	Technical Discipline: Asset Management
2023	Āpōpō Guide
2020	NAMS International Infrastructure Management Manual
2015	NAMS International Infrastructure Management Manual
2011	NAMS International Infrastructure Management Manual
2014	ISO 55000, ISO 55001 and ISO 55002 - Asset Management
2007 v2.0	NAMS Developing Levels of Service and Performance Measures Guidelines
2004 v1.0	NAMS Optimised Decision Making Guidelines
2006 v2.0	NAMS Infrastructure Asset Valuation and Depreciation Guidelines
2006	NZWWA New Zealand Pipe Inspection Manual
1999	NZWWA The New Zealand Infrastructural Asset Grading Guidelines
	Technical Discipline: National Environmental Standards
2006	NES Sources of Human Drinking-Water
2008	Code of Practice for Fire Fighting Water Supplies NZS PAS 4509:2008 set the minimum flow rates and pressure that must be obtainable from fire hydrants and spacing's.

### 3.4.4 NAMS International Infrastructure Management Manual

This AMP refers to both the 2011 and 2015 guidelines, with significant improvements made in areas including sustainability and Asset Management Policy.

### 3.4.5 ISO 55000 Asset Management 2014

This international standard was released in January 2014 and makes the previous BSI PAS55 Asset Management (2008) standards redundant. The new standard outlines the requirements for a management system for achieving a balance between cost, risk and performance in asset management to help guide asset related decision making and activities.

At the time of writing this Water Services AMP Council has yet to review whether current Council asset management practices will be changed to seek conformance with ISO 55000. However, improvement areas have been identified in this AMP which will assist in the move towards aligning with the requirements of ISO 55000 if this is the direction Council decide to take in the future.

### 3.4.6 Āpōpō Guide

The Āpōpō Guide is an online resource for those practicing infrastructure asset management in Aotearoa New Zealand.

The Āpōpō Guide is more than just a guide - it is a comprehensive compilation of best practices, expert insights, and te ao Māori principles - tailored specifically to the unique context of Aotearoa New Zealand. It brings together internationally sourced practices (such as ISO 55000) with locally-developed guidance (including the Āpōpō digital badges) to provide a holistic approach to infrastructure asset management.

## 3.5 Regional Plans

### 3.5.1 Natural Resources Regional Plan (NRRP)

The NRRP was revoked during February 2017 and replaced with the LWRP.

### 3.5.2 Land and Water Regional Plan (LWRP)

The Land & Water Regional Plan is a new planning framework for Canterbury and aims to provide clear direction on how land and water are to be managed and help deliver community aspirations for water quality in both urban and rural areas.

The Canterbury Land and Water Regional Plan (LWRP) identifies the resource management objectives for managing land and water resources in Canterbury to achieve the purpose of the Resource Management Act 1991. It identifies the policies and rules needed to achieve the objectives and provides direction in terms of the processing of resource consent applications.

This LWRP is made up of 16 sections and a map volume:

- the first describes Canterbury's land and water resources, interrelated issues that need to be managed, the key partnerships, relationships and processes already underway, including the Canterbury Water Management Strategy (CWMS).
- The second section describes how the Plan works and contains the definitions used in the Plan.
- The subsequent three sections cover the region-wide objectives, policies, and rules.
- Sections 6 to 15 inclusive contain sub-region catchment specific policies and rules, and
- Section 16 contains the schedules.
- The maps referred to in the rules are in a separate map volume.

Rule 5.111 to 5.115 address small and community water takes. Rule 5.123 to 5.127 addresses the take and use of surface water. Rule 5.128 to 5.132 addresses the take and use of groundwater. The existing community water takes for Waimate public water supplies are discretionary activities and operated under current consents.

### 3.5.3 Regional and Iwi Plans

Regional and Iwi Plans affecting the Water Services activities are listed in Table 3-4. Each of these is a significant document, any impact on the current or proposed Waters Policy must be accounted for.

**Table 3-4: Regional and Iwi Plan Documents**

Canterbury Regional Council Plans	Key Impacts on Water Services
Canterbury Land and Water Regional Plan (LWRP)	Compliance through existing resource consents
Regional Coastal Environment Plan 2011. Covers coastal marine area and the coastal environment and its integrated management.	
Regional Policy Statement Sets the framework for resource management in Canterbury for the next 10 to 15 years	Notified June 2011. Climate change factors included. Currently being reviewed by Ecan, submissions likely in 2024.
Canterbury Water Management Strategy	Drinking Water – ensuring primacy of quality

### 3.5.4 Canterbury Mayoral Forum

The Waimate District Council is part of the Canterbury Mayoral Forum (11 member Councils) consisting of:

- Kaikōura District,
- Hurunui District,
- Waimakariri District,
- Christchurch City,
- Selwyn District,
- Ashburton District,
- Timaru District,
- Mackenzie District,
- Waimate District,
- Waitaki District (part of which lies within the Canterbury Regional Council area), and
- Environment Canterbury

Region wide issues identified by the Joint Working Group include:

- a need for more effort in compliance, monitoring and enforcement
- a greater focus on biodiversity outcomes monitoring and reporting
- opportunities for councils to share approaches and share resources
- addressing scale and complexities of issues, recognising the size of rating bases and capacities of councils.

Key work by Council supporting ecosystem health and biodiversity, drinking water and water use efficiency targets include:

- ecosystem health and biodiversity
  - restore Wainono lagoon
  - District Plan
- 3 Waters
  - Major drinking water upgrades including Hook-Waituna, Lower Waihao, Waihaorunga and Waikakahi
  - Water safety plans in place and implemented
  - Global stormwater discharge consent in place
  - 3 Waters infrastructure renewals
- water use efficiency
  - water savings through upgrade of ageing infrastructure
  - water conservation measures in place
  - urban toby replacement with manifold meters

Key actions to meet 2025 Goals are tabled below:

**Table 3-5: Key Actions to meet 2025 Goals**

<b>Ecosystem Health</b>
<p><b>Biodiversity</b>  <b>Lowland Stream health</b>                      Fulfil requirements to obtain and comply with stormwater consents for townships by 2025.                      Progress improvement to stormwater infrastructure to reduce ecological damage to lowland streams from sediment and contaminants.                      Continue regular community education/behaviour change campaigns on stormwater issues and management.</p>
<p><b>Lowland Stream health</b>                      Review the state and operation of the district’s wastewater treatment plant infrastructure to address and reduce potential impacts on the district’s highly valued rivers.</p>
<p><b>Biodiversity</b>  <b>Drylands</b>                      Identify and map SNAs on private land. Review status of SNAs listed in District Plan in line with NPSIB criteria and requirements by 2026.                      Implement system to actively protect SNAs and maintain indigenous vegetation.                      Work with Environment Canterbury to develop a biodiversity monitoring strategy.                      Secure funding for shared biodiversity role to undertake compliance monitoring.                      Advocate for indigenous biodiversity through regular education/behaviour change campaigns to improve understanding of the importance of protecting and conserving indigenous vegetation.</p>
<p><b>Biodiversity:</b>  <b>Drylands / Hill and High country streams</b>                      Review vegetation clearance rules as part of District Plan review to protect indigenous vegetation.                      Advocate for indigenous biodiversity through regular education/behaviour change campaigns to improve understanding of the importance of protecting and conserving indigenous vegetation.</p>
<b>Source Water Quality</b>
<p>Priority planning for water supply wells and new treatment plants, including rural water schemes (Waihaorunga, Cannington-Motukaika, and Waikakai).                      Review the state and operation of the district’s wastewater treatment plant infrastructure to address and reduce potential impacts on the district’s highly valued rivers and source groundwater Raise awareness of health impacts from high nitrate in drinking water.                      Run campaigns to recommend regular testing of private bores and consider options for secure water supply</p>
<b>Water Use Efficiency</b>
<p>Improve compliance with national regulations on the measurement and reporting of water takes.                      Manage water demand through meeting requirements under LWRP.                      Run local public relations education/behaviour change campaigns on water use efficiency to raise awareness and reduce usage.</p>

Environment Canterbury provides quarterly updates to the Chief Executives Forum and Mayoral Forum on the regionwide progress towards implementing the CWMS. These quarterly reports provide a summary of the last three months’ progress of zone committee projects and provide information on the latest freshwater related policy and RMA planning.

As work progresses on implementing the Fit for Future work programme, future quarterly reports to the Mayoral Forum will focus on reporting on the delivery of the CWMS Targets and review of the Canterbury Biodiversity Strategy in line with national direction.

## **3.6 Waimate District Council Strategies, Plans and Bylaws**

### **3.6.1 Council Strategies**

The following Council Strategies have impacts and are considered as part of the Water Services Activity

- District Wide Strategy
- Economic Development Strategy
- Procurement Strategy
- Infrastructure Strategy

### **3.6.2 Council Planning Documents**

The following Council Planning Documents have impacts and are considered as part of the Water Services Activity

- Waimate District Long Term Plan 2021-31 (current)
- Waimate District Long Term Plan 2025-34 (proposed)
- Waimate District Plan
- Waimate District Council Engineering Design Standards for Subdivisions and Development (NZS 4404:2010)
- Structure Plans
- Waimate District Council AMPs

### **3.6.3 Council Bylaws**

Section 146 of the Local Government Act 2002 provides for a Territorial Authority to make Bylaws in its district for the purposes of managing, regulating against, or protecting from damage, misuse, or loss, or for preventing the use of; the land, structures, or infrastructure associated with the Water Services.

Waimate District Council Consolidated Bylaw 2018, Chapter on Water Services consist of six parts:

- Part 1 General Conditions, applicable to all Network Infrastructure Services.
- Part 2 Urban Water Supply
- Part 3 Rural Water Supply
- Part 4 Stormwater Drainage
- Part 5 Sewerage
- Part 6 Trade Waste

The bylaw defines standards and obligations for the use, consumption, protection, access, conditions of supply and infringements.

### 3.6.4 Council Policies

#### Significance and Engagement Policy

Waimate District Council developed the Significance and Engagement Policy to determine the significance of issues within the District, and how to align Council engagement with the public based on the degree of significance of the issue.

This policy exists to:

- Inform the public can expect from the Waimate District Council regarding community engagement and the ways you can influence and participate in the decision-making of the Council.
- To provide Council with a tool that guides the assessment of significance during decision making. A decision on significance and engagement provides direction on the level of community engagement that might be desirable to enable Council to develop a clearer understanding of community views and preferences on an issue or proposal.

This Policy identifies the following Strategic assets:

- Regent Theatre
- Waimate Public Library - building and collections
- Resource Recovery Park
- Parks and Reserves
- Public Toilets
- Cemeteries
- Roading Networks and connected infrastructure
- Sewerage Networks and Treatment Plants
- Norman Kirk Memorial Pool
- Stormwater Networks
- **Water Treatment, Storage and Supply Networks**
- Community Housing
- Local Government Centre
- Waimate Sports Stadium

#### Earthquake Prone Buildings

Earthquake Prone Buildings are no longer included in a Council Policy but are now included in the Building Act 2004 under, Subpart 6A Building (Earthquake-prone Buildings) Amendment Act 2016. These new provisions came into effect on 1 July 2017.

Council is required to identify potential earthquake prone buildings or parts of Earthquake Prone Buildings and advise building owners that they are required to provide an Engineering Assessment that has been undertaken in accordance with the Earthquake Prone Buildings Methodology.

The Waimate District is designated as being in a Low and Medium Seismic Risk Areas the Council has until 1 July 2032 to identify potential earthquake prone buildings in the district. Council also has the ability to identify potentially Earthquake Prone Buildings at any time if they have reason to suspect it may be Earthquake Prone Building.

This Engineering Assessment is required to be provided by the building owner to the Council within 12 months of the building owner being notified by the Council of their building being considered to be an Earthquake Prone Building.

In the case where a building owner has had an Earthquake Prone Building Assessment undertaken prior to 1 July 2017, then this assessment is to be provided to the Council for review against the Earthquake Prone Building Methodology. The Council will assess these reports against the Earthquake Prone Buildings Methodology and decide whether the report is acceptable or may request either additional information or a new report to be provided.

The Council will also assign the Earthquake Prone Building rating and if it is less than 33% then the rating will be entered into the MBIE National Earthquake Prone Buildings database. The building owner will be required to erect and maintain the prescribed placards in the building in the prescribed locations indicating what the Earthquake Prone Building Rating of their building is until such time as the building is strengthened or demolished. These placards are required to be displayed where they will be clearly visible, so members of the public are aware of the Earthquake Prone Rating of the building.

The period for building owners to undertake strengthening of buildings in the Waimate District is 35 years from the date when the Council advises the building owner of its decision that the building is an Earthquake Prone Building.

### **Dangerous and Insanitary Buildings**

Council has revoked the Earthquake Prone Buildings, Dangerous and Insanitary Building Policy and separated the Dangerous Buildings and Insanitary Buildings into two individual policies to make easier for staff when dealings with these buildings. These new policies were first adopted by Council in December 2017 and subsequently on 15 August 2023

When either a Dangerous or an Insanitary Building are brought to Councils attention an assessment will be undertaken by staff to establish whether they are either Dangerous or Insanitary.

Council staff will work with the building owner to make the building safe and to remove or reduce the danger in the case of both dangerous building and insanitary buildings.





## 4.0 DESCRIPTION OF THE WATER SERVICE

*This section of the AMP covers the rationale for ownership of the Water Services assets and the description of assets covered under this AMP. This section also highlights the critical Water Services assets.*

### 4.1 Waimate District Overview

The Waimate District is located at the southern end of the Canterbury Region. The Canterbury Region has an estimated population of approximately 666,300 as of 2023 Census.

The Waimate District is bounded by the Waitaki and Pareora Rivers to the south and north respectively, the Hakataramea Valley and mountains of Mackenzie District to the West and the Pacific Ocean to the East.

The main centre of population is the town of Waimate itself, a town housing a population of some 3,590 people. This represents approximately 44% of the total population of the district of 8,121 (source 2023 census). Other centres of population include the coastal townships of Glenavy, Willowbridge, Makikihi, Morven and St Andrews.

The Waimate District community profile is presented in the table below:


**Table 4-1: Waimate Community Profile**

Area	3,582 km <sup>2</sup>		
Population (2023 census)	8,121	Households (occupied dwellings)	3,409
Employees	60.11 FTE's (as at 30 June 2023)	Rating system: Mix of General Rates and Targeted Rates	
<b>Infrastructure (as at 30 June 2024):</b>		Total rateable properties	4,145
Length of roads/streets	1,325 km	Average total rates per property	\$3,928 inc. GST
Length of wastewater network (mains and laterals)	62.4km	Council debt	\$3.50m
Length of stormwater network (mains, laterals and drains)	14.0 km	<b>Climate:</b>	
Length of water network (mains and laterals)	932.3 km	Mean Annual Rainfall	600 mm

### 4.2 Description of Activity

Council supplies water to approximately 3253 connections in the water schemes of Waimate Urban, Cannington Motukaika, Hook Waituna, Lower Waihao, Otaio Makikihi, Waihaorunga and Waikakahi. The Water schemes are presented in the figure below:

Figure 4-1: Scheme Location and Area



### 4.3 Summary of Water Assets

The majority of the rural water schemes source their water from river intakes as indicated in the table below. In the rural schemes only the Lower Waihao sources its water from a shallow bore located next to the Waitaki River.

The Waimate Urban scheme sources its water from two bores, the Manchester Road bore (main supply) and Timaru Road Bore (supplementary source).

**Table 4-2: Summary of Water Assets**


Scheme	Year Installed	Treatment Plants	Supply Bores	River Intakes	Pumping Stations	Storage Reservoirs	Dams	Water mains (kms)	Service Lines (kms)	Replacement costs
Waimate Urban	1906	2	2		2	1		68.5	20.4	\$30,104,603
Cannington Motukaika	1973	1		1	1	1		54.7		\$1,233,767
Hook Waituna	1973	1		1	4	4		256.2	1.4	\$6,586,371
Lower Waihao	1972	1	1		3	1		132.2	0.5	\$6,286,235
Otaio Makikihi	1969	1	1	0	1	1		158.9		\$6,451,049
Waihaorunga	1977	2		2	4	4		65.4		\$1,403,428
Waikakahi	1972	1		1	3	2		174.3		\$5,329,281
SCADA										\$123,188
<b>Total</b>		<b>9</b>	<b>4</b>	<b>5</b>	<b>18</b>	<b>14</b>		<b>910.1</b>	<b>22.2</b>	<b>\$57,517,921</b>

*Replacement costs from 3 Waters Infrastructure Valuation as at 30 June 2024*

The water schemes are made up of the following components:

- Water Lines: pipes, mains, connections
- Water Service Lines: property connections
- Water Points: valves, hydrants, manifolds, backflow prevention, meters and tobies
- Water Plant: bores and river Intakes, pumping and valve stations, water treatment plants and reservoirs
- Buildings

**Figure 4-2: Water Components - Replacement Cost**




## 4.4 Water Reticulation

### 4.4.1 Asset Description

The total length of the combined reticulation (mains and service lines) is 932km. The main purpose of the reticulation system is to supply water from service reservoirs or treatment plants to the customer’s point of supply while maintaining the quality of the water. The reticulation system also provides the capacity for fire-fighting supply within the Waimate Urban water scheme. The scheme networks have been hydraulically modelled. The reticulation which includes water mains, water points and service lines make up 85% of the total water asset value with the water mains (>20mm diameter) making up 71%.

The Council has water pipe assets ranging from new to 118 years of age. The distribution of pipe length verses remaining life can be seen in Figure 4-5. A summary of pipe materials is shown in the figure below.

**Figure 4-3: Summary of Pipe Materials**



The majority (76%) of pipe is of a diameter 50mm and less with pipes 51mm to 150mm making up a further 22%. This is as a result of the significant portion of rural schemes, which use small diameter mains for conveyance that do not provide firefighting capabilities. The summary of pipe length versus pipe diameter is presented in the table below:

**Table 4-3: Summary of Pipe Length vs. Diameter**

Diameter (mm)	Length (m)	%
0 – 50	722,759	77%
51 – 100	141,165	15%
101 – 150	63,994	7%
151 – 200	9,778	1%
201 – 250	5,601	1%
251 – 300	134	0%
<b>Total</b>	<b>943,433</b>	<b>100%</b>

**Figure 4-4: Summary of Pipe Length vs Diameter**





Figure 4-5: Pipe Length by Remaining Life



As shown in the figure above there is a significant amount of pipe, 325 km of PE, which will reach the end of its expected economic life within the next 30 years. There is also 11.8km of AC and 13km of CI pipe (all in Waimate Urban supply) that will reach the end of its expected economic life within the next five years.

Council engineers report that the AC pipe in the networks are becoming soft and pipe breaks are expected to increase on AC pipe mains. Monitoring of pipe break frequency will introduce robust data into the renewal strategy.

#### 4.4.2 Condition of Reticulation

Pipe condition ratings for all pipe assets are stored in the Univerus Assets. These condition ratings have been based on pipe age, material and some field inspection.

The base life should be considered as a guideline only. While some non-pipe assets may be “past” their base life, Council engineers consider that they are still able to achieve the desired Level of Service and may do so for some time. Council operators assess asset condition during routine inspections in relation to potential effects on asset performance and reliability.

The condition of the pipe reticulation network can be determined by recording pipe failures and the taking and assessment of pipe samples.

AC condition samples from Waimate Urban water scheme taken during 1999 indicated that pipe failures can be expected approximately 15 years from the date of the pipe evaluation, which is from 2014 onwards.

Cast Iron (CI) condition samples and assessments performed over the past 15 years indicate that a small amount of the CI pipes in the Waimate Urban scheme are near the end of their useful life. Staff have not observed failures in recent years, but performance of some smaller diameter pipes can affect fire flows and not cater for growth in some areas.



Data states there is 13km of CI pipe that will reach the end of its expected economic life within the first five years of this AMP. Further assessment of economic useful lives may reduce this figure significantly and is a future focus / improvement.

Staff will continue to monitor CI pipe breaks and intervene as appropriate.

To date limited pipe sampling has been undertaken for the rural schemes.

Staff are investigating an option of utilising its reactive maintenance records to assist with renewal programming. Since 2013 the utilities business unit has been recording, in real-time, breaks in the field. This dataset is now of considerable size and can be used to perform a statistical analysis to identify renewals. This is not to replace the conventional asset management approach but will compliment it.

#### 4.4.3 Performance of Reticulation

Over the last number of years Council has reduced its leakage through improved maintenance procedures and repairs resulting in a decrease for Waimate Urban water scheme in minimum night flows from 15 L/s to about 9 L/s. Targeted renewals have continued to reduce leakage and consequently the Minimum Night Flows.

#### 4.5 Water Service Lines and Water Points

Water service lines (Waimate Urban water scheme only) are the pipe connection from the main to the property boundary. This includes the toby/manifold and any meter for monitoring or billing purposes.

Water ‘points’ are made up of valves, hydrants, manifolds, backflow prevention devices, water meters, sample points, tanks, tobies, capped ends.

There are 3,253 physical connections in the district. Council is continually updating its systems and capturing data to ensure that all connected properties are rated/billed.



##### 4.5.1 Asset Description

Only the Waimate Urban water scheme has service lines. The rural schemes do not have service lines as the mains are usually small diameter pipes over long distances and as such are not counted as service lines. In general service lines in the Waimate Urban water scheme are 15mm or 20mm diameter.

**Table 4-4: Length of Service Line by Pipe Material**

Scheme	CI		Galv		PE		PVC		Unknown		Steel		AC	
	No.	m	No.	m	No.	m	No.	m	No.	m	No.	m	No.	m
Waimate Urban	2	119	366	4,117	1042	9,832	27	136	668	6,131	1	11	2	20
Total number of service lines					2108									
Total length of service lines					20,367m									



Table 4-5: Point Water Assets

Community	Hydrant	Valves	Restrictor	Meters		Replacement Value (\$)
				Retic	Service & Manifold	
Waimate Urban	367	402	-	3	2021	\$4,249,133
Cannington Motukaika	-	37	49	1	-	\$79,810
Hook Waituna	-	128	534	8	4	\$586,137
Lower Waihao	-	73	231	4	4	\$298,579
Otaio Makikihi	-	84	230	5	3	\$300,049
Waihaorunga	-	19	42	-	1	\$55,581
Waikakahi	-	66	172	1	-	\$251,934
<b>Total</b>	<b>367</b>	<b>809</b>	<b>1258</b>	<b>22</b>	<b>2033</b>	<b>\$5,821,224</b>

#### 4.5.2 Condition

The general condition of the point assets is considered by Council's engineers as good to excellent. The condition assessments were extracted from the asset valuation data with its base data the Univerus Assets Asset Register. It is likely that these are default values and may not always reflect the true condition of a single asset. However, the total replacement value is small and does not represent a large financial risk to justify individual condition assessments.

Over the next three years additional condition assessment will be instigated to provide greater confidence in the condition.

#### 4.5.3 Performance and Capacity

Residential connections within the town boundaries are unrestricted 15mm and 20mm diameter connections providing adequate supply for household use. Those consumers with higher demand such as businesses, industry and schools have larger metered connections by arrangement.

Consumers outside the Waimate Urban water scheme supply boundary generally have metered or restricted connections.

On average 30 urban water scheme service lines are replaced per year and Council strategy on service line replacement is to replace the service line and toby with a new service line, manifold (dual check), meter and manifold box. This adds improved backflow prevention to service connections and the ability in the future to record consumption for monitoring purposes, or to detect leakage on private properties.

#### 4.5.4 Data Reliability

The reliability of 3 Waters data held by Council has not, to date, been systematically assessed and remains ungraded as per the IIMM manual. However, the data is based on good records and procedures and is subject to ongoing quality assurance as a result of maintenance works and has

been informally assessed as B/C (see 2020 Valuation Report). In order to address this short-fall we would propose to add an improvement item to the Improvement Plan (IP 34).

Condition assessments have been completed for a number of the 3 Waters assets and include, but are not limited to:

- i. NDT of AC Water Mains
- ii. CCTV of Sewer Mains (Inc. those programmed for renewal)
- iii. Visual inspections during maintenance activities

The results of these condition assessments have been applied to similar, uninspected assets to provide more reliable condition assessment of the whole asset base. For example, smaller diameter Asbestos Cement water mains are known to be in poorer condition than their larger counterparts, and smaller diameter AC mains in the northern extents of the urban area are failing due to ground conditions and pipe material combination.

Condition ratings do exist within the AMIS on an equivalent scale of 1 to 5.

Renewal works are prioritised based on criticality (assessed), empirical knowledge of failure rates/historic maintenance activity, other unrelated (and concurrently programmed) capital works. It should be noted that predictive models being used are age based in the first instance.

An improvement item (IP 34) will be noted in the improvement plans to produce a second predictive model which includes weighting on Condition and Performance gradings held within Univerus Assets.

## **4.6 Water Facilities**

Water facilities are made up of water treatment plants, pumping stations and reservoirs.

### **4.6.1 Asset Description**

The largest issue facing levels of service is with the quality of water supplied to the consumers and usually this also has the highest dissatisfaction level with customers. Council has started upgrading the treatment plants to improve water quality and comply with the Water Services (Drinking Water Standards for New Zealand) Regulations 2022 and the Drinking Water Quality Assurance Rules 2022.

Council water treatment plants range from basic chlorination sites to the Waimate Urban scheme water treatment plant featuring filtration. A list of the treatment plants and their respective water sources is presented in the table below:

Table 4-6: Waimate District Council Water Treatment Plants

Component	Unit	Waimate Urban	Cannington Motukaika	Hook Waituna	Lower Waihao	Otaio Makikihi	Waihaorunga	Waikakahi
Source	No 1	Groundwater	Surface water	Surface water	Groundwater	Surface water	Surface water	Surface water
	No 2	Groundwater			Groundwater	Groundwater	Surface water	
Intake	No 1	Bore	Stream	River	Well	River	Stream	Stream
	No 2	Bore			Well	Bore	Stream	
	Filter	Yes at bore 1	Roughing filter	River gallery	n/a	River gallery	River gallery	Yes
	Bore Depth (m)	B1 -110m B2 -83m	n/a	n/a	Outside 6m Inside 3.5m	n/a	n/a	n/a
	Dia. (mm)	B1 - 250mm			150PVC	Outside 200mm		50PVC
B2 – 300mm					Inside 100mm		150AC	
Treatment Capacity	(m <sup>3</sup> /day)	B1 – 2,592m <sup>3</sup>	475m <sup>3</sup>	1,728m <sup>3</sup>	1,633m <sup>3</sup>	928m <sup>3</sup>	455m <sup>3</sup>	1,468m <sup>3</sup>
		B2 – 1,728m <sup>3</sup>				928m <sup>3</sup>		
Treatment Process	Coagulation	No	No	No	No	No	No	No
	Flocculation	No	No	No	No	No	No	No
	Filtration	Yes at B1	Screen	Screen	No	No	No	No
	UV	B2 Yes		Yes		No.2 Yes		
Disinfection	Chlorine	Chlorine	Chlorine	Chlorine	Chlorine	Chlorine	Chlorine	Chlorine
Treatment Location	Plant	B1 Timaru Rd B2 Manchesters Rd	Backline Rd	Upper Hook Rd	Ferry Rd	Colliers Rd	Main pump Hursts Rd Tavendale pump Tavendale Rd	Hakataramea Ikawai Highway
Constructed	Year	B1 – 2000, B2 – 1972 (Renew 2018/19)	1973	1973	1978 (Renew 2013)	1969	1977	1973
Storage								
- Raw Water	m <sup>3</sup>	None	None	None	None	None	None	None
- Treated Water	m <sup>3</sup>	2,700m <sup>3</sup>	25m <sup>3</sup>	25m <sup>3</sup>	350m <sup>3</sup>	360m <sup>3</sup>	150m <sup>3</sup>	450m <sup>3</sup>
Reticulation Length	km	66	56.7	252	125	155	67	176
Connections	No.	2007	48	532	225	227	42	172
Fire Hydrants	No.	359	n/a	n/a	n/a	n/a	n/a	n/a
Approximate population (WSP)		3,416	90	962	700	422	99	344

### 4.6.2 Condition of Treatment Plants

The Waimate Urban scheme water treatment plants were recently upgraded and the remainder of treatment plants in the District are soon to be upgraded to comply with the requirements of the Health Act. At this time the condition of the assets within these facilities were be recorded.

In general, the condition and performance of asset components at the treatment plants are all considered by Council's engineers as good to excellent.

### 4.6.3 Capacity/Performance of Treatment Plants

The capacity of the water treatment plants is not known, but this will be considered under the water treatment plant upgrades. The available information is captured in the table below:

**Table 4-7: Water Treatment Plant Capacity and Production**

	Waimate Urban	Cannington Motukaika	Hook Waituna	Lower Waihao	Otaio Makikihi	Waihaorunga	Waikakahi
Average Demand (m <sup>3</sup> /day)	1900	251	745	1353	759	237	744
Peak Demand (m <sup>3</sup> /day)	3598	417	911	1739	1009	438	1080
Treated Water Storage (m <sup>3</sup> )	2600	30	nil	330	nil	405	876
Storage as a % of Peak Demand	72%	7%	-	19%	-	92%	81%
Treatment Capacity (m <sup>3</sup> /day)	4,882	475	1728	1771	1296	455	1054
Resource Consent Allow. (m <sup>3</sup> /day)	5,616	475	1,728	1,633	929	576	1,469
Design Population	6,300						
Maximum No of Possible Residential Connections	1,750						
Based on household occupancy	3.6						
Based on peak flow rate	45						
Average demand as % treatment capacity	39%	53%	43%	76%	59%	52%	71%
Peak demand as % treatment capacity	74%	88%	53%	98%	78%	96%	102%
Peak demand as % resource consent	64%	88%	53%	106%	109%	76%	74%
Total length of reticulation (km)	88.6	52.8	252.3	130.9	158.4	65.4	174.7
Length of undersized reticulation (km)							
Undersized as % total							
No. of Existing Connections	2,007	48	532	225	227	42	172
% Residential use	94.5	14.2 <sup>1</sup> .				18.2 <sup>1</sup> .	19 <sup>1</sup> .
% Commercial use	5.5						
% Agricultural use		85.8 <sup>2</sup> .				81 <sup>2</sup> .	81.8 <sup>2</sup> .

<sup>1</sup> Based on number of rural dwellings at 1500L/day

<sup>2</sup> Based on total volume sold, minus total rural dwellings at 1500L/day.

New Capital Expenditure planned to achieve compliance with the Water Services Act, the Drinking Water Quality Assurance Rules, and the Drinking Water Standards incorporate any planned renewals.

## 4.7 Water Pumping Stations

### 4.7.1 Asset Description

The general details of the pump stations are presented below:

**Table 4-8: Description of Pump Stations**

Scheme	Pumping Station	Number of Pumps
Waimate Urban	Timaru Rd Bore	4
	Manchester Rd Bore	3
Cannington Motukaika	Booster	2
Hook Waituna	Hook Waituna Intake	4
	O'Donnells	2
	Simmons	2
	Tekit	2
	Brownleas	1
Lower Waihao	Lower Waihao Intake	2
	Lower Waihao Booster	3
Otaio Makikihi	Intake Otaio Gorge	2
	Campbell Forrests	4
	Tavistock Source	2
	Tavistock Booster	4
Waihaorunga	Main Intake	2
	Tavendale Plant	1
	Melford Booster	4
	Takitu Booster	2
Waikakahi	Stonewall Intake	2
	Lower Waihao Booster	1
	Dog Kennel	1
	Claytons Booster	2

### 4.7.2 Condition of Pump Stations

In general, the condition and performance of asset components at the pump stations are all considered by Council's engineers as good to excellent.

### 4.7.3 Performance/Capacity of Pump Stations

The current performance of pump stations is adequate to achieve the desired Level of Service. However, electrical equipment within the pump stations is generally non-compliant with Electrical Regulations for wet areas. This increases the risk of failure of electrical equipment and loss of Level of Service. Council is undertaking steps to upgrade electrical equipment at pump stations.



The Council’s engineers consider that there are no current issues with pump station capacity.

## 4.8 Reservoirs

### 4.8.1 Asset Description

Reservoirs provide multiple purposes; at treatment plants they normally allow the plant to even out the flows without the loss of water to the consumer in the event that problems occur at the treatment plant. When demand requires an increase in flow, reservoirs can buffer the additional requirements for water allowing the plant to increase production without compromising quality.

Treated water reservoirs are used to balance demand from the consumer and in the Waimate Urban scheme on demand supply to provide sufficient storage to meet NZ Fire Service requirements for fighting fires. Water is either pumped from the reservoir or water flows from the reservoir under gravity and depends on the available elevation around the network to ensure adequate pressure and flow.

### 4.8.2 Condition of Reservoirs

In general, the condition and performance of asset components at the reservoirs are all considered by Council engineers as good to excellent.

### 4.8.3 Reservoirs Capacity / Performance

The current performance of the reservoirs is adequate to achieve the desired Level of Service.

**Table 4-9: Reservoir Storage Capacity**

	Waimate Urban	Cannington Motukaika	Hook Waituna	Lower Waihao	Otaio Makikihi	Waihaorunga	Waikakahi
Average Demand (m <sup>3</sup> /day)	1800	292	850	955	660	244	740
Peak Demand (m <sup>3</sup> /day)	3600	389	1010	1360	790	374	979
Treated Water Storage (m <sup>3</sup> )	2,600m <sup>3</sup>	30m <sup>3</sup>	nil	330m <sup>3</sup>	nil	405m <sup>3</sup>	876m <sup>3</sup>
Storage as a % of Peak Demand	75%	5.8%	-	36%	-	48%	46%
Storage as a % of Average Demand	150%	7.7%	-	51%	-	74%	61%

- \* Otaio reservoir not in use due to bore position

## 4.9 Asset Data Confidence and Integrity

A data confidence and integrity review was undertaken as part of the 2024 Valuation. The report extract on data confidence and integrity follows:

*The assets recorded in Univerus are based on hierarchical assets with reliable attribute information. Data accuracy is rated using a five-grade excellent to very poor matrix.*

*In terms of general context, nearly 100% of the data was rated as average and above.*

For valuation data confidence, the five-grade rating principle is applied across condition, quantity, unit cost, and base life attributes that are essential for a valuation. These attributes are rated as below:

**Table 4-10: Data Confidence**

Level	Description	Accuracy	Condition	Quantity	Unit Cost	Base Life
A	Highly Reliable and Accurate	100%				
B	Reliable with Minor Inaccuracies	± 5%		B	B+	B+
C	50% estimated	± 20%	C			
D	Significant data estimated	± 30%				
E	All data estimated	± 40%				

Condition was rated C as most condition data is anecdotal. However, this rating has not been taken into the overall data confidence grade as condition was not used to adjust remaining lives.

Quantities across the assets are reliable as they have been captured using GIS with linear measurements for lines and nodes for points. This may be lifted to a level B+ when all manholes have highly reliable depths.

Unit cost have been assessed from both observed contract (purchase costs) and 2022-unit cost escalations. As it is not possible to observe contract unit costs for all assets, escalations make up a large proportion of the unit costs. Unit costs can be made even more reliable if backed up by using bottom-up engineering costing techniques.

Base lives mostly conformed with the guidelines apart from stormwater culverts, manholes and pipes where base lives up to 150 years were observed. This extension was justified however as inspections have confirmed that these assets with installation dated prior to 1920 were in good condition.

A minor Asset ID duplication issue for 1,047 assets was noted in the renaming (numbering) of the Univerus generated Asset IDs cross the *ws\_line* and *ws\_point* asset classes, whereas the (text) renaming of *ws\_plant* and *ww\_plant* assets did not result in any duplicate IDs for the 51 applicable assets. However, unique Asset IDs for analysis are achievable by concatenating the Asset Class and Asset ID, although this is best avoided.

#### 4.9.1 Asset Condition Assessments

Condition assessments have been completed for a number of the 3 Waters assets and include, but are not limited to:

- iv. NDT of AC Water Mains
- v. CCTV of Sewer Mains (Inc. those programmed for renewal)
- vi. Visual inspections during maintenance activities

The results of these condition assessments have been applied to similar, uninspected assets to provide more reliable condition assessment of the whole asset base. For example, smaller diameter Asbestos Cement water mains are known to be in poorer condition than their larger counterparts, and smaller diameter AC mains in the northern extents of the urban area are failing due to ground conditions and pipe material combination.

Condition ratings do exist within the AMIS on an equivalent scale of 1 to 5.

Renewal works are prioritised based on criticality (assessed), empirical knowledge of failure rates/historic maintenance activity, other unrelated (and concurrently programmed) capital works. It should be noted that predictive models being used are age based in the first instance.

An improvement item (IP 34) will be noted in the improvement plans to produce a second predictive model which includes weighting on Condition and Performance gradings held within Univerus Assets.

## 4.10 Environmental Effects

### 4.10.1 Resource Consents

There are a number of resource consents held for the Water Services activity. These range from permission to install a bore, to divert flow, to dam water and ultimately take water. There are no resource consents for “taking water” which are up for renewal within the timeframe of this AMP.

A number of resource consents expire within the latter part of the 10 year timeframe of this AMP. These are summarised in the chart and table below:

Figure 4-6: Water Resource Consent Expiry Summary Chart




Table 4-11: Water Resource Consent Expiry Dates

Consent Number	Scheme	Expiry date
CRC940846	Lower Waihao	23/02/2029
CRC962154.1	Waikakahi	29/05/2031
CRC970320	Waikakahi	29/05/2031
CRC970321	Waikakahi	29/05/2031



Consent Number	Scheme	Expiry date
CRC980385	Hook Waituna	21/05/2034
CRC980386	Hook Waituna	21/05/2034
CRC981066	Otaio-Makikihi	28/01/2033
CRC981876.1	Otaio-Makikihi	22/04/2034
CRC992050	Otaio-Makikihi	21/05/2034
CRC202845	Waimate Urban	14/06/2034

Consent CRC981066 is no longer required as it is the consent for the old intake for the Otaio Makikihi water scheme.

Two of the consents held by the Waimate District Council to take water are now for private water supplies. They are CRC940845 for Cattle Creek rural water supply intake and CRC981015 for Hakataramea rural water supply intake. The smaller Cattle Creek supply is not a registered drinking water supply and is privately managed. The Hakataramea rural water supply is managed by the Hakataramea Water Scheme Committee Incorporated and is a registered drinking water supply.

Consents are relatively simple to update and most updates are expected to be managed inhouse by Council staff with very little external support required.

Section 4: Description of the Water Service

**Table 4-12: Water Resource Consents**

Consent Number	Status	Scheme	Activity	Issue date	Expiry date	Comment	Volume
CRC020225	Current	Waimate Urban	To discharge contaminants to land	14/09/2001	11/09/2036	To discharge contaminants into land (from filter backwash - Timaru Rd, Waimate Water TP)	
CRC084606	Current	Waihaorunga	Take surface water	17/12/2008	16/12/2043	To take and use water from an unnamed tributary of the Waihaorunga Stream	not exceeding 1.4l/s or 847m <sup>3</sup> /7 days
CRC084608	Current	Waihaorunga	Take surface water	17/12/2008	17/12/2043	To take and use water from the Waihaorunga Creek	not exceeding 5.3l/s or 3,185m <sup>3</sup> /7 days
CRC092155	Current	Cannington-Motukaika	Take surface water	2/10/2009	1/10/2044	To take and use water (from Nimrod Stream - White Rock River, Cannington)	not exceeding 5.5l/s or 3,325m <sup>3</sup> /7 days
CRC110693	Current	Cannington-Motukaika	Construct remove structure			To construct a Pipe bridge - 41 Mt Nimrod Road (Opus). No conditions.	
CRC940845	Current	Cattle Creek (Private Scheme)	Take surface water	25/02/1994	23/02/2029	To take water from a tributary of the North branch of the Waihao River for the Cattle Creek Rural Water Supply	not exceeding 1.6l/s or 138m <sup>3</sup> /day
CRC940846	Current	Lower Waihao	Take groundwater	23/02/1994	23/02/2029	To take groundwater from bore for the Lower Waihao Rural Water Supply Scheme	not exceeding 18.9l/s or 1,633m <sup>3</sup> /day
CRC962154.1	Current	Waikakahi	Take surface water	23/03/1998	29/05/2031	To take water from a tributary of the Waitaki River for domestic use and stock water (SH82, Ikawai)	not exceeding 17l/s
CRC970320	Current	Waikakahi	Construct/remove a structure, works to divert water	27/03/1998	29/05/2031	To reconstruct and maintain a weir, and to disturb the bed of an unnamed tributary of te Waitaki River for a rural water supply (SH82, Ikawai)	not exceeding 1.5m high and 30 m wide
CRC970321	Current	Waikakahi	Dam surface water	27/03/1998	29/05/2031	To dam water for a rural water supply (SH82, Ikawai)	not exceeding 3,000m <sup>3</sup>
CRC980385	Current	Hook Waituna	Construct/remove a structure, works to divert water	27/05/1999	21/05/2034	To disturb the bed of, maintain and reconstruct a rock weir, in the Hook River (Upper Hook Road, Hook Bush)	not exceeding 1.6m high

Consent Number	Status	Scheme	Activity	Issue date	Expiry date	Comment	Volume
CRC980386	Current	Hook Waituna	Take surface water	27/05/1999	21/05/2034	To dam, divert, take and use surface water from the Hook River for domestic & stock water purposes and trickle irrigation of up to 25.2ha (Upper Hook Road, Hook Bush)	not exceeding 20l/s or 1,728m <sup>3</sup> /day
CRC981015	Current	Hakataramea (Private Scheme)	Divert surface water	23/1/1998	21/01/2033	To divert water in the Hakataramea River for erosion and flood control purposes (Wrights Crossing, Hakataramea River)	
CRC981066	Current	Otaio-Makikihi	Works for maintenance/protection	30/01/1998	28/01/2033	To disturb the bed of the Otaio River for the improvement of water flow to a pump chamber (Otaio River, Blue Cliffs Rd)	Surrendered
CRC981876.1	Current	Otaio-Makikihi	Take surface water	12/05/2004	22/04/2034	To take surface water for the Otaio-Makikihi RWS (Backline Rd, St Andrews)	not exceeding 15l/s or 6,500m <sup>3</sup> /7 days
CRC992050	Current	Otaio-Makikihi	Construct/remove structure	<del>25/05/1999</del>	21/05/2034	To disturb the bed of the Otaio River by installing and maintaining an intake structure (Backline Rd, St Andrews)	
CRC202845	Current	Waimate Urban	Take groundwater	25/08/2020	14/06/2034	To take and use water (Timaru Rd & Railway Reserve)	not exceeding 65l/s or 4,320m <sup>3</sup> /day
CRC122551	Current	Otaio-Makikihi (Otaio Gorge intake & Tavistock Road bore combined)	Take Groundwater	06/07/2012	06/07/2047	to take groundwater for domestic and stock water purposes	not exceeding 15l/s or 6,500m <sup>3</sup> /7 days and no more than 351,500 m <sup>3</sup> / year

The resource consents for the Hakataramea Rural Water Supply are held in the name of the Hakataramea Water Scheme Society.

## Section 4: Description of the Water Service

Consent Number	Status	Scheme	Activity	Issue date	Expiry date	Comment	Volume
CRC030733	Current	Hakataramea	To divert, take and use surface water	26/08/2003	25/08/2038	.	Not exceed 12.6 litres per second
CRC030734	Current	Hakataramea	Discharge to land	17/09/2003	25/08/2038		Not exceed 12.6 litres per second

### 4.10.2 Environmental Monitoring and Reporting

Consent reporting within Council for Water and Wastewater is the responsibility of the Water and Waste Engineer. Information for consent compliance is provided by the Council's Water and Waste Group and forwarded to Environment Canterbury.

### 4.11 Assessment of Water Services

Central Government is continuing water services delivery reform. The current 'Local Water Done Well' legislation places the responsibility for Water and Sanitary Services assessments back with Councils.

**Table 4-13: Public and Private Water Supplies**

Public Water Supplies Managed by Council	
Waimate Urban	Cannington Motukaika
Hook Waituna	Lower Waihao
Otaio Makikihi	Waihaorunga
Waikakahi	
Public Water Supplies Managed by other Councils	
Downlands Rural Water Supply (Timaru District Council)	
Camping Grounds: now owned by Waimate District Council and administered and maintained by Council Parks and Reserves Group	
Briar's Gully Camp Site	Fisherman's Bend Camp Ste
Te Akatarawa Camping Ground	Waitangi Reserve Camp Ground
Private Water Supplies	
Hakataramea Valley Rural Water Supply	Cattle Creek (Upper Waihao) Rural Water Supply

The table below addresses specific risks and issues identified for the water schemes managed by Council.

**Table 4-14: Quality and Adequacy**

Scheme	Quality
Waimate Urban	Complies fully with DWSNZ and partially with the Drinking Water Quality Assurance Rules.. Is serviced by two sources. The majority of the year the Timaru bore is on standby. During hot dry months the Timaru bore assists in supply. Water supply conservation measures have been put in place at times during recent years. Demand is increasing and it is envisaged that in terms of volume the Waimate Urban water scheme will require increased volume in the medium term (20-30 years).
Rural Schemes	Recent enhancements have increased delivery volumes. Changes in farming practices, i.e. changing from sheep to dairy farming may drive further demand. Single point failures remain a concern. Not all are compliant with the DWQAR and isolated exceedances of MAV's have occurred in the Lower Waihao RWS.

#### **4.11.1 Update of the Water & Sanitary Assessment (2005)**

The update of the Water & Sanitary Assessment in 2011 noted the following:

- i. There are many properties within the district which are not connected to a Council managed water supply scheme or to a private scheme. Many of these are isolated dwellings within more remote areas and are served by private sources.
- ii. Other properties reliant on private sources are located within townships such as Willowbridge. In these areas a connection to a public water supply is available, but this option is not always taken up due to the inability of individuals to afford the connection costs or a personal preference not to do so. These areas are not served by sewerage reticulation, and this enhances the likelihood of the contamination of the water supplies to these communities. Bores have been known to run dry in such areas.

#### **4.12 Criticality**

During 2017 Council performed a criticality assessment on 3 Waters assets by using the New Zealand Asset Metadata Standards methodology and criticality ranking. This included consideration of GIS, population, key facilities and hydraulic model data. The NZAMS defines criticality as “the significance of any individual component or asset to the ability of any part of a network or portfolio to deliver the service it was designed to perform”. The methodology considered:

- residential population rating – the number of people affected by the removal of the asset
- facility importance rating – the importance of the facility based on the role the facility plays in enabling the community to function


The global criticality ratings are:

1. very low
2. low
3. medium
4. high
5. very high

An additional diameter based component was included for water supply assets. The criticality assessment provided the following results.


The figure below shows the pipe length distribution across the different criticality categories for the Waimate Urban Water Supply. Graphs are also available for the rural water supplies.

**Figure 4-7: Waimate Urban Water Supply Criticality and Lengths Distribution**



The figure below shows an overview plan of the criticality rating for the Waimate Urban Water Supply. Maps are also available for the rural water supplies.

**Figure 4-8: Waimate Urban Water Supply Criticality Map**



The criticality assessment provides Council engineers the ability to clearly identify the assets of highest importance and the greatest value. This ensures the asset can be managed more proactively in order to mitigate the risk associated with their failure. This proactive management includes:

- Prioritising condition assessments
- Adjusting economic lives with respect to renewal profiles

## Section 4: Description of the Water Service

- Prioritising/deferring renewals
- Prioritising expenditure operation and maintenance planning
- Priorities for collecting asset information to the required level of confidence

It is important to align the asset data in Univerus Assets with the criticality assessment ratings (**IP 31**).

The criticality assessment report made the following recommendations (**IP 32**):

- Plan a renewals program supported by a condition management program for critical infrastructure
- Plan around supplying critical customers and key facilities following a critical asset failure
- Identify sensitive customers (for example: dialysis patients) for a more detailed criticality assessment
- Update and maintain the water supply models, especially where new assets have been added (new bore and pump station in the Otaio rural water supply). The Water hydraulic models were updated during 2022.
- Expand the stormwater model for a better understanding of stormwater flows and populations served by WDC's assets. The Stormwater hydraulic model was updated during 2022.
- Maintain the GIS data, especially for the stormwater assets

In view of the ongoing Government 3 Waters reform programme Council may reconsider the Criticality assessment as appropriate to ensure the four wellbeing's (social, economic, environmental and cultural) are adequately captured within the assessment (**IP 33**).

At the time of updating this AMP, it's likely that the four wellbeings will be removed from consideration. Amendments to the LGA 2002 are yet to be implemented.





## 5.0 LEVELS OF SERVICE

*This section defines the Levels of Service and performance measures by which the service levels will be assessed for Water Services. The service levels are aimed at meeting the strategic goals of Council. This section also contains information on the customer research undertaken and the legislative requirements adhered to in arriving at the service levels.*

Levels of service define the type and extent of services delivered to the customer. They are written from a customer viewpoint such that Council can set targets against the levels of service to demonstrate outputs and performance against the community outcomes. Levels of service assist the Council in optimising all activities for each service, as well as providing a benchmark against which to meet customer expectations.

### 5.1 Community Outcomes

#### 5.1.1 Revision of Community Outcomes

##### 2009/19 Community Plan

During the development of 2009/19 Community Plan, Council resolved to update and revise the community outcomes. Council produced a survey document asking the District's residents to focus and comment on the existing 25 community outcome statements. As a result of this survey Waimate District's community outcomes statement were modified to retain the 25 outcomes from 2006 but group the existing 25 outcomes under five high-level wellbeing statements (Economic, Social, Environmental, Cultural and Social).

##### 2012/22 Long Term Plan

In 2011 the Council amended the community outcomes, and these were subsequently reassessed for the 2015-25 Long Term Plan. The Council has indicated that there will be no significant change to the community outcomes for the 2018/2028 LTP. Changes relate to alignment with the Council Vision. These outcomes and linkage of the Wastewater levels of service are provided in Table 4-1 below.

##### 2015/25 Long Term Plan

In 2017 the Council amended the community outcomes. These outcomes and linkage of the Water Services Levels of Service via the Rationale are shown in Table 4.1 below. There are no changes to the Community Outcomes for the 2025-34 LTP.

Table 5-1: Waimate District Council Community Outcomes 2024-34 and Water Services Rationale

COMMUNITY OUTCOMES				
	Thriving Community	Safe & Healthy People	Sustainable District and Environment	Active, Diverse and Supportive Community
	Economic Wellbeing	Social Wellbeing	Environmental Wellbeing	Social Wellbeing
	A District that encourages development	A place where people are safe in their homes, work and public spaces	The Waimate District is enhanced through sustainable and diverse development	All people are encouraged to participate in our democratic process
<b>Rationale</b>		<i>Water – Protecting the communities from drinking water related health issues and providing firefighting capability</i>		
	A District that provides infrastructure for economic activity	Our services, infrastructure and environment enhance quality of life	Our heritage is valued and protected	District assets that provide recreation and leisure choice
<b>Rationale</b>	<i>Water – The timely provision of utility services is essential to supporting growth</i>	<i>Water - We have reliable, efficient and well planned water, wastewater, stormwater and solid waste infrastructure that meet the needs of residents</i>		
	A District that actively promotes itself and its businesses	A resilient and adaptive community in a changing environment	We value the natural environment, biodiversity and landscapes	We celebrate and support the good things about our community
<b>Rationale</b>		<i>Water – Infrastructure is planned and installed taking into account climate change impacts over the life of the assets</i>	<i>Water – water is used efficiently and in a sustainable manner</i>	

## 5.2 Level of Service Consultation

### 5.2.1 Consultation Processes

#### Community Outcomes for the Long Term Plan

The Council has carried out significant consultation to establish the Community Outcomes for the LTP; these were reviewed in 2011 following the changes to the Local Government Act in 2010. For the 2025 LTP the Community Outcomes retain the essence of those included in previous Waimate Community and Long Term Plans and were tested against the Waimate District Council vision statement.

#### Community Consultation

The Council has undertaken a range of consultation processes over the past few years specifically targeted at gathering information on preferred Levels of Service or the extent of infrastructure that Council will be required to install, future vision or how we manage the service. The extent of the historical and proposed consultation is detailed in Table 5-2 below.

**Table 5-2: Waters Services Consultation Processes (Historical and Proposed)**

Consultation Processes	Key Stakeholders Involved	Date	Reasons for Consultation	Extent of Consultation
<b>Historical</b>				
2012-2022 LTCCP process	All	2012	Legislative requirement criteria of LGA 2002	In accordance with the LGA 2002 consultation requirements
2015-2025 LTP process	All	2015	Legislative requirement criteria of LGA 2002	In accordance with the LGA 2002 consultation requirements
2018-2028 LTP process	All	2015	Legislative requirement criteria of LGA 2002	In accordance with the LGA 2002 consultation requirements
Bylaws	All	2018	Review of Bylaws	Public and Industry submissions requested
2021-2031 LTP process	All	2021	Legislative requirement criteria of LGA 2002 and RMA	In accordance with the LGA 2002 consultation requirements
Water Safety Plan (Waimate Urban and Rural)	Urban and Rural customers	2013 & ongoing		
<b>Proposed</b>				
Enhanced 2024/25 AP and 2025-34 LTP	All	2025	Legislative requirement criteria of LGA 2002 and RMA	In accordance with the LGA 2002 consultation requirements
District Plan Review	All	2024 onwards		

## 5.3 Rules for Performance Measures

In 2010, the Local Government Act 2002 was amended to require the Secretary for Local Government to make rules specifying non-financial performance measures for local authorities to use when reporting to their communities. The aim was to help the public to contribute to

discussions on future levels of service for their communities and to participate more easily in their local authority's decision-making processes.

Performance measure rules come into force on 30 July 2014. Local authorities were required to incorporate the performance measures in the development of the 2015-2025 LTP. The performance measures were reported against for the first time in the 2015/2016 annual reports. The performance measures are:

- Performance measure 1 - Safety Of Drinking Water
- Performance measure 2 - Customer Satisfaction
- Performance measure 3 - Demand Management
- Performance measure 4 - Fault Response Times
- Performance measure 5 - Maintenance of the Reticulation Network

Subsequently the Department of Internal Affairs has modified Performance measure 1 to align with the new regulatory framework.

#### **5.4 Water Levels of Service**

In 2023 the 2018 Customer Levels of Service were reviewed. The table below details the results of this review.

Council reviewed the customer service requests system to ensure they align with the Mandatory Performance Measures and ensured the internal and Contractor reporting aligns with the Mandatory Performance Measures 'tasks'. Council's AMIS (Univerus Assets) and associated Service Request module have been programmed to allow reporting aligned with the NFPM and to ensure consistency and accuracy of reporting.

Section 5: Levels of Service

**Table 5-3: Water Services Levels of Service**

<b>What we do it</b>	<b>Council provides a regular supply of water to the designated Waimate urban area and the six rural areas of Waimate to serve drinking, commercial and fire protection uses.</b>			
<b>1. Provide safe drinking water</b>				
<b>How we do it</b>	<ul style="list-style-type: none"> <li>• Manage and monitor all water supplies under requirement of Drinking Water Standards</li> <li>• Monitor ongoing regulatory change for water supply activities</li> <li>• Implement Water Safety Plans for drinking water schemes</li> </ul>			
<b>How we measure performance</b>		<b>Actual</b>	<b>Years 1 – 3 Target</b>	<b>Years 4 - 10 Target</b>
	Extent of compliance with Drinking Quality Assurance Rules. (M)  4.4 T1 Treatment Rules; 4.5 D1.1 Distribution System Rule; 4.7.1 T2 Treatment Monitoring Rules; 4.7.2 T2 Filtration Rules; 4.7.3 T2 UV Rules; 4.7.4 T2 Chlorine Rules; 4.8 D2.1 Distribution System Rule; 4.10.1 T3 Bacterial Rules; 4.10.2 T3 Protozoal Rules; and 4.11.5 D3.29 Microbiological Monitoring Rule.	Not achieved (2022/23)	Full compliance – All schemes	Full compliance – All schemes

**2. Provide a continuous, appropriate and safe water system throughout the District with excellent customer service**

<p><b>How we do it</b></p>	<ul style="list-style-type: none"> <li>• Manage, monitor and test all water supplies</li> <li>• Respond to service failures and faults</li> <li>• Provide a customer service request system 24 hours a day 7 days a week</li> </ul>			
<p><b>How we measure performance</b></p>		<p><b>Actual</b></p>	<p><b>Years 1 – 3 Target</b></p>	<p><b>Years 4 - 10 Target</b></p>
	<p>Median attendance and resolution times for urgent and on-urgent callouts for water supply faults or unplanned interruptions to the urban network* (M)</p>	<p>Achieved (2022/23)</p>	<p>Attendance to urgent callout - ≤ 1 hour</p>	<p>Attendance to urgent callout - ≤ 1 hour</p>
		<p>Achieved (2022/23)</p>	<p>Resolution for urgent callout - ≤ 24 hours</p>	<p>Resolution for urgent callout - ≤ 24 hours</p>
		<p>Achieved (2022/23)</p>	<p>Attendance to non-urgent callout - ≤24 hours</p>	<p>Attendance to non-urgent callout - ≤24 hours</p>
		<p>Achieved (2022/23)</p>	<p>Resolution for non-urgent callout - 72 hours</p>	<p>Resolution for non-urgent callout - 72 hours</p>
	<p>Total number of complaints received about:</p> <ol style="list-style-type: none"> <li>1. drinking water clarity</li> <li>2. drinking water taste</li> <li>3. drinking water odour</li> <li>4. drinking water pressure or flow</li> <li>5. continuity of supply</li> <li>6. Council’s response to these issues (M)</li> </ol>	<p>Urban aachieved (2022/23) Rural Not achieved (2022/23)</p>	<p>Urban water supply: &lt;10 complaints per 1,000 connections</p> <p>Rural water supply: ≤ 40 complaints per 1,000 connections</p>	<p>Urban water supply: &lt;10 complaints per 1,000 connections</p> <p>Rural water supply: ≤ 40 complaints per 1,000 connections</p>
<p>Percentage of residents receiving the service satisfied with water supply services</p>	<p>Urban and Rural water Not achieved (2022/23)</p>	<p>≥ 70%</p>	<p>≥ 75%</p>	



### 3. Provide reliable, efficient and well-planned water infrastructure and services that meets the needs of the community

<b>How we do it</b>	<ul style="list-style-type: none"> <li>• Monitor demand on all water supplies</li> <li>• Manage growth of network</li> <li>• Monitor condition and performance of water supply reticulation and assets and analyse data to predict asset failure/identify priority improvements required</li> <li>• Complete capital expenditure programme associated with developing the network</li> <li>• Minimise the disruptions to water supplies</li> <li>• Provide a restricted supply of water to customers on rural water schemes</li> <li>• Implement leak detection and reduction programme</li> </ul>
---------------------	--

		<b>Actual</b>	<b>Years 1 – 3 Target</b>	<b>Years 4 - 10 Target</b>
<b>How we measure performance</b>	The average consumption of drinking water per day per resident within the Waimate district (M)	Achieved (2022/23)	Average consumption ≤ 300 litres per person per day	Average consumption ≤ 300 litres per person per day
<b>How we measure performance</b>	Percentage of real water loss from Council's network reticulation systems (M)	Achieved (2022/23)	Real water loss - ≤ 25%	Real water loss - ≤ 20%
<b>How we measure performance</b>	<b>Estimated assumed water loss per connection per day</b>	New Measure	Estimated assumed water loss <150L per connection per day	<b>Estimated assumed water loss &lt;100L per connection per day</b>
<b>How we measure performance</b>	Reactive maintenance (system failure) or programed work in the Waimate urban area that exceed 8 hours of not supplying drinking water to the community or a consumer.	Achieved (2022/23)	< 1 per year	< 1 per year

## Section 5: Levels of Service

	Reactive maintenance (system failure) or programmed work in the Rural Water Supplies that exceed 3 days of not supplying drinking water to the community or a consumer.	Achieved (2022/23)	< 1 per year	< 1 per year
--	---	--------------------	--------------	--------------

*The interpretation of the Non-Financial Performance Measures Rules is shown in [http://www.dia.govt.nz/diawebsite.nsf/wpg\\_URL/Resource-material-Our-Policy-Advice-Areas-Local-Government-Policy?OpenDocument#ElectoralAct](http://www.dia.govt.nz/diawebsite.nsf/wpg_URL/Resource-material-Our-Policy-Advice-Areas-Local-Government-Policy?OpenDocument#ElectoralAct)*

Compliance (bacterial and protozoal) with drinking-water standards: This measure is only partially achieved as a number of the plants are yet to be upgraded to meet the bacteria and protozoal compliance criteria required by the Water Services Act and supporting rules.

Several Water Treatment Plant Upgrades are programmed for completion within the first two years of this AMP. These include Waihaorunga, Hook-Waituna, Cannington-Motukaika and Waikakahi Rural Water Supplies. These upgrades are subject to changing legislation in late 2024 and early 2025.


Complaints about rural water supply: Due to the nature and mechanics of a rural water scheme, and a number of factors beyond Council's control (i.e. members of public damaging pipe network) there is a greater potential for a loss of water pressure and continuity of supply. Council does have a renewals programme for pipe and points of supply (i.e. restrictor), a policy of 4 days point of supply storage, and public access to GIS maps of the water supplies on its website.

Real Water Loss: At present Council only has meters at the Timaru Road and Manchesters Road plants and no zone or points of supply meters. Therefore, we are unable to measure true water usage in Waimate and have to rely on an assumed water loss calculation for this reporting.

### 5.4.1 Customer and Technical Levels of Service

The Technical Service Standards for each Customer Levels of Service, along with linkages to the monitoring and Performance Measurements is described below.

Figure 5-1: Customer and Technical Levels of Service




### 5.4.2 Activity contribution to the Four well-beings

Section 10 of the Local Government Act restores the four aspects of community well-being by requiring local authorities to promote the social, economic, environmental, and cultural well-being of communities in the present and for the future. The reinstatement of the four well-beings acknowledges that the Council has a broader role in looking after our communities, than simply providing core services. The water activity levels of service contribution to the four wellbeings are shown below.

At the time of writing this AMP, legislative changes to remove reference to the four wellbeing’s are yet to be incorporated into the LGA 2002.

**Figure 5-2: Levels of Service Contribution to Four Wellbeings**



### 5.5 Performance Gaps

The results for the April 2023 Key Research customer satisfaction survey as shown below. The results from the survey report that:

- 66% of residents are satisfied with the water supply and service (77% in 2021), with 37% being very satisfied (43% in 2017). 13% are not very satisfied and 13% are unable to comment.
- The percentage not very satisfied (13%) is similar to the Peer Group and National Average readings for water supply and 5% above the 2017 reading.
- Based on the scores across different age groups and wards, the decrease in satisfaction overall is most likely due to the worsening perceptions among residents from Lower Waihao and those aged over 65 years
- The main reasons residents are not very satisfied with the water supply and service are:

- Water quality is bad/boil water notices 65%
- Too many chemicals in the water/strong smell of chlorine/nitrate levels, 25%,
- Water tastes bad, 6%
- The cost of water is too high, 5%
- Poor pressure/flow rate, 2%.

Figure 5-3: Key Research Survey Trends



Figure 5-3 shows the satisfaction levels have decreased considerably over the last two years. These are likely due to worsening perceptions among residents from the Lower Waihao.

A summary of the performance gaps is shown below along with a summary of how the gap(s) will be closed. These are further discussed in the Sections 5 to 10.

Table 5-4: Level of Service Performance Gaps

Level of Service	Ten Year Performance Measure	Performance Gap	Summary of How the Gap will be Closed
Council will provide potable water	Council provides water that complies with DWQAR and DWSNZ	Yes	Increased water treatment and monitoring
Council manages the water schemes wisely	85% of satisfied or very satisfied residents with the overall performance of the Water service	Yes	Increased water treatment and monitoring

## 6.0 GROWTH AND DEMAND MANAGEMENT

*The Growth and Demand Section provides details of growth forecasts, which affect the management, and utilisation of all Waters assets and details demand management strategies.*

### 6.1 Waimate District Growth

Population growth (or decline), age structure and distribution (spread), and the number and type of households and families in our district affects:

- Demand for local services
- The willingness and ability of ratepayers to pay for them
- Representation and participation in local democracy
- Interactions between human activity and the environment.

It is therefore an essential for asset management planning that sound information is used regarding population, demographic and geographic change.

Council continues to model and track changes in district growth to ensure infrastructure planning remains well informed about growth impacts.

Expected growth impacts are beyond the 10-year LTP planning period.

Capital programme network extensions included in this Asset Management Plan allow for the currently modelled growth.

#### 6.1.1 Methodology

Rationale developed the previous set of growth projections for Waimate District Council (WDC) in 2020. These projections were developed using a using a bottom-up approach. Individual growth drivers for each Statistical Area 2 (SA2) were developed using migration for employment and lifestyle as the basis of the modelling. The modelling was based off 2019 data, which was the most up to date at the time.


WDC approached Rationale to update the projections to ensure their continued relevance, check for any significant changes including the actual impact of COVID-19, and to inform the 2025 to 2034 Long Term Plan. Rationale and WDC completed a review of the 2020 projections, comparing the forecast growth to 2022 with the actual growth that has occurred. The 2020 projections generally tracked the actual growth, and it was decided that a “light update” of the projections was appropriate.

For the light update, the following items were updated.

- Historical usually resident population estimates to 2022.
- Historical filled jobs to 2022.
- Current number of rating units.
- Removal of any assumptions relating to the Covid-19 pandemic.
- Migration and growth assumptions for the Morven-Glenavy-Ikawai SA2.

All other assumptions and inputs remain unchanged from the 2020 projections.

**Figure 6-1: Comparison between the 2020 projections and the 2023 predictions**



### 6.1.2 Growth Scenarios

Four growth scenarios have been modelled for each parameter representing different levels of ambition in terms of the district’s growth over the next thirty years.

**Table 6-1: Summary of the Four Growth Scenarios**

	Scenario	Description
Scenario 1	Baseline	Used as a baseline to build the other three scenarios. It is derived from historical migration and employment trends
Scenario 2	High	Migration drivers and assumptions are increased by 20% above the baseline which means more people will move to Waimate and less people will leave. Employment levels are increased by 10% above the baseline by 2053. Investment in the town centre of Waimate is expected to generate an additional 20 long term jobs per year, from 2023 to 2028 (120 total). The Oceania Dairy plant continues to employ people at a rate of 4% (twice the MBIE forecast for food productions) through to 2053.
Scenario 3	Medium	Migration drivers and assumptions are set to the baseline. Employment levels are set to the baseline, with the exception of Waimate Town Centre. Investment in the town centre of Waimate is expected to generate an additional 10 long term jobs per year, from 2023 to 2028 (60 total). The Oceania Dairy plant continues to employ people at a rate of 2% (matching the MBIE forecast for food productions) through to 2053
Scenario 4	Low	Migration drivers and assumptions are reduced by 20% which means less people will move to Waimate and more people will leave. Employment levels are decreased by 10% below the baseline by 2053. The Oceania Dairy plant stops expanding and ceases to employ people from now until 2053.

### 6.1.3 Recommendation – Growth Scenario 3


It is recommended that WDC adopt Scenario 3, medium growth. Unless otherwise stated, all charts and tables in this report refer to Scenario 3.

## 6.2 Population Demographic Changes

Over the next thirty years, the usually resident population of Waimate District is predicted to increase.

The average age of Waimate District’s population is 44.9 years, this is older than the national average of 39.4 years (Stats NZ). Looking across the district, Waimate township has a significantly older average age of 49.7 years in 2022 when compared to the outlying rural areas. This suggests that people are living and working on farms then moving into Waimate for retirement later in life.

**Figure 6-2: Population Projections (Usually Resident Population)**



The 2018 Census population of Waimate District was 7,815<sup>1</sup>. The recommended medium growth scenario projects the District’s population to increase to 9,500 by 2053.

Based on the medium projection, the population of the Waimate District is projected to grow by, on average, 0.4% a year between 2023 and 2053.

The high projection would see Waimate District population reach close to 11,000 by 2053. This is not the recommended growth scenario but does demonstrate the upper bound of modelled growth.

With a low base population, significant industrial projects are capable of having an impact of the District’s population. Expansions of both Oceania and Fonterra Dairy Factories in the next ten years could increase job opportunities in the District.<sup>2</sup> The potential future Hunter Downs Irrigation Scheme (currently suspended) could also see an increase in on-farm jobs in the District and the creation of secondary jobs as a result of increased agricultural production in wider South Canterbury.<sup>3</sup> Should all of these projects proceed the District may see population growth trending more towards the high projection. While this may appear conservative, it is important that Council does not overestimate population growth, and the associated infrastructure provision required. Also reflects that a considerable number of employees from both dairy factories live in either the Waitaki or Timaru Districts.<sup>4</sup> Given the close proximity of both Timaru and Oamaru to these sites, increased

<sup>1</sup> Statistics New Zealand, 2018 Population Usually resident population counts)

<sup>2</sup> Oceania anticipate an additional 67 jobs in the next twelve months though a number of expansion projects and a further 43 jobs in two or three years with the addition of another dryer. Fonterra estimates a sizeable expansion of its Studholme factory should plans proceed - 70-80 new jobs on site with potentially 500 persons involved in the construction.

<sup>3</sup> Original Hunter Downs predictions (published in 2011) detailed the creation of between 1400 and 1800 jobs in wider South Canterbury and approximately 450 on-farm jobs. The latest information provided by Hunter Downs Water was that construction of the scheme would start late 2017 and would take approximately 27 months.

<sup>4</sup> Employment data provided by Fonterra shows approximately a third of staff live in the Timaru District. Oceania Dairy report that 79% of their staff live outside of the Waimate District.



job opportunities may not necessarily equate to comparable population increase in the Waimate District. Growth over the next 30 years of between 1,000 and 2,000 people is likely.

### 6.2.1 Natural Decrease

As New Zealand’s population continues to age, more and more areas will consistently experience a natural decrease, i.e. more deaths than births (3 territorial authorities experienced this between 2010-2014). For areas that have traditionally relied on a natural increase for population growth (including Waimate), a natural decrease will mean a shrinking population unless offset by net migration gains. Within the Waimate District, natural decrease is projected to occur around 2040. Without net migration gains, the population proper will decrease.

**Table 6-2: Average age of District Population**

	2022	2023	2033	2043	2053
District wide	44.9	44.9	44.5	44.2	44.6
Hakataramea	41.9	41.9	41.8	40.8	40.6
Lyalldale	42.5	42.8	44.5	45.2	46.3
Makikihi Willowbridge	44.0	44.1	43.9	43.3	43.7
Maungati	39.0	39.2	40.3	40.5	41.8
Morven Glenavy Ikawai	38.6	39	42.2	44.1	45.1
Waimate	49.7	49.5	46.9	45.8	45.7

### 6.2.2 Higher Median Age


The median age for the Waimate District population is set to remain steady at about 45 years through to 2053.

### 6.2.3 Larger proportion of older people

Under all projection series (high, medium and low), all 67 territorial authorities in New Zealand are projected to have a higher proportion of older people (aged 65 and over) in 2053 compared with 2022.

In 2013 19.5% of the Waimate District population was aged 65 and older. Using the medium projection series, by 2043 29.6% of the Waimate District population will be aged 65 and over.

**Figure 6-3: Age distribution of Waimate District’s population in 2053**



### 6.2.4 Urban Rural Split

Projections also suggest a change in the age composition of the urban and rural populations. While the 0-14 years, 15-39 years’ age brackets remain relatively stable across the 25-year period in all areas, there is a considerable increase in the number of residents over the age of 65 living in the rural areas of the District and a decrease in the number of residents aged 40-64 years. The proportion of people aged over 65 living in the Waihao area unit is projected to nearly double, from 8.7% to 16.4% of the total district population. While the number of residents over the age of 65 living in urban Waimate is also projected to increase over the 25 years, by 2038 it is projected there will be more over 65s living rurally than in the urban centre of Waimate.

### 6.2.5 Key migration drivers


The key characteristics of Waimate District’s population are:

- Younger people leave the area for education and employment opportunities.
- People later in their working lives or early retirement are moving to the area for the lifestyle, affordability and/or retirement.
- Older people (over 70) are moving from the rural areas of the district to Waimate or leaving the area, likely in search of better healthcare or to be closer to family.

### 6.2.6 Growth story from 2019 to 2022

WDC has experienced steady population growth over the past three years with an average yearly growth of 50 people per year. This is similar to long term historical trends. The average age in WDC has increased from 43.8 to 44.9, and there is now a larger population in both the 30 to 39 year and 60 to 84 year age groups.

Figure 6-4: Waimate District’s population by Age – 2013, 2018, 2022 (Source: NZ Stats)



### 6.2.7 Households


The number of households in the District is projected to increase by an average of 0.4% a year between 2023 and 2053.

The average household size in the Waimate District is set to decline from 2.3 people in 2013 to 2.1 people by 2038. This will follow the national and regional trends (NZ – decrease from 2.64 people to 2.50 people. Canterbury - decrease from 2.4 to 2.3 people). Smaller households may contribute to demand for housing over and above the impact of population growth.

Dwelling numbers have also increased. While detailed dwelling information will not be readily available until the 2023 Census data is released (the first tranche of data is expected to be released

late 2023 or early 2024), consent records provided by WDC indicates that on average around 30 new dwellings have been constructed each year since 2019. This is similar to long term trends and aligns with expectations considering the levels of population growth.

**Figure 6-5: Waimate District Household numbers and type**



The number of one person households is the fastest growing household type in the Waimate District, increasing by an average of 1.2% per year. By 2038 33% of Waimate households will be one-person households and over 15% of Waimate residents will be living alone.

The number of families in the Waimate District is projected to increase by an average of 0.34% per year between 2013 and 2038.

### 6.2.8 Employment

WDC is a mostly rural district with agriculture being the prominent employer. The number of agriculture jobs has dropped since 2019, with a decline in orchards and livestock farms in Makikihi-Willowbridge, and dairy farm jobs in Morven-Glenavy-Ikawai.

The fastest growing sector is food manufacturing, driven by the expanding Oceania Dairy plant in Morven.

The other prevailing sectors are secondary supporting services including education, construction, and retail. These industries have remained relatively steady.


Whilst jobs have decreased since 2019, it is not believed that this is a long-term trend.

### 6.2.9 Population Location

Statistics New Zealand provides population breakdowns for area units within territorial authority boundaries for the period 2013-2043. For the Waimate District the area units provided are for urban Waimate, St Andrews township, and Waihao (covering the rest of the district).

The graph below shows gradual growth in the Waimate and Waihao areas, with growth flattening from 2038 onwards. Waimate DC will continue to monitor growth trends though subsequent census periods to confirm these trends.

**Figure 6-6: Waimate District Population Projections 2013-2053**



### 6.3 Projects That Will Have An Impact On District Population

There are a number of projects that will or have had an impact on the district’s population:

- Hunter Downs Irrigation Scheme – Did not proceed (2020)
- Waihao Downs Irrigation scheme (Commissioned)
- Oceania Dairy Factory
- Alps to Ocean Cycle Track (Commissioned)

Details of these projects are presented below.

#### Hunter Downs Irrigation Scheme

The Hunter Downs Irrigation Scheme was to be a community irrigation proposal developed originally by the South Canterbury Irrigation Trust (SCIT) and Meridian. The scheme would have potentially irrigated up to 40,000 ha of land from the Waitaki River stretching as far north as Otipua. The scheme was reduced to just 12,000 ha of irrigated land with construction supposed to start mid-2018. At the time of writing this AMP, the consent has lapsed, and the project did not proceed.

#### Waihao Downs Irrigation Scheme

The Waihao Downs Irrigation Scheme irrigates 6,800 ha of farmland within a larger command area of 14,000 ha in the Waihao basin. The scheme involves taking water from the Waitaki River which is then distributed through a piped network to farms. There are a few potential farm conversions left.

#### Kurow Duntroon Irrigation Scheme

The Kurow Duntroon Irrigation Scheme, within the neighbouring Waitaki district, was developed by the Ministry of Works during 1965.

The original system consisted of a siphon drawing water from the Waitaki Dam into a 35 kilometres long open water race delivering water via a gravity fed system of manually operated gates.

This system was replaced during 2018/19 by installing 76 kilometres of pipelines from Waitaki Dam to Duntroon on the west bank of the Maerewhenua River. The system will ultimately enable irrigation of 5,500 hectares.


The Kurow Duntroon Irrigation Company (KDIC) is a community owned irrigation scheme and holds a resource consent (CRC163429) from Ecan that expires in 2048, for an annual water take of 26.3 million litres. The scheme will increase activity in the rural service industries (on farm contractors and farm supplies) and processing companies (milk companies and vegetable processing).

**Oceania Dairy Factory**

Oceania Dairy Limited is a wholly-owned subsidiary of Inner Mongolia Yili Industrial Group (Yili) and is China’s largest dairy producer. The state-of-the-art Glenavy processing plant has been designed for the production of milk powder for export to China where it will be used by Yili to produce infant formula. Stage Two is now complete.

**Alps to Ocean Cycle Track**

This is a cycle track from Aoraki/Mt Cook to Oamaru and is not yet fully complete. Construction of the off-road trail is ongoing and will likely take another few years to finish. Given central Otago Rail Trail didn't have real impact until a number of years later, Council has assumed that any impact will be similar for Waimate District.



With both the Hunter Downs and Waihao Downs Irrigation projects there is a high chance that Waimate will experience slight increases in population with changes in socio-economic structure and changes in land use.

**6.4 Water Supply Demand Drivers**

There are significant projects planned within the Waimate District which will have a significant impact on the water demand.

The change in land use from dry land to dairying has been occurring for a number of years and is continuing, albeit at a slower pace. The associated population increase will potentially place pressure on already limited resources.

The following table indicates how these factors are expected to be reflected in changes in domestic and non-domestic water usage.

**Table 6-3: Water Demand Drivers**

Water Demand Drivers	Domestic	Commercial	Industrial	Agricultural/Horticulture
Growth	Population change in reticulated areas	Increase in commercial areas	Expansion of industrial areas	Change in land use
Water Usage - Consumption	Domestic water usage	Commercial water usage	Water Conservation Increase in “wet” industries	Domestic consumption in rural areas
Water Usage - Irrigation	Domestic Irrigation	Not Significant	Industrial water irrigation	Irrigation Intensive farming
Water losses	Water Losses – All Reticulated Areas			
Resource Consent - Renewals	The renewal of resource consents will require water conservation measures to be implemented and will place additional drivers to match demand and customer expectations. A water conservation strategy will be developed and promoted prior to future water extraction consent renewals			
Legislative changes	Central Government is signalling that the focus will change from water quality to water quantity			

## 6.5 Water Usage Trends in Waimate District


Water intensive industries can have a large impact on the total daily water consumption for small water schemes. The impact of water intensive industries would need to be assessed as they arise and their effect on the scheme assessed at that time.

### 6.5.1 Waimate Urban Water Scheme

The Waimate Urban water scheme consented volume allows flows up to 65 L/s from two sources, Manchester Road bore (20 L/sec) and the Timaru Road bore (44 L/sec). The only limitation in the supply of water is the reticulations’ ability to distribute the full consented allocation and supply the reservoir. At peak times, Manchesters Bore can reach 21L/sec (10.3Bar), and Timaru Road Bore 35L/sec (10.25Bar) with minimal flow into the reservoir. More flow can be provided but at higher pressures. In 2008 Timaru Road Bore had been set to 12Bar pumping pressure to increase supply with negative effects on the reticulation pipework. Under the current normal conditions there is sufficient capacity for the Waimate Urban water scheme demand. However, during 2009 Council conducted a pressure management study “Waimate Water Supply – Pressure Management Study” (Opus International Consultants Ltd. 2009), which recommended pressure management of the system to defer renewals. Different options are currently under consideration, which includes a dedicated delivery rising main from the bores to the reservoir. In the last five years only water conservation measures have been implemented.

The following Figure details the average daily water usage for the period 2020/21 to 2023/24. Note that these figures include water supplied to the Hook-Waituna Rural Water Supply.

Figure 6-7: Waimate Urban Water Supply Demand



The graph above shows that the average daily demand ranges between 1,415m<sup>3</sup> to 1,627m<sup>3</sup> and the peak demand days between 3,354m<sup>3</sup> to 3,687m<sup>3</sup>. Annual demand ranging from 516,436m<sup>3</sup> (2021/22) to 593,690m<sup>3</sup> in 2023/24.

### Future Capacity

There is insufficient capacity within the Waimate Urban water scheme to service significant increases over the next 10 years. During peak summer periods the existing pumping system is operating 24 hours a day. The inclusion of a new 300mm diameter well (Winter 2018) at Manchesters Road and the commissioning of a dedicated delivery main by 2019/20 will ensure that increases in population are catered for. Additionally, this will free up capacity within the existing reticulation. Capacity is likely to increase when volumetric charging is considered in the future.

### 6.5.2 Rural Restricted Schemes

The continued change in farming practices, mainly sheep to dairy farming, not only increases the demand for potable water but also affects the quality of water sources. Dairy farms in close proximity of water sources increase the potential for contamination.

There is increasing demand on the rural schemes to provide more water for stock consumption and in the case of dairy farms, high quality water for wash down of facilities. Council will carefully consider any application for extra water for all of the rural schemes.

In other districts where there has been a change from dry land farming to irrigated (with significant dairy farming), the demand for dairy stock water and wash-down water (within the milking sheds) is significantly higher than what a restricted scheme can supply. The restriction is usually the reticulation (main diameter). While the demand for stock watering with increased dairy farming may decrease, there is a corresponding increase in the number of houses and subsequent domestic water requirement. Note that the quantity of water supplied to rural properties is controlled via restrictors that can be adjusted to ensure that each property receives the correct amount of water.



**Table 6-4: Water Demand**

2018/19	Waimate Urban	Cannington Motukaika	Hook Waituna	Lower Waihao	Otaio Makikihi	Waihaorunga	Waikakahi
Average Demand(m <sup>3</sup> /day)	1,332	319	957	740	652	267	891
Peak Demand(m <sup>3</sup> /day)	2,545	531	1159	1,358	882	274	982
Treatment Capacity (m <sup>3</sup> /day)	4,882	475	1,728	1,771	1,296	455	1,054
Resource Consent Allow. (m <sup>3</sup> /day)	5,616	475	1,728	1,633	929	576	1,469
Service Connections (as at 2024)	2,007	48	532	225	227	42	172

Customer expectations are increasing, with demands for greater water pressure and availability. Increased water quality expectations are reflected in the Water Services Act (legislative) and in aesthetics qualities such as odour and taste (DWSNZ). There is also a shift observed in lifestyles with more households having spa pools, landscaped gardens with water features and sprinklers to maintain the gardens and lawns. The result is an increasing demand on the water schemes (reticulation network and water treatment plants) to supply greater volumes of water of higher quality.

## 6.6 Legislative Changes

The legislative framework and government and industry direction is discussed in Section 3.0.

## 6.7 Demand Management

### 6.7.1 Background

Demand Management strategies are used as alternatives to the creation of new assets. They are aimed at modifying customer demands to achieve:

- Social, environmental and legislative objectives for Waimate District.
- The delivery of cost-effective services.
- Defer the need for new assets and optimise the performance/utilisation of the existing assets.

Council is working on a range of strategies to manage the demand for water and therefore the requirement for additional infrastructure. Table 6-5 lists strategies used by the Council.

**Table 6-5: Demand Management Strategies**

Strategy	Objective/ Description
Operations	Reduce unaccounted for water by leakage detection and control Investigate the level of water loss (leakage) to determine if a water loss problem exists
Operations	System Pressure Management: Pressure measurement is being considered to enable changes that will reduce operating pressures which impact on reticulation and reduces water losses. This needs to be balanced with levels of service with the consumer on adequate pressure
Waimate District Consolidated Bylaw 2018	The Water by-law does not have any direct water conservation requirements other than to prohibit water wastage and to ensure prudent use and require consumers to comply with any water restrictions publicly advertised during droughts, periods of unusually high demand or emergencies
Policy	Water Management Strategies: Council will consider developing a strategy to encapsulate the overall planned management of the water takes, use, and conservation education with an aim to reduce the per capita consumption. This is consistent with Councils resource consents requirements



Strategy	Objective/ Description
Education	Water Conservation Strategy: Water conservation programmes aimed at increasing community awareness of the benefits of conserving water and reducing water demand. These programmes include information on ways to conserve water and can be implemented through public signage in key locations and using the print media
Water Charges	Water meters were installed for all extraordinary supply users, therefore commercial, industrial, non-urban, and high usage consumers. In 2021/2022 universal metering was installed across the urban network. These meters are currently being used to measure water loss remotely.
Water Restrictions	Water restrictions are used to manage peak demand. Water restrictions typically include limits on the use of garden hoses

The NZS 4404: 2010 Land Development and Subdivision Infrastructure Standard specifies for design purposes the daily consumption as 250 L/person/day.

The Ministry of Health published “Household Water Supplies – The selection, operation and maintenance of individual household water supplies (2006)” which provides information about the supply of safe drinking-water to households not connected to town water supplies. These figures provide useful guidance as to what the Ministry for Health deems appropriate for personal consumption, cleaning and washing, which amounts to 300 L/person/day.

The 2007 AMP stated that the peak daily consumption (Total Demand – Leakage) was estimated to be 1,960 m<sup>3</sup>/day, this equates to 710 L/per capita/day.

As part of the Non-Financial Performance Measures Rules 2013, consumption monitoring became a mandatory performance measure. From this monitoring the daily average consumption for the last two financial reporting years showed a reduction of 130 – 150L/day per person. This reduction in consumption can be attributed to the leak detection surveys, and the follow up maintenance and repairs. The daily average consumption was 559L/person/day for 2015/16 and in the 2016/17 financial reporting year, 578L/person/day, which is still high considering the NZ standards and Ministry of health figures (250 and 300 litres/person/day). When adjusted for network water loss these figures reduce to approximately 310L/person/day (2016/17). This has reduced to 383L/person/day in 2022/23 and 469L/person/day in 2023/24

A Water Demand Management Strategy / Plan is required to:

- Identify the drivers for demand management in the Waimate context.
- Identify positives and negatives of demand management initiatives.
- Identify the following:
  - actual necessary use
  - wasteful use
  - losses (avoidable, economic and interference)
- Prioritise the areas where greatest need exists for demand management.
- Identify and implement appropriate demand management initiatives.

### 6.7.2 Reduction of Leakage

The reduction in water leakage rate within the Council’s reticulation has a positive effect on maintenance costs (reduced pumping costs) and increases the time before additional capacity is required (optimisation of the existing assets).

The leakage rate in the urban area has historically been very high. Council staff has developed a strategy of assessing leakage in the urban area via measuring minimum nighttime flow rates.

During the period May to June 2009 Council actively targeted the repair of all leaks identified during the leak detection exercise. However, a review of telemetry flow data for the period pre/post leak repair showed that the minimum night flows increased from 10 L/s to 15 L/s. A further substantial leak was found and repaired. This highlighted the sensitivity of the network and its tendency to burst under high pressures. This also highlighted the need for pressure management to reduce burst rates, reduce leakage and extend asset lives.

In 2011 another survey was undertaken, leakage rates reduced from 18 L/s to 9 L/s. To assist to achieve a target of 6 L/s, it is intended to zone the town into four to five sub-zones to better concentrate leakage reduction results. The leak detection service will be used on a three year cycle.

Again, in mid-2015 another survey was undertaken. 84 leaks were detected which equated to an estimated 171.2 L/m (2.8 L/sec) loss through leakage. 52 out of the 84 (62%) leaks were on private property, after the point-of-supply. This raised the question of individual consumer responsibility, water conservation, education and water meters (*Water and Wastewater Managers report for the District Infrastructure Committee meeting August 2015*).


**Table 6-6: July 2015 Leak Detection Survey Leak Counts and Estimated Water Loss**

Leak Type	Count	Estimated Combined Leakage Flow Rates (L/min)
Private	52	134.4
Leak at Connection	19	4.75
Lateral	3	13
Sluice Valve	6	7.5
Fire Hydrant	3	1.5
Tapping/main	1	10

Water losses have also become a mandatory Non-Financial Performance Measure requirement. Council has made significant progress in reducing water loss in recent years and is currently holding at around 22% (as shown in Figure 6-8).

No further leak detection was undertaken as the mains renewal programme resulted in a significant reduction in water loss. The MNF water loss calculations provides useful commentary on the reduction in water loss as a result of the mains renewal programme. Between September 2017 and December 2018 MNF water loss hovered around 55% - 58% within the Waimate Urban Water Supply. Mains renewals, AC & CI, resulted in a significant reduction of 44% between December 2018 and March 2020. A major contributor was a significant water leak on the Wilkin Street mains, which was renewed from Edward Street to Michael Street. This Wilkin Street project was completed during March 2019.

However, water loss had increased from 13.8% in March 2020 to 22.1% in September 2020. As mains are replaced, reducing leakage in one area it increases pressures throughout the network which may lead to increased leakage or breaks in other areas and as a result water loss rates may fluctuate. In June 2024 water loss has been recorded as 21.3%. With an active renewal programme, the introduction of pressure management during the life of this AMP and the implementation of universal metering, Council is expecting further reductions.

**Figure 6-8: Water Loss Trends**

As part of Council's delivery plan water meters are installed at all connections throughout the network. This aid in leak detection on both private and commercial properties. Extra Ordinary users (high volume, commercial and businesses) with continue to be charged for water in excess of 200m<sup>3</sup> per six-month period. At the time of writing this asset management plan, Council is not considering a review of either charging mechanism or setting price points. The outcome of the 3 Waters reform programme may well result in this decision being revisited in the future.

Consideration of future volumetric charging shall be based on the drivers created by the 3 Waters Regulatory reform and 'Water Sensitivity' i.e. improved management from source to customer. This includes programmes such as the Canterbury Water Management Strategy.

### 6.7.3 Network Modelling

Network modelling (InfoWorks WS) has been carried out for all schemes. The network modelling provides staff with:

- Determining the capacity of the existing network and identify areas not meeting the existing or future Levels of Service and upgrade requirements determined.
- An operational and management tool to assist in making the right decisions to improve and maintain service levels and reducing costs.
- New subdivisions can be modelled and effect on the network determined.
- Reliable calibrated hydraulic models provide a robust decision-making support framework in which numerous future scenarios of demand, population growth, climate change and land use variables can be readily evaluated to assist in the determination of optimal network improvements required to meet future or changing needs.

### 6.7.4 2021 Modelling Project

During 2021 Council engaged One Water Modelling (OWM) to update their water model stock to 2021 to assess any capacity issues in the networks and ability to service future growth. The following Schemes were assessed:

- Waimate Urban

## Section 6: Growth and Demand Management

- Otaio-Makikihi
- Lower Waihao
- Waihaorunga
- Waikakahi
- Cannington-Motukaika

The project covered the following areas for each scheme:

- Building a model including:
  - Reticulation,
  - Plant,
  - Customer demand
  - Leakage
- Calibration
- Verification
- Current & future demand scenarios
- Pressure Management
- Network & Plant upgrades
  - Priority 1, 2 and 3 Upgrades
- Recommendations

### Waimate Urban:

The recommendations for Waimate Urban include:

**Table 6-7: Waimate Urban – Model Recommendations**

Waimate Urban recommendations	Priority	Year
Pipe upgrades – Butchers Lane Parsonage Road Timaru Road Hilary Street Massey Street High Street / Bakers Road	1	
Pipe upgrades – High Street Herbert Street Town Belt Point Bush Road	2	
Pipe upgrades – High Street Queen Street	3	
Establish Pressure Management Areas		
Resolve Manchester Road pump issues		

Waimate Urban recommendations	Priority	Year
Construct upgrades to comply with SNZ PAS 4509:2008 Firefighting Code of Practice		
Automate pump controls at Manchesters and Timaru Road pump stations		
Track specific consumption		
Confirm Manchesters and Timaru Rd PS can meet 2050 demand		
Develop Concept Plan to service Waimate beyond 2050		
Monitor the long term performance of the rising mains		
Assess likely timing of pump and rising main upgrades		
Confirm likely impact of additional augmentation to Hook Waituna		
Fix Timaru Rd Booster transducer		
Replace the Waimate Reservoir flow meter		
Review growth areas		
Confirm likely service plan for Tekiteroa		
Demand Management		
Review model, demand and system performance 3 yearly		

### Otaio Makikihi

The recommendations for the Otaiao Makikihi Upgrades include:

**Table 6-8: Otaio Makikihi – Model recommendations**

Otaio Makikihi recommendations	Priority	Year
Pipe upgrades – Campbell Forest Tanks supply Thompsons BPT supply Middle Reticulation PRV Supply Middle Reticulation Upgrades Lower South Reticulation Upgrades Woolshed Upgrades Upper Paddock and Upper Roadside Upgrades	1	
Pipe upgrades – None	2	
Pipe upgrades – Middle Reticulation Lower South Reticulation Woolshed Upper Roadside	3	
Investigate Tavistock Middle meter accuracy		
Upgrade flow meters		
Upgrade pipes to resolve pressure (LoS) issues		
Limit additional sold volume		
Ground model		
Update pipe GIS to include nodes at junctions		
Maintain model		

**Lower Waihao**

The recommendations for Lower Waihao include:

**Table 6-9: Lower Waihao – Model recommendations**

Lower Waihao recommendations	Priority	Year
Pipe upgrades – Glenavy and on Substation and Andrews Roads pressure LOS at T13LW and T193LW pressure LOS at T12LW pressure LOS issues on McLeays Road pressure LOS at T217LW, T233LW and T192LW pressure LOS issues at T45LW	1	
Pipe upgrades – pressure LOS at T21LW pressure LOS at T6LW and T146LW pressure LOS at T71LW	2	
Pipe upgrades – Glenavy demand area Morven demand area Old Ferry Road demand area Main demand area	3	
Maintain model		
Upgrade pipes to resolve pressure (LoS) issues		
Consider Pressure Management Areas		
Resolve high elevation customer issues		
Install additional flow meters		
Investigate SCADA timing offset between plant sites		
Record impeller size in plant information		
Review Peak Day Demand		
Update pipe GIS to include nodes at junctions		
Confirm PRV setting at Old Ferry Road		
Combine Lower Waihao and Waikakahi models		

## Waihaorunga

The recommendations for the Waihaorunga Upgrades include:

**Table 6-10: Waihaorunga – Model recommendations**

Waihaorunga recommendations	Priority	Year
Pipe upgrades – Tavendale Intake Main East of Tavendale Contact Tank East of Tara Hill BPT Zig Zag Road PRV East of Melford Reservoir South of Takitu Reservoir	1	
Pipe upgrades – None	2	
Pipe upgrades – North of Tavendale Contact Tank East of Tavendale Contact Tank Waihaorunga Reservoir Zone Zig Zag Road PRV North Branch Melford Hills PRV Zone Downstream of Takitu Reservoir	3	
Resolve Melford Pump Station operation		
Resolve Waihaorunga Intake Pump Station operation		
Upgrade recommended pipes to resolve pressure (LoS) issues		
Limit additional sold volume in Tavendale		
Upgrade SCADA coverage		
Install or upgrade flow meters		
Ground model		
Survey elevation at Plant sites and key customers		
Update pipe GIS to include nodes at junctions		
Maintain model		

## Waikakahi

The recommendations for the Waikakahi Upgrades include:

**Table 6-11: Waikakahi - Model recommendations**

Waikakahi recommendations	Priority	Year
Pipe upgrades – Upgrades to supply Break Pressure Tank BT4WK Upgrades to supply Claytons Pump Station Suction Tank Elephant Hill Back Road Between Serpentine Valley Road and Waihaorunga Road Downstream of BT3WK Downstream of BT8WK Downstream of Claytons Pump Station Suction Tank	1	

Waikakahi recommendations	Priority	Year
Downstream of BT15WK Downstream of Claytons Reservoir Downstream of BT5WK		
Pipe upgrades – None	2	
Pipe upgrades – Near Waikakahi Reservoir Downstream of BT5WK West of Trunk Main Downstream of BT16WK Downstream of BT9WK Waikakahi East	3	
Resolve Waikakahi intake pump station operation		
Maintain model		
Upgrade recommended pipes to resolve pressure (LoS) issues		
Limit additional sold volume		
Ground model		
Survey elevation at Plant sites and key customers		
Install additional flow meters		
Update pipe GIS to include nodes at junctions		
Combine Lower Waihao and Waikakahi models		

### Cannington-Motukaika

The recommendations for the Cannington Motukaika Upgrades include:

**Table 6-12: Cannington Motukaika – Model Recommendations**

Cannington Motukaika recommendations	Priority	Year
Pipe upgrades – Downstream of PRV2CM Downstream of PRV7289 Downstream Of Cannington Reservoir Galways Road (lateral) Hamiltons Break Tank (lateral) Downstream of PRV7036 Timaunga Road Moa Road	1	
Pipe upgrades – None	2	
Pipe upgrades – None	3	
Resolve Pratts Road Pump Station operation		
Confirm the PRV setting at PRV 7036		
Upgrade recommended pipes to resolve pressure (LoS) issues		
Install additional flow meters		
Ground model		



Cannington Motukaika recommendations	Priority	Year
Survey elevation at Plant sites and key customers		
Resolve high elevation customer issues		
Update pipe GIS to include nodes at junctions		
Maintain model		

### Hook Waituna Augmentation Project

During 2017 WSP Opus was engaged to perform a model build and capacity assessment to identify infrastructure upgrades required to meet current and anticipated future demand. During 2023 options were assessed to augment water to the Hook Waituna water supply from the neighbouring Otaio-Makikihi rural and Waimate Urban domestic supplies.

Hook Waituna is currently augmented from Waimate Urban at two locations:

- Willowbridge transfer at Bathgates Road, approximately 800 m downstream of Manchesters Road bore, water treatment plant (WTP) and pump station. This is discrete augmentation area with a boundary valve at Maytown Road.
- Mill Road transfer at the intersection of Mill Road and Allen Street.

The project considered the following options:

1. Augmentation from Otaio Makikihi WS
  - a. From low reticulation pressure zone
  - b. From middle reticulation pressure zone
  - c. Otaio Makikihi pump operation
  - d. Otaio Makikihi source capacity assessment
2. Augmentation from Waimate Urban WS
  - a. From Northwest Waimate
  - b. From Timaru Road rising main at Maytown Road
  - c. From Timaru Road via Crouch Road
  - d. Waimate Urban pump operation
  - e. Waimate Urban source capacity assessment

Connecting the northern part of the Hook Waituna WS (335 connections, population 600) to the Otaio Makikihi WS (228 connections, population 422) will impact the future of the Otaio Makikihi WS. The source (Tavistock bore) will require expansion which will require a minimum yield of 15 L/s to ensure a combined total yield of 30 L/s. with a second bore installed but yet to be commissioned. Further options include installing a 12.5km DN200 connecting main between the two schemes.

### **Waikakahi Augmentation Project**

Council is investigating and considering combining Waikakahi East (54 connections, population 101) with the Lower Waihao RWS (population 700). This will impact the remaining Waikakahi Scheme (119 connections, population 204).

#### **6.7.5 Universal Metering for Waimate Urban Water Scheme**

The benefits of universal metering are as follows:

It provides Council with a mechanism to implement a fair and equitable user-pays water billing system

It promotes the efficient use of water through reduction in excessive consumption and minimising water losses through leakage

It enables the Council to keep track of consumption and accurately identify the quantity of water lost to the system as leakage

It may assist with obtaining resource consents for future bores

These benefits needed to be balanced against the cost of installation, maintenance, and administration of the metering programme. A detailed economic assessment of the costs and benefits associated with universal metering for the Waimate Urban water scheme had been discussed in the report “Waimate Urban Water Supply: Issues and Options for Universal Water Metering” (Opus, 1998). This report concluded that the implementation of a universal water metering programme was not economically justifiable. Subsequently Council secured funding through the Covid Stimulus Fund and local share.

Council is not considering a review of either charging mechanism or setting price points. The outcome of the Local Water Done Well reform programme may well result in this decision being revisited in the future.

The installation of water meters allows remote monitoring of these connections to better understand consumer consumption, and understand water loss through leakage.

#### **6.7.6 Public Education**

Effective external education programs increase public knowledge about

The need for water conservation,

The potential benefits of demand management, and

How to participate in local action

It is important for the public to permanently change their water use through an appreciation of the value of water and an understanding of simple and efficient ways to achieve at home. This can only be achieved through a well organised and consistent education and outreach programme.



## 7.0 RISK MANAGEMENT

*This section looks at the Risk Management Processes utilised by Council for assessing and managing risk within the Water Services.*

### 7.1 WDC Risk Management Framework

Council has a Risk Management Policy, 2022 that provides a policy framework for risk management across council. The policy states that WDC recognises that early and systematic identification, analysis and assessment of risks, and the development of plans for controlling and mitigating risk, are necessary to achieve its desired objectives

#### 7.1.1 Risk Management Objectives and Principles

Key WDC risk management objectives are:

- The implementation of a comprehensive Risk Management Framework;
- Identifying, analysing, assessing and appropriately managing the risks to its objectives;
- An open and receptive approach to solving risk problems;
- Ensuring that risk management is integrated into normal business processes and is aligned to the strategic outcomes of the WDC.

The WDC key principles in its approach to risk management:

- a. Risk management creates and protects value.
- b. Risk management is an integral part of all organisational process.
- c. Risk management is a part of decision making process.
- d. Risk management explicitly addresses uncertainty.
- e. Risk management is systematic, structured and timely.
- f. Risk management is based on the best available information.
- g. Risk management is tailored.
- h. Risk management takes human and cultural factors into account.
- i. Risk management is transparent and inclusive.
- j. Risk management is dynamic, iterative and responsive to change.
- k. Risk management facilitates continual improvement of the organisation.

#### 7.1.2 WDC Approach to Risk Management


WDC approach to risk management recognises that Business-as-usual procedures encompass a number of elements that together facilitate an effective and efficient operation, enabling the WDC to respond to a variety of risks. These elements include:

- a. Operational awareness: keeping ourselves updated on changes or issues within our operating environment.
- b. The process of tracking progress towards achievement of the strategic outcomes defined in the Long Term Plan, Annual Plan, Financial Strategy, and 30-year Infrastructure Strategy.
- c. Unit planning and budgeting – the unit planning and budgeting process is used to set actions and allocate resources. Progress towards meeting unit plan targets is monitored regularly.
- d. Major projects - risk assessment and mitigation strategies are essential elements.
- e. Risk Register – to identify, assess, and monitor risks significant to the WDC. The risk register is reviewed quarterly and emerging risks are added as required.
- f. Assurance measures (internal reporting and internal audit where appropriate).

### 7.1.3 WDC Risk Management Process

The Risk Management Process comprises the activities described in the diagram below. It should be embedded in the culture and practices of the organisation and tailored to its business processes.

Figure 7-1: WDC Risk Management Process Diagram



The process diagram highlights the following important risk management actions:

- **IDENTIFICATION OF RISKS**

All staff members are empowered, and expected, to identify and communicate risks. Identified risks will be recorded in a risk management plan.

- **ANALYSIS OF RISKS**

Risks will be analysed to determine potential causes, the likelihood of occurrence, and the potential consequences if they do occur.

The causes, likelihood and consequence will be recorded in a risk management plan (risk register).

- **EVALUATION OF RISKS**

Analysed risks will be evaluated against criteria to determine whether a risk is tolerable in its current state or whether further action is required. The evaluation of risks will consider established risk tolerances for such risks, as well as any risk-specific factors. In the first instance, the evaluation of risk will include reference to the WDC Risk Response table

- **TREATMENT OF RISKS**

Where residual risk is considered to be too high, risk treatments will be applied to reduce the residual risk to an acceptable level.

In considering risk treatments, consideration will be given to both the costs and effort involved in the treatment and the potential benefit from the risk reduction. Key

Risk treatment can involve:

- a. Avoiding a risk by deciding not to start or continue with the activity that gives rise to the risk.
- b. Removing the risk source
- c. Changing the likelihood of the risk occurring
- d. Changing the consequence if the risk occurs
- e. Sharing the risk with another party or parties, or
- f. Retaining the risk by informed decision.

- **RECORDING OF RISKS**

Risks, controls and mitigations will be recorded in a risk management plan (risk register).

8.15 A high-level organisation-wide 'corporate risk management plan' (risk register) will be maintained to record and report on risks of WDC-wide significance. Subsidiary risk management plans will be prepared as appropriate throughout the organisation.

These may include, but will not be limited to:

- a. Group risk management plans
- b. Activity risk management plans (within Activity Management Plans)
- c. Asset risk management plans (if appropriate to be separate from Activity Management Plans)
- d. Specialists risk management plans (for example, health and safety)
- e. Project risk management plans, and
- f. Any other risk management plan relevant to helping the WDC achieve its objectives.

- **REPORTING OF RISKS**

Identified risks, and the associated controls, mitigations and accountabilities, will be reported in accordance with the Risk Response table included as Appendix 2. Risk management plans (risk registers) will be reported regularly to both the Leadership Team and the Committee responsible for risk.

- **ACCOUNTABILITY OF RISKS**

Specific accountability for each risk, control and mitigation will be identified and recorded in a risk management plan (risk register).

#### **7.1.4 Audit & Risk Committee**

Audit & Risk Committee to provide direction for the WDC's risk management and to ensure that appropriate risk mitigation activities are functioning effectively. Subject to the governing body's delegated authority, the Committee responsible for risk has responsibility to:

- Review the risk management framework
- Consider the robustness of mechanisms adopted by management to
- mitigate key risks, including the adequacy of internal controls
- Advise the governing body on matters of risk and provide objective advice
- and recommendations for the governing body's consideration
- Review disaster management and business continuity plans.
- Review the Risk Register at each quarterly meeting.

### 7.1.5 Risk Roles and responsibilities

Detailed roles and responsibilities of council staff are detailed in the Risk Management Policy.

### 7.1.6 Risk Audits

The use of internal audit is an important tool to assess the effectiveness of the internal control environment. The Audit and Risk Committee are responsible for approving the appointment of the internal auditor and overseeing their programme of work. From time to time, external Third Party Audits may be appropriate. The use of specialist third parties for auditing and reporting may be used to increase the reliability of the internal control system.

## 7.2 Water Risk Assessments

There are essentially three levels of risk assessment that should be considered for each activity within Council:

Level 1 - Organisational Risk Assessment

Level 2 - Activity Management Risk Assessment

Level 3 - Critical Asset Risk Assessment

### Level 1 - Organisational Risk Assessment

Organisational Risk Assessment focuses on identification and management of significant operational risks that will have an impact beyond the activity itself and will affect the organisation as a whole. This approach allows the Integrated Risk Management framework to address risks at the organisational level, as well as at both the management and operational levels within the particular Council activities. The decision to implement the treatment measures identified will be at an organisational level, not activity level. Council recently adopted a risk policy at an organisational level.

### Level 2 - Activity Management Risk Assessment

Activity Management Risk Assessment uses the same principal and consequence tables, but the focus has been at more detailed level. During this process, specific risk events were identified which would affect the operational ability or management of the activity as a whole. If an individual system within the activity was identified as being at a greater risk or would need to be managed in a different way to the rest of the systems, then it was highlighted for separate consideration.

A Risk Summary Table was established in 2011 (see Table 7-1 below), which identifies risk management strategies to minimise risks associated with the provision of the Water, wastewater, stormwater and solid wastes services. It is considered that the risks, mitigations and improvements have not markedly changed since the risk summary table was established in 2011. Notwithstanding this, specific risks associated with water quality are documented within the Water Safety Plans for each water scheme.

Cannington-Motukaika Water Supply Water Safety Plan *Version 3.0 2022*

Hook-Waituna Water Supply Water Safety Plan *Version 4.0 September 2022*

Lower Waihao Water Supply Water Safety Plan *Version 3.0 November 2022*

Otaio-Makikihi Water Supply Water Safety Plan *Version 3.0 October 2021*

Waihaorunga Water Supply Water Safety Plan *Version 3.0 2022*

Waikakahi Water Supply Water Safety Plan *Version 3.0 2022*

Waimate Water Supply Water Safety Plan *Version 4.0 November 2022*

The risk profile will be extended to encompass assets down to a component level in a Risk Management Plan. In the absence of component level assessments, the risk summary table will be used to provide guidance for mitigation steps.

The risk management plan will be designed to ensure that:

- All significant operational and organisational risks are understood and identified.
- The highest risks that should be addressed within a 10 year planning horizon are identified.
- Risk reduction treatments which best meet business needs are applied:

### **Level 3 - Critical Asset Risk Assessment**

Critical assets are considered those assets in which failure would result in a major disruption to the supply of water or levels of service. Usually, the identification of critical assets is based on pipe diameter or population served.

The criticality of an asset reflects the consequence of the asset failing (not the probability). High Criticality assets are best defined as assets which have a high consequence of failure (not necessarily a high probability of failure).

A criticality assessment has been carried out in 2017. See Section 3.11



Table 7-1: Risk Summary Table (Showing Significant or High Risks only)

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
1	<b>Higher Level Policies, Procedures and Controls</b>					
1.5	The Council does not have an acceptable position on the impact of climate change on service delivery	Financial loss due to liability for property damage, loss of asset. Not able to provide service.	Significant	Council is developing a Climate Resilience Strategy To be finalised in 2025	Low	Continued implementation of Councils Climate Resilience Strategy on the effects of climate change
2	<b>Financial</b>					
2.1	Lack of long-term financial planning	Higher than necessary financial costs	Significant	Existing network models are up to date and available	Low	
2.2	Service levels vs funding and works not clear	Service levels not being met due to lack of funding as decision makers not aware of implications for Service Levels.	Significant	Set performance targets for next 10 years and monitor and report on performance. Impacts of delayed capital works reported to Council.	Low	
2.3	Assumptions for financial forecasting not always understood	Additional costs incurred because assumption/uncertainties not accounted for i.e.: asset valuations, depreciation	Significant	Finance/managers need to be aware of assumptions and uncertainties behind financial forecasting information.	Moderate	Improvement of quality of information
2.4	Unforeseen Additional Costs	Reputation of Council detrimentally affected	Significant	Ensuring AMPs and asset information up to date and accurate.	Low	
2.8	Insurance cover needs review	Insurance not adequate and unnecessary costs incurred	High	Insurance cover reviewed to ensure adequate cover on annual basis.	Low	
3	<b>Organisational Management</b>					
3.3	Lifelines Plan not up to date or implemented	Large scale asset failure due to a naturally occurring event resulting in prolonged and substantial loss of service to District	Significant	Ensure Lifelines Plan up-to-date and recommendations implemented that includes having a high level of risk reduction, readiness, response and recovery during and following Civil Defence Emergency.	Significant	Update lifelines plan

Section 7: Risk Management

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
4	<b>Human Resources</b>					
4.3	Information in people’s heads or inappropriate recording of information	Organisational knowledge lost with staff leaving	Significant	Ensure staff document and appropriately file everything that is relevant. Ensure good management succession when existing staff leave.	Moderate	Formalise and update maintenance schedules and procedures, contingency and operation and maintenance manuals.
4.4	Insufficient staff or not appropriately skilled	Programmed work not completed due to insufficient staffing or skill levels, having negative impact on service levels and creating public health risk.	High	Skill levels are appropriate	Low	Formal training programme required that includes the use of activity management plans.
4.5	Inadequate attention to staff succession	Organisational knowledge lost with staff leaving	High	Implement good staff/management succession plan and document procedures. Address imminent risks associated with staff retirements.	Moderate	Ensure staff are appropriately trained and have a good understanding of the requirement for written procedures and manuals (inc. AMP’s)
6	<b>Asset Management</b>					
6.1	Network modelling, condition assessments not undertaken.	Capital Works programme not optimised. Renewal works not completed due to lack of knowledge causing failure of assets. Future forecasting not accurate.	Significant	Undertake formal condition assessments of network and develop robust renewals programme based on sound knowledge.	Moderate	Network model informed by the ongoing assessment programme of condition and performance data.
6.2	As-built information can be slow or incorrect coming from maintenance staff, Contractors, Consultants	Council faces legal action because of incorrect information provided (particularly with regard to LIMS)	Significant	Ensure As-builts up to-date and on record promptly. Ensure GIS capability. Better define as-built requirements for internal staff and external contractors.	Low	

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
6.3	Criticality assessment not undertaken	Failure of critical assets resulting environmental damage or not meeting service levels	Significant	Criticality assessment of assets have been undertaken. implementation strategy for managing critical assets is ongoing	Low	Continue to Incorporate criticality assessment of assets and implement strategy for managing critical assets.
6.5	Asset management systems not up-to-date or completed	Failure to of utility systems because maintenance work not completed or management system not operational.	Significant	Asset Management System in place and updated as required	Low	Continuous improvement required to retain appropriate level of sophistication. Provide dedicated resource to managing asset data flows.
6.8	Capital works delayed due to unforeseen circumstances	Programmed Capital Works not completed. Target Service Levels not met	Significant	Staff held accountable for delays & Staff trained in project management.	Moderate	Develop projects process that provides for project plans to be prepared for every approved renewal and capital development item.
6.9	Deferred renewal and maintenance not recorded or not done	Deferred maintenance not recorded causing unexpected, additional costs from asset failure	High	Record all deferred maintenance and renewals	Moderate	Ensure all deferred renewals work recorded and management aware of impact on service levels if not funded.
6.10	Not all easements recorded or obtained	Council faces legal action or cannot carry out its activities because it does not have legal right to cross a property	Moderate	Keep up-to-date record of easements. Establish clear policy for processes to be followed when easements are required.	Low	Easement information needs to be improved with all identified easements provided with details of

Section 7: Risk Management

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
						interested part. Legal situation to be clarified.
6.11	Insufficient documentation of escalating process decision making	Response to emergency situations reduced, higher expenditure	Significant	Employment of staff with the appropriate qualifications and skills	Low	
10	<b>Asset Risks - Stormwater</b>					
10.5	Insufficient overland flow paths	Flooding of houses and properties	Significant	Modelling of system will ascertain flow path requirements	Moderate	
10.6	Overland Flow Paths located on private property - no maintenance (overgrown/built upon)	Flooding of houses and properties	Significant	Council staff have good maintenance and monitoring provisions	Moderate	
10.7	Overland Flow Paths Located on Councils property or roads - no maintenance (overgrown etc.)	Flooding of houses and properties	Significant	Council staff have good maintenance and monitoring provisions	Moderate	
11	<b>Asset Risks - Wastewater</b>					
11.1	SCADA Failure	No alarm available	Significant	Back-up systems and procedures	Moderate	

## 7.3 Risk Management Focus Areas within Council

### 7.3.1 Business Continuity

Business Continuity is a progression of disaster recovery, aimed at allowing an organisation to continue functioning after (and ideally, during) a disaster, rather than simply being able to recover after a disaster.

It is proposed to develop Business Continuity and Emergency Management Plan (for rapid and structured response to emergency failures and significant hazards) and ensure review control process is carried out.

### 7.3.2 Succession Planning

Succession planning within any business is considered necessary to reduce the risk associated with staff leaving the organisation and forms part of the business continuity process. Succession planning allows institutional knowledge to be passed on and assists in ensuring continuity of organisational culture. To this end the Water AMP is quite detailed to ensure all relevant documents and information required for appropriate decision making are recorded and knowledge transfer can occur even in the absence of key staff.

### 7.3.3 Health and Safety

Council is responsible for providing a safe work environment for its staff and public. A Health and Safety committee meets regularly and provides information to all council staff on their obligations in this matter. Council provides training in general and specific safety areas as required.

The Council's Utilities staff, by the nature of their work are exposed to risks outside the office environment that are associated with the utilities services (reticulation and facilities). Council provides training in general and specific safety areas as required, examples for the utilities services are:

- Confined space requirements for supervisors and engineering staff that are associated with reticulation
- Traffic control at work sites via the code of practice
- Facilities Health and safety register and associated sign in/out procedures

### 7.3.4 Pandemic Response – COVID 19

The 2019–20 coronavirus pandemic is ongoing at the time of writing of this Plan. The timeline of events are as follows:

**Table 7-2: COVID 19 Chain of events**

Date	Event	NZ Government Response	Waimate DC Response
11/02/2020	World Health Organisation declares an official pandemic		
28/02/2020	NZ first reported case		
21/03/2020		Alert Levels (1-4) announced	
23/03/2020			Temporary closure of Council facilities
24/03/2020		Move to Alert Level 3	
25/03/2020		State of Emergency declared	Refuse services continue. Recycling services cease
26/03/2020		Move to Alert Level 4	

Date	Event	NZ Government Response	Waimate DC Response
27/03/2020			Notice of Essential Services
24/04/2020			Notice of Building Control Services under Alert Level 3
27/04/2020		Move to Alert Level 3	
30/04/2020			Emergency budget response
13/05/2020		State of Emergency lifted	
14/05/2020		Move to Alert Level 2	
10/06/2020		Move to Alert Level 1	

The impacts have been wide ranging and have included a significant and protracted recession. Council received funding through the following central government initiatives, with some related to the pandemic and others related to the Three Waters Reform programme(s):

- Covid Stimulus Funding (\$3,360,000)
- Transition Funding (\$350,000)
- Better-Off Funding (\$2,420,000)

The response to COVID 19 provided a snapshot of how quickly our environment can change and how quickly we can adapt. People working from home. The uptake of technology. Change in transportation patterns. Online sales and deliveries. Outdoor activities. Socio economic impacts and response.

### 7.3.5 Operation & Maintenance

In the daily operation and maintenance of the water supply system Council employ a range of risk management procedures including but not limited to:

- Prevention of contamination of treated water
  - Minimum requirements for disinfection of existing water mains and fittings during planned and reactive maintenance
  - Separate wastewater vehicle and tools
  - Best appropriate practices for staff including contractors and materials
  - Illegal connections
  - Appropriate use of backflow preventers
  - Develop a Hygiene Plan / Process
- Critical consumers
- Shutdowns
- Health and Safety
- Asbestos handling
- Traffic control and management
- Overflows and Clean up

Council also has the following agreements in place with local contractors in relation to Civil Defence Emergency expectations:

- Provide plant and personnel on site to enable the emergency work to be undertaken
- Advise the Engineer immediately if unable to either commission sufficient resources or undertake the emergency work

- Co-operate with the appropriate authorities i.e. Police, Civil Defence
- Carry out emergency work immediately if such work is essential to ensure the health and safety of the community or to protect the environment
- Prioritise emergency work to reduce the risk to the community and environment to acceptable levels
- Advise the Engineer immediately of any situation where the emergency is likely to continue and affect the health and safety of the community and the environment

### **7.3.6 Havelock North Water Inquiry**

Following the widespread outbreak of gastroenteritis in Havelock North in August 2016, with more than 5,000 people falling ill, the Government launched an Inquiry into the Havelock North water supply contamination incident.

The Stage 1 of the Inquiry addressed the regulatory regimes, the facts concerning the campylobacter outbreak and the question of failures by various agencies to meet required standards.

Stage 2 will look at lessons to be learned, how to prevent outbreaks in the future and changes that would improve the safety of drinking water.

A background paper prepared for the WaterNZ by Dr. Steve Hurdey and tabled with the Havelock North Inquiry identifies the following:

Recurring Themes Evident from an Analysis of International Outbreak Experience

- Complacency
- Lessons that should have been learned and widely known are too often forgotten
- Groundwater is a common source in outbreaks if mistakenly trusted as secure
- Politicians and “responsible” officials are often sceptical about possible contamination
- There is a common myth about water being pristine which reduces vigilance
- Safety does not require stricter water quality numbers – better practice is needed
- Misplaced fear of chemicals has interfered with adequate management of pathogens
- Public health monitoring is generally unable to detect small outbreaks
- Miscommunication occurs among individuals who are relied on to ensure safety
- Even high-quality systems can fail
- Chance / luck is often a factor in avoiding or driving an incident
- Investigations into the causes of an outbreak will often find multiple causes
- Blaming failures on human error generally misrepresents the underlying problems
- Preventing failure requires learning from experience
- Risk-based approaches like Water Safety Plans cannot work if identification and understanding of risk is inadequate

and lists the evidence for guiding principles applicable to New Zealand

**Principle 1** - The greatest risks to consumers of drinking water are pathogenic microorganisms. Protection of water sources and treatment are of paramount importance and must never be compromised

**Principle 2** - The drinking water system must have, and continuously maintain, robust multiple barriers appropriate to the level of potential contamination facing the raw water supply.

**Principle 3** - Any sudden or extreme change in water quality, flow or environmental conditions (e.g. extreme rainfall or flooding) should arouse suspicion that drinking water might become contaminated.

**Principle 4** - System operators must be able to respond quickly and effectively to adverse monitoring signals.

**Principle 5** - System operators must maintain a personal sense of responsibility and dedication to providing consumers with safe water and should never ignore a consumer complaint about water quality.

**Principle 6** - Ensuring drinking water safety and quality requires the application of a considered risk management approach.

Council engineers note these recurring themes and guiding principles identified by the author (international environmental health science authority). It is expected that the impacts from the Inquiry will be significant and wide ranging including but not limited to the way the water service is delivered, managed, operated, maintained, monitored and reported on. Council will stay up to date with developments in this area to protect public health and safety.

### 7.3.7 Government Review of 3 Waters Services

During 2017 the Minister for Local Government initiated a review of 3 Waters services to assess whether current local government practices and the system oversight are ‘fit for purpose’. This acknowledge that effective 3 Waters services are essential for communities as:

- Health and safety - depends on safe drinking water, safe disposal of wastewater and effective stormwater drainage



- Prosperity - depends on adequate supply of cost effective 3 Waters services for housing, businesses and community services
- Environment - depends on well managed extraction of drinking water, and careful disposal of wastewater and stormwater

A series of events indicated there are system-wide performance challenges and supported the perception that service failure is the only indicator that service delivery is not in accordance with the expected outcomes.

On 8 July 2020 the Government announced a funding package of \$761m to provide immediate post COVID 19 stimuli to local authorities to maintain and improve 3 Waters infrastructure, support reform of local government water services delivery arrangements, and support the operation of the Water Quality Regulator.

During 2021 to 2023 the Government introduced a range of Water Services legislation which will have a significant impact on the 3 Waters services. This included legislation with a staggered approach to establishing the water services entities, and proposed all entities going live between 1 July 2024 and 1 July 2026.

However, during the 2023 Government election a new coalition government was formed which put immediate sop work orders to 3 Waters (with assets returned to council ownership).

In 2024 the new Government introduced the 'Local Water Done Well' legislation with two of the three Bills enacted at the time of the updating of this AMP. This legislative change requires Councils to consider the sustainability of their water services provision and consider service delivery mechanisms. Detail of this legislation is provided in Appendix E.

### **7.3.8 Insurance**

The Council has a variety of insurance policies including cover for the water network; property, plant and equipment; motor vehicles and moving plant. The insurance cover is updated on a regular basis to ensure the cover is appropriate. Land is not insured and there are no self-insurance funds currently maintained by council.

Insurance cover for the 3 Waters network is provided through a mix of material damage policies and through the Local Authority Protection Programme (LAPP).

- LAPP is a mutual pool created by local authorities to cater for the replacement of 'below ground' infrastructure following catastrophic damage by natural disaster. LAPP provides cover for 40% of relevant assets (with central government liable for the remaining 60%). Of the 78 local authorities in New Zealand, 22 are currently Fund members. Civic Financial Services is the Fund's administration manager.
- Material Damage and related policies provide for 'above ground' asset replacement cover.

Additionally, Council holds Public Liability and Professional Indemnity insurances.

### 7.3.9 Emergency Management

#### Background

Waimate district is subject to a wide range of natural hazards. Several significant natural events have been recorded which have caused damage to property and the environment with no one hazard being the “standard” event. The district has suffered five main events over the last 45 years:

- Snowstorms: in 1967, 1992 and 2006 blanketed a large part of the Waimate district cutting road access causing power outages and stock deaths.
- High Winds: in 1975 damaged trees blocking roads and bringing down power wires.
- Floods: in 1981, 1986 and more recently have badly eroded land adjacent rivers damaging bridges and roads. Water supplies with surface water intakes were blocked with sediment. Power cuts also disrupted supply of water to consumers.
- Rural fire: Cause disruption to power in Waimate and the surrounding rural margins.
- High Winds: in 2014 damaged trees blocking roads and bringing down power wires.

The Council has subsequently modified pump stations to enable operation using standby generators and / or permanently fixed on-site generation.

Council has three generators at its disposal, and contact details for hiring generators. The generators that belong to Council are the Civil Defence generator for the main Council building standby generation, and the other two are for and owned by the Otaio-Makikihi Rural Water Supply. These generators are mobile and can be moved around if not needed at those designated sites in and event. Recent high winds causing significant district wide power disruptions identified that more standby generators are required to ensure continuity of supply. This AMP allows for the installation of on-site generators at many sources and critical pump stations.

Critical pipeline crossings over bridges have been strengthened or alternative pipe routes have been provided.

*The impact of the Christchurch earthquake has served to further highlight the importance of adequate emergency planning.*

#### Civil Defence and Emergency Response Plans

The Civil Defence Emergency Management (CDEM) Act 2002 requires Local Authorities to coordinate Plans, Programmes and Activities related to CDEM across the areas of Risk Reduction, Readiness, Response and Recovery. It also encourages cooperation and joint action within regional groups. Management systems for civil defence emergencies are detailed in the Council’s CDEM plan.

A Lifelines Response Plan has been prepared for key Council utility services. The Lifelines Response Plan considers natural hazard events including earthquake, flooding, meteorological (snow/wind) and mass movement (land slip), and also takes account of fire and civil disruption events.

The principle objectives of the Lifelines Response Plan are to:

- Possess a management tool that identifies natural hazards for the individual utilities.
- Identify the consequences of the natural hazards.
- Identify immediate remedial actions.
- Define restoration levels, priorities and issues.
- Identify long term risk management issues.
- Ensure that Emergency Management knowledge is retained within Council.

The Lifelines Response Plan details the hazards, possible cascading effects and the interventions that may be applicable. It does not consider the effect on any individual community as these will change with the extent of the hazard i.e. the depth and extent of snow and the extent and makeup of that utility i.e. if the water scheme has a standby generator.

### **Disaster Resilience Summary Report**

In 2006 the Council commissioned the Disaster Resilience Summary Report. The DRS is designed to: -

- Create an understanding of the Utilities Lifeline services and operation.
- Provide a clear summary of facts to assist CDEM undertake their role.
- Provide each Utility with a simple method for providing the only information that is required by the CDEM Groups.
- Increase CDEM Group knowledge of each Utility's organisation and operations in order to significantly increase the efficiency of future CDEM/Utility contact

The hazards have been identified that might affect the networks were:

Snow, earthquake, floods (after most floods there is a re-think of how the planning and network is managed), river change/management, rain, wind (trees falling across roads), electricity failure, networks weakness, tsunami, telecommunications and Pandemic planning.

Items requiring further works in progress include:

- Hazardous substance spill
- Fire
- Dam failure
- Drought/climate change
- Fuel supply failure
- Tsunami

#### **7.3.10 Infrastructure Resilience**

Recent high profile natural disasters have raised public awareness, but there is still a significant need to increase actual preparedness – both in general (e.g. household plans and emergency supplies) and for specific circumstances (e.g. tsunami preparedness in coastal communities).

However, resilience is not only applicable to natural hazards, but also needs consideration at an operational level where an asset failure is not necessarily a service failure.

Redundancy (duplication) does not provide Resilience. Resilience requires early detection and recovery, but not necessarily through re-establishing the failed system. Resilience is about the ability to plan and prepare for adverse events, the ability to absorb the impact and recover quickly, and the ability as a community to adapt to a new environment.

Council acknowledge that resilience is not only about physical assets. It is about the people. It includes but are not limited to:

- connecting people and communities (neighbour to neighbour; educate; access to household resilience items, etc.);
- supporting community organisations
- the built environment and asset systems which are robust

Adverse events/natural disasters/climate change and the related impacts cannot be avoided and as a result Council have to factor this into long term planning, civil defence planning and determining the infrastructure requirements moving forward to ensure the community's expectations are met with regard to safe and reliable services and general wellbeing.

In order to improve resilience Council approach will be to:

- Actively participate in CDEM planning and activities, at both regional and local levels
- Investigate options for alternative service provision and system redundancy

- Promote design and construction standards (where cost effective) that ensure infrastructure is able to withstand natural hazards and long term changes in circumstances such as those resulting from climate change
- Identify critical assets and ensure mitigation methods are developed
- Obtain insurance where this is deemed to be the most cost effective approach
- Invest in business continuity succession planning and training

Council will take guidance from 100Resilient Cities website <http://www.100resilientcities.org/>. This includes the strategies of Greater Christchurch and Wellington.

### 7.3.11 Project AF8

Project AF8 is a cutting edge risk scenario-based earthquake response planning project, informed by thorough earthquake source, expression, and consequences science. The focus of the project is New Zealand's South Island Alpine Fault. Project AF8 commenced in July 2016, with funding from the Ministry of Civil Defence & Emergency Management's Resilience Fund, and is managed by Emergency Management Southland on behalf of all South Island CDEM Groups.

Project AF8 has been initiated to introduce outline planning for response actions, resources, and overall coordination within and between CDEM Groups across the South Island.

The South Island Alpine Fault Earthquake Response (SAFER) Framework provides a concept of coordination of response and priority setting across all six South Island Civil Defence Emergency Management (CDEM) Groups and their partner organisations in the first seven days of response. It is not intended to replace existing plans within agencies but to provide a coordinated picture of response across the South Island.



The SAFER framework includes:

- Scenarios
- Response assumptions
- Secondary and compounding risks such as:
  - Aftershocks
  - Ongoing structural failure
  - Cascading landscape effects
  - Tsunami
  - Severe weather
  - Communicable human diseases
  - Impacts on response operations
- Consolidated response framework

Council will keep a keen eye on the response actions and resources from the AF8 project and work with CDEM Groups.

### 7.3.12 Climate Change

It is now generally accepted worldwide that human activities have accelerated climate change, and that further future climate change is unavoidable. The effects of climate change include both effects on our climate (such as temperature increases or flooding), and a wide range of secondary

effects (such as damage to strategic infrastructure). The following details climate change projections for the Canterbury region.

In response to the challenges associated with climate change Council has developed a Climate Change Resilience Strategy, March 2024. Work to date in developing the resilience pathway have included:

- Appointing a part-time Climate Change Office to oversee the development of the strategy
- Consulting, informing and engaging with district communities, neighbouring councils and the Canterbury Climate Partnership Plan
- Completing the second council carbon footprint assessment in 2022/23

As Councils Climate Change Resilience Strategy and associated pathway continues to develop and mature this AMP will be updated as necessary with actions, responses and budgets required to meet the Strategy requirements.

The National Climate Change Risk Assessment (MfE August 2020) identifies 43 priority risks across five value domains (natural environment, human, economy, built environment and governance) and highlights 10 risks considered to be the most significant. This MfE report highlights, among others, the following two domains (particularly applicable to Council infrastructure) as extreme risks:

**Table 7-3: Climate Change Risk to Council**

Domain	Risk	Consequence
Economy	Risks to governments from economic costs associated with lost productivity, disaster relief expenditure and unfunded contingent liabilities due to extreme events and ongoing, gradual changes.	Extreme
Built environment	Risk to potable water supplies (availability and quality) due to changes in rainfall, temperature, drought, extreme weather events and ongoing sea-level rise.	Extreme
	Risks to buildings due to extreme weather events, drought, increased fire weather and ongoing sea-level rise.	

Waimate District is expected to experience two of the main impacts of climate change – sea level rise and more extreme weather patterns.

Sea level rise is considered the lesser of the influences as much of our coastline is elevated above MSL. Modelling of associated inundation, as a result of tsunami, is known to affect very few council-controlled assets.

What is understood is that climate change associated risks will increase in time.


*Waimate mayor Craig Rowley said climate change was a priority.*

*"As far as doing the work on something, we always take it into account looking at the of risk of climate change."*

*Rowley said it was a hectic time of the year with budgeting and planning, but climate change was something we certainly do recognise" (Timaru Herald 13/9/2017)*

Council recognised the roles of Local Government, NZ, the Ministry of Primary Industries, and the Ministry for the Environment and the Royal; Society of NZ in researching and guiding a pragmatic response.

Figure 7: Average changes in annual mean temperature (left, degrees Celsius) and precipitation (right, percent) during 2080–2099 compared to 1980–1999, for a climate change scenario midway between low- and high-carbon futures.



Source: Climate change: implications for New Zealand (Royal Society of New Zealand, April 2016)

*The local government position statement on climate change (2017) states*

*Climate change actions have three components:*

- 1. actions to reduce emissions (mitigation);*
- 2. planning and actions at the national and local level to support public safety and effective adaptation; and*
- 3. limiting or removing pressure on systems affected by climate change.*

*All local authorities (city, regional, district and unitary) are at the frontline of climate change adaptation and have a role to play in mitigation.*

The role of Council is key in delivering the outcomes sought by the community. Key drivers to support and manage the challenges are the National Climate Risk Assessment for New Zealand (Ministry for the Environment, 2020) and the Climate Change Projections for the Canterbury Region (NIWA, 2020).

### Projections for Canterbury

Climate Change Projections for the Canterbury Region have considered the following scenarios, which take into account either cutting greenhouse gas emissions over time from 2019 levels – or not curbing emissions during the life of this Infrastructure Strategy.

#### Average Temperatures

- Increase with time and greenhouse gas concentrations.
- By 2040, annual mean temperature up 0.5 to 1.5°C.
- By 2090, up 0.5 to 2°C (if we cut emissions) or up 1.5 to 3.5°C (if we don't).

**Maximum Daytime Temperatures**

- By 2040, annual mean maximum temperature up 0.5 to 2°C.
- By 2090, up 1 to 3°C (if we cut emissions) and up 2 to 5°C (if we don't).
- By 2090, western Canterbury's alpine and sub-alpine areas could be 5 to 6°C warmer in spring and summer (if we don't).

**Maximum Night-time Temperatures**

- By 2040, annual mean minimum temperature up zero to 1°C.
- By 2090, up 0.5 to 1.5°C (if we cut emissions) and up 1 to 2.5°C (if we don't).
- The difference between a day's high and low increases with time and greenhouse gas concentrations.

**Hot Days (25°C or more)**

- By 2090, expect 20 to 60 more hot days in most of Canterbury (if we don't cut emissions).
- Inland areas feel it the most, particularly the southern Mackenzie Basin, which could have 60 to 85 more hot days.
- Most of these hot days would happen in summer.
- Our warmer season could get longer in relatively low-elevation areas, with 5 to 10 more hot days in autumn and spring.
- Increased fire risks.

**Cold Days (Frosts)**

- Expect fewer frost days throughout the region.
- Inland areas and higher elevations warm the most, with 10 to 30 fewer annual frost days by 2040, and 20 to 50 fewer by 2090.
- The frost season (the time between a year's first and last frost) will likely get shorter.

**Rainfall**

There is likely to be increased rainfall depth and intensity associated with climate change. In addition, the heat that comes from the condensation of this increased moisture will make storms more intense. These extreme events may exacerbate flooding risks for Waimate District.

- Most of the region can expect small changes in annual rainfall, up or down 5%.
- By 2040, autumn might be dryer in the Mackenzie Basin, with up to 10% less rain.
- By 2090, winters could be wetter in many eastern, western and southern parts of the region, with 15 to 40% more rain.
- By 2090, Banks Peninsula and many inland areas might get 5 to 15% less rain (if we don't cut emissions).

**Snow**



- Expect fewer snow days everywhere, especially in the mountains.

### **Drought**

The modelling indicates that by the 2080s, there will be a significant increase in the average water deficit across Canterbury, with increases of between 2 weeks and over 6 weeks of pasture deficit as an average climate condition. By the 2030s, current drought events that are so severe that they only occur in 1 out of 20 years are projected to occur more frequently. Increased fire risks.

### **Windspeed**

- Annual mean wind speeds up slightly, by nil to 5%.
- By 2090, winter and spring could be windier (up 5 to 15%, if we don't cut emissions).
- That seasonal change might be more keenly felt in inland areas north and west of Rangiora (up 15 to 25%).
- Increased fire risks.

### **Sea Level Rise**

Climate Change Projections for the Canterbury Region have identified worsening impacts over time at a regional and national level:

- Sea level rise projections for Canterbury are the same as for New Zealand.
- Up by 0.4m in the next 50 years and up 0.6 to 0.7m in 100 years (if we cut emissions).
- Up 0.5m in 50 years and up 1.2 metres in 100 years (if we don't).
- High tides get higher. At 0.65 metres of sea level rise, every high tide is above the spring tide mark (compared to 10% now).



Source: [www.wetlandtrust.org.nz](http://www.wetlandtrust.org.nz)



Source: Stuff 24 July 2017

### **Climate Change Effects**

The major effects that may impact on the Council's Infrastructure activities are set out below, along with potential mitigation options and an analysis of when the effects may occur. It should be noted that further work is required to understand how these effects will impact the Waimate District, but the collection and monitoring of data will be used to inform a more robust climate change response.



**Dust from Unsealed Roads:** Hotter temperatures and associated drought conditions could have detrimental effects in terms of increased dust from unsealed roads. This may mean that in future areas of unsealed roads need to be sealed, particularly close to residential properties. Council currently allows for \$50k to part fund “dust seals” via policy. Road classifications and traffic volumes on our low use roads dictate the overall level of service. Individuals are able, with part funding by Council, to increase the level of service adjacent to their property to mitigate adverse effects associated with dust.

Council will continually monitor demand for this service and provide increased funding as required.

Hotter temperatures potentially have an impact on the timing of both grading and metalling activities which will need to be monitored over time.

In the shorter term this approach is considered appropriate but as the effects of drought conditions become more prevalent, Council may need to consider a revision of the level of service relating to unsealed rural roads which, in turn, will adversely affect funding requirements (increased).

- Likelihood - Possible (25 – 50%)
- Location - District Wide
- Timeframe - 2030 onwards
- Mitigation - Monitor

**Changes in Demand:** An overall decrease in the mean rainfall for the district could impact on land use and in turn change demand on certain areas of the Council’s infrastructure networks. More intense rainfall events have the ability to damage crops, and this may manifest in changing farming practices. These changes in farming practices could result in changing traffic volumes for particular areas, changes in demand from our water networks, and requirements for higher levels of service to mitigate the risks associated with nuisance flooding, to name the major impacts.

Council will need to monitor and understand these requirements to inform future work programmes. This is achieved through regular traffic counts, up-to-date hydraulic modelling of our water schemes and optimised renewal of drainage assets.

Council is mindful that changes in demand with manifest as changes to LoS, geographic demand and overall demand. In order to cater for this, underlying data is important to plan appropriate renewals in the future.

Council has installed water metering within the urban water network as a means to manage demand, manage water losses and to increase the availability of potable water.

- Likelihood - Likely (50 – 70%)
- Location - District Wide
- Timeframe - 2030 onwards
- Mitigation - Monitor

**Drainage Capacity:** Extreme rainfall events in a generally dry region may cause surface flooding affects due to poor capacity of drainage assets. The cost of upgrading drainage assets for these extreme events is likely to be prohibitive for Council. Whilst, as a district, council is unable to build infrastructure to deal with these extreme flows and volumes, it is able to define the levels of service (20% and 2% annual exceedance probability) and therefore the level of protection that ratepayers and users can expect.

Mitigation of events outside of these parameters are dealt with through the protection and definition of overland flow paths, defined areas for detention and improved stormwater management practices. These practices (in an urban sense) are defined in Waimate District Councils draft Stormwater Management Plan which is an underpinning document for the global consent that

is currently being sought through Environment Canterbury Regional Council. For example, Council defines on-site management of stormwater as the preferred solution up to a 1 in 50 year event. The defined 1 in 50 year design event takes into account climate change factors defined by NIWA.

Extreme rainfall events have a detrimental impact on council's wastewater network where inflow of stormwater presents several challenges in terms of conveyance capacity and surcharging of manholes. In 2021, council is undertaking an inflow investigation to identify which areas are affected and formulating appropriate responses to mitigate the effects. Left unchecked, climate change impacts would adversely affect this activity. When addressed, this will lead to increased levels of service, allow for future growth by increasing available capacity and reduced compliance risks.

- Likelihood - Almost certain (70 – 99%)
- Location - District Wide
- Timeframe - 2021 onwards
- Mitigation - Design, planning, and policy

**Increased Flood Damage Repair Work:** Extreme rainfall events in a generally dry region may cause surface flooding affects and in turn increase requirements for flood damage repair works. Consideration will need to be given to design and location aspects for Council's assets to reduce the risk of damage or loss of service due to extreme weather events. There is no provision (currently) to fund these repairs, and they are typically funded via existing budgets and often with co-funding from Waka Kotahi.

Council is continually monitoring the financial effects associated with flood events (and the diversion of existing budgets) and has considered (in the past) developing a "flood event" fund. This monitoring will continue with intervention likely if existing programmed work begins to be adversely affected. Potentially this issue will need to be consulted on as increased costs will result in increased rate requirement. Resultantly the community will receive a higher level of service than currently experienced.

Furthermore, storm events can impact on raw water quality from streams and bores used for water supply. This presents challenges associated with the provision of potable water in terms of reliability, treatability and therefore compliance with the Drinking Water Standards for New Zealand

- Likelihood - Almost certain (70 – 99%)
- Location - District Wide
- Timeframe - 2021 onwards
- Mitigation - Monitor and adapt funding if required

**Water availability for Construction:** Increasing demand for water is currently an important issue for Canterbury. This increased demand is likely to become increasingly critical in a future characterised by drier average conditions, and an associated increase in both drought frequency and intensity. This may mean, as an example, that it will be more difficult to obtain the required water to complete construction works.

Updating of hydraulic models for the council water supplies allows for optimised future renewals that address the location of demand within the schemes (up or down). They also allow Council to plan for growth and increased demand as a result of changes to legislation e.g. the Water Services Bill and its potential impact on water suppliers outside of the current reform programme.

- Likelihood - Almost certain (70 – 99%)
- Location - District Wide

- Timeframe - 2025 onwards
- Mitigation - Monitor and adapt future programmes as required (LoS, additional demand, changing demand)

## 7.4 Managing Water Safety Risks

### 7.4.1 The Water Services Regulator (Taumata Arowai)

The Water Services Regulator Act 2020 established a new regulatory body, Taumata Arowai, to oversee, administer and enforce a new and strengthened drinking water regulatory system. Taumata Arowai also have a national oversight role to improve the environmental performance of stormwater and wastewater networks.

The role and operating regulations of the water services regulator are under review by the government at the time of the writing of this AMP. Council will continue to monitor changes and interact with Taumata Arowai in accordance with these requirements.

Taumata Arowai's role is to:

- Oversee and administer an expanded and strengthened drinking-water regulatory system, to ensure all New Zealand communities have access to safe drinking water. That includes holding suppliers to account, if need be.
- Oversee from a national perspective the environmental performance of drinking-water, wastewater and stormwater networks. (Regional councils will remain the primary regulators of wastewater and stormwater).

Following public consultation Taumata Arowai released, new Drinking Water Standards, Drinking Water Quality Assurance Rules, and Aesthetic Values which came into effect on 14 November 2022.

#### Drinking Water Standards

The Water Services (Drinking Water Standards for New Zealand) Regulations 2022 set the Maximum Acceptable Values (MAVs) for a range of contaminants which can affect the safety and quality of drinking water. They are based on guideline values set by the World Health Organisation (WHO). The standards apply to all supplies, regardless of the nature of the source water in use, and number of people served by the supply. All consumers on a supply should receive water that meets these standards and therefore the standards must be met at all points in a distribution system.

MAVs are provided for microbiological determinants, inorganic determinants, organic determinants, cyanotoxin determinants, radiological determinants, and acceptable ranges for determinants that may affect the aesthetic properties of drinking water.

#### Drinking Water Quality Assurance Rules

The Rules set out minimum compliance requirements and cover water quality operational requirements from source water abstraction to the point of supply to a consumer

The Rules identify the following components of a water supply:

- source water abstraction
- water treatment plant
- distribution system.

The Rules have been prepared for the following drinking water supply categories:

1. **Very Small Communities** – up to 25 people (excluding domestic self-supplies)

2. **Networked Supplies** - Drinking water supplies that provide drinking water via a distribution system at a pressure and volume to meet consumer demand, or at a restricted flow and volume. These supplies may include storage facilities within the network to buffer demand. The Rules have been prepared for Networked Supplies with the following population sizes:
  - a. **Small** 26 – 100 people. Varying Population module requirements can apply to this drinking water supply category.
  - b. **Medium** 101 – 500 people. Varying Population module requirements can apply to this drinking water supply category.
  - c. **Large** >500 people.
3. **Self-supplied Buildings** - are water supplies (excluding domestic self-supplies) which provide drinking water to up to ten buildings on one site (within the boundaries of one property, or within the boundaries of two or more properties with common ownership arrangements) and provide water to more than 25 people
4. **Water Carrier Services** - that involve the transport of drinking water in a vehicle or vessel with a water tank (e.g., a truck, trailer, or rail wagon) and supply to consumers or other drinking water suppliers, often to a storage tank on a property
5. **Water Carrier Supplies** - are drinking water supplies that provide water specifically to fill tanker vehicles that are owned or operated by a Water Carrier Service
6. **Community Drinking Water Stations** - are drinking water supplies that provide drinking water from a single point of supply to a community who collect the water in containers. Public taps or container filling stations that are connected to a Networked Supply (e.g., community taps that provide water which is chlorinated and then de-chlorinated) are not considered to be Community Drinking Water Stations.
7. **Temporary Drinking Water Supplies** - Planned short-term events where people gather and where a Temporary Drinking Water Supply is registered under section 33 of the Act for the duration of an event, which continues for a limited time. Typically, this category includes temporary drinking water supplies for events like music festivals, farm field days, civil defence operations, or military exercises

At the time of reviewing this Asset Management Plan (September 2024), Taumata Arowai have commenced a review and consultation on the DWQAR's. The purpose is to reduce compliance burden wherever appropriate.

For Waimate this translates to:

**Figure 7-2: DWQAR Water Supply Categorisation**

Scheme	Population served	DWQA Rules Categories
Waimate Urban	3416	Large
Cannington Motukaika	90	Small
Hook Waituna	962	Large
Lower Waihao	700	Large
Otaio Makikihi	422	Medium
Waihaorunga	99	Small
Waikakahi	344	Medium
Large = 3 Supplies		
Medium =	2	Supplies
Small = 2 Supplies		

The Rules include modules that drinking water suppliers must demonstrate compliance against.

Figure 7-3: DWQAR Applicable Rules

Scheme	WS Category	Rule Module
Waimate Urban	Large	G + S3 + T3 + D3
Hook Waituna		
Lower Waihao		
Otaio Makikihi	Medium	G + S2 + T2 + D2
Waikakahi		
Cannington Motukaika	Small	G + S1 + T1 + D1
Waihaorunga		

Apart from the treatment requirements to meet the drinking water standards there are also further requirements including but not limited to:

- General rules
  - Source water rules
  - Treatment rules
  - Distribution rules
- Backflow prevention programme
  - High and medium risk assessment at least every 5 years
  - Inadequate BFP resolved within 3 months
  - Annual testing of devices
  - No access to water network unless fire and emergency, water supplier or authorised contractor – for water supply activities only
  - *What is our status?*
- Hygiene procedures
  - requires risk assessment prior to work and to **keep record of risk assessment and procedures**
  - Tools to be disinfected
  - Disinfection of mains to follow best management practices
  - Develop and document standard operating procedures for planned, unplanned and emergency repairs
  - *What is our status?*
- Storage facilities
  - requires Water Storage Management Plan (min. & max. operating levels, target turnover rates, inspection & cleaning)
  - Annual security and contamination inspection assessment
  - Written disinfection procedures
  - Drained storage facilities must be cleaned and disinfected
  - Following full/partial draining to test for E. coli, total coliforms and disinfectant residual
  - *What is our status?*
- Disinfectant residual
  - written sampling plan showing locations, response procedures, etc.
  - sampling based on zone population
  - byproduct sampling
  - *What is our status?*
- Microbiological monitoring
  - written sampling plan for monitoring total coliforms, E. coli and any other determinants including a system map showing sampling locations.

- Sampling locations to be representative of distribution system and include storage facilities and entry points from another water supplier
- sampling based on zone population
- *What is our status?*

The Rules will have a significant impact on the way the drinking water supplies are managed, operated and maintained including monitored and reported on. This will result in a significant impact on capital and operational costs.

### **Drinking Water Aesthetic Values**

The Aesthetic Values for drinking water came into effect on 14 November 2022 and specify or provide minimum or maximum values for substances and other characteristics that relate to the acceptability of drinking water to consumers (such as appearance, taste, or odour).

A drinking water supplier must take all reasonably practicable steps to supply drinking water that complies with aesthetic values issued by Taumata Arowai under the Water Services Act 2021.

### **Acceptable Solutions**

The Acceptable Solutions provide drinking water suppliers with a ready-made option to meet their compliance obligations under the Water Services Act 2021. They apply to particular supply types and situations and must be implemented in their entirety.

The supply types include:

- Roof water
- Spring and Bore Water Supplies
  - No more than 500 people and other criteria
- Mixed use rural Water Supplies
  - Not less than 50% of water supplied is intended for agricultural or horticultural purposes, for example stock water and irrigation, and not more than 50% is used for domestic purposes, including drinking water

### **Fluoridation**

The Health (Fluoridation of Drinking Water) Amendment Act 2021 was enacted on 28 November 2021.

During July 2022 the Director-general of health ordered 14 local authorities to begin fluoridating their water supplies. In November 2022, a further 27 local authorities (including Waimate District Council) were advised the Director-General of Health is now considering whether to issue a direction to fluoridate in relation to one or more of their drinking-water supplies. For Waimate DC this included Waimate Urban WS and HookWaituna WS.

In accordance with section 116I of the Act, Council may be required to fluoridate these two water supplies to specified levels of fluoride. Council may opt to also provide a single source of water within each water supply that is not fluoridated for residents to collect water from.

The capital cost of introducing fluoridation will be significant plus there will be ongoing management and monitoring costs.

Local authorities who are directed to fluoridate their water supplies will be invited to apply for funding from a \$11.3 million fund for capital projects associated with these works.

There are three fluoride chemicals used for the fluoridation of drinking-water in New Zealand:

- Fluorosilicic acid (FSA aka Hydrofluorosilicic acid (HFA), hexafluorosilicic acid)
- Sodium fluoride (aka Sodium monofluoride)
- Sodium fluorosilicate (SFS aka Sodium silicofluoride, sodium hexafluorosilicate)

Sodium fluoride and SFS are supplied as powders that are dissolved in water to make a solution that is then added to the water supply, whereas FSA is supplied as a liquid.

Powder dosing systems relied heavily on operator procedures and safe handling practices to minimise the risk of human contact with the raw chemicals while making up bulk solutions from powder. With the liquid dosing systems however, process design was able to be used to minimise the risk of contact between operators and the raw chemicals.

The three chemicals available for fluoridation have advantages and disadvantages. A number of factors needs to be considered when selecting the chemical and method:

- Health and Safety of operational and maintenance staff
- Supply cost
- Availability and security
- Plant capacity
- Capital cost of
  - fluoridation system
  - chemical reception facility
  - building
- Operational and maintenance costs

The nature of the health & safety risks for the liquid and powder systems are different. The systems present different challenges for effective mitigation of those risks.

The Water NZ Code of Practice - Fluoridation of Drinking-Water Supplies in New Zealand (December 2014) provides a guideline to safety in design, operation and maintenance, documentation as well as reporting and auditing.

On 15 December 2021 the Ministry of Health sent out a questionnaire on Community Water Fluoridation to inform decision making on directing the council to fluoridate three of its seven water supplies. The three supplies were Waimate urban, Hook Waituna and Lower Waihao Rural water supplies.

Council responded with the requested data, the proposed fluoride dosing process, costs, Depravation Index, and highlighting water usage and percentage for domestic use and human consumption in the Lower Waihao and Hook Waituna water supplies.

The Director-General of Health wrote back to the Waimate District Council on 3 November 2022 to let council know the Ministry of Health was actively considering whether to direct the Council to fluoridate the Waimate urban and Hook/Waituna Rural water supplies, under section 116E of the Health Act 1956. The Lower Waihao water supply was removed from the list as it predominantly supplied water for agricultural purposes (85%).

Council responded on 27 January 2023 acknowledging the requirement that the Waimate urban supply will require fluoridation but requested an invitation to apply for funding. For Hook Waituna

rural water supply, council deferred response on fluoridation to a later date, as the alternate source is being sourced (ground water at Tavistock Bore) as part of the drinking water compliance upgrade.

If enough water is available in the Otaio Makikihi rural supply at Tavistock. The Hook Waituna northern area will amalgamate with Otaio Makikihi rural water supply, and the southern section of Hook Waituna will amalgamate with the Waimate Urban supply. The new modified Otaio and Hook rural water scheme will be reassessed for fluoridation once a new source and yield is confirmed.

Then, on 2 September 2023 the Director-General of Health advised council that these supplies remain under active consideration but will take further time. This is to allow consideration of the impact of several wider factors including the Government’s Water Services Reform programme, capacity pressures across the water services sector, and the impact of recent weather events in the North Island.

When council or the water supplier is directed to fluoridate, the preferred form of dosing process is a Sodium Fluoride 5 kg jar system (vacuum). This system is easier to manage, and the Health and Safety risks are lower for staff working on the dosing system.

**Table 7-4: Waimate District Council Water Supplies Under Consideration for Fluoridation**

Local Authority	Reticulated drinking water supply name	Water supply pop	Estimated capital works cost to fluoridate	Estimated ongoing mgmt. & monitoring costs
Waimate District Council	Waimate	3416	\$530,000	TBC
	Hook Waituna Rural	962	\$330,000	TBC
	<i>Proposed Otaio Hook Rural</i>	<i>1022</i>		

## 7.4.2 Water Safety Plans

### Legislation

In accordance with Section 30 of the Water Services Act drinking water suppliers are required to prepare and implement a Water Safety Plan (WSP)<sup>5</sup> for any water supply, except water supplies operating under ‘acceptable solutions’. Council has submitted water safety plans for all of their water supplies in November 2022 as required by Taumata Arowai.

However, the water safety plans submitted will need reviewing soon practicable, as they were either hastily put together in the new format, or require updating to reflect the changes (legislative & operational), as well as upgrades that have been done since November 2022.

Once reviewed and updated the Waimate District Council will have a programme to progressively renew and update WSPs for each water supply in conjunction with future treatment plant renewals, upgrades and operational changes.

### WSP Improvement Programme

The following Water Safety Plan improvements are programmed for development/renewal:

<sup>5</sup> Previously known as Public Health Risk Management Plans (PHRMPs)



**Table 7-5: WSP Improvement Programme**

Scheme	WSP	Timing
Waimate Urban*	Renew	2024/25
Cannington Motukaika	Renew	2025/26
Hook Waituna*	Renew	2025/26
Lower Waihao	Renew	2025/26
Otaio Makikihi*	Renew	2025/26
Waihaorunga	Renew	2025/26
Waikakahi	Renew	2025/26

*\*If a new source and enough yield can be found at Tavistock, Hook Waituna will split into north and south, to amalgamate with Otaio Makikihi or Waimate Urban. Therefore, WSP's will have to be rewritten for Waimate and Otaio Makikihi (Otaio Hook), and Hook Waituna supply decommissioned.*

Also see New Zealand Drinking Water Compliance Upgrades section below for further information on compliance related upgrade works.

Section 31 of the Water Services Act details the requirements of a WSP. The WSP focus is moving from a compliance document to risk identification and continued management, control, or elimination of identified risks, including a source water risk management plan. The Water Services Act has also introduced new requirements e.g. all reticulated drinking water supplies must, unless an exemption has been granted, require and provide for the use of residual disinfection.

The WSP needs to comply with Section 31 and any requirements set out in compliance rules and continually be reviewed. Section 56 requires annual renewal of the DWS registration. This includes confirmation that the WSP is still current and, if not, lodging a new or amended WSP. Historically a WSP had to be reviewed every 5 years, but a WSP is now a living document and needs continual revision and updating.

Taumata Arowai released Drinking Water Quality Assurance Rules (the Rules) which set out the requirements that drinking water suppliers must meet as part of their responsibility to demonstrate that they are supplying safe drinking water. Refer to Section 0 Drinking Water Quality Assurance Rules.

The WSPs identified a number of issues that require resolution and these are detailed in the next section below.

### **WSP Review and Reporting**

Reviewing and reporting on the WSPs will include the following:

- Review of the performance of the WSPs and adjustments to the WSPs will be undertaken annually.
- Report on the performance of the WSPs, including information of the review of the WSPs will be included in Council's Annual Plan Report each year.

### **New Zealand Drinking Water Compliance Upgrades**

The costs associated with the compliance with the Water Services Act, the DWQAR and DWSNZ are detailed below.

**Table 7-6: DWSNZ Compliance Upgrades**

Risk Level	Water Supply Area	Details of Proposed Works	Expected Cost	Intended date of Completion
<b>Cannington-Motukaika</b>				
Extreme	Source, Treatment	Upgrade Cannington-Motukaika Plant to comply with DWSNZ 2005 (revised 2018) <ul style="list-style-type: none"> <li>• Maintain the existing source site's weir and roughing filter.</li> <li>• Upgrade treatment plant site to Log 4 treatment.                             <ul style="list-style-type: none"> <li>○ Selective abstraction based on turbidity.</li> <li>○ Pre-treatment with an invalidated membrane</li> <li>○ 1µm Filter.</li> <li>○ UV reactor</li> <li>○ Disinfection – Sodium hypochlorite</li> <li>○ Increase post treatment storage</li> <li>○ Install telemetry for data acquisition and control (SCADA)</li> </ul> </li> </ul>	\$1,200,000	2025/26
<b>Hook-Waituna</b>				
Extreme	Treatment	Stage 2 Upgrade - Add a pre-treatments separation process to the new Hook Waituna Treatment Plant to aid the removal of the submicron particulate from the source raw water to achieve log 4 treatment compliance. <ul style="list-style-type: none"> <li>○ Pre-settling balance tank.</li> <li>○ Course self-cleaning screen (50 -100 micron)</li> </ul> Pre-treatment with an un-validated membrane SUBJECT TO CHANGE BASED ON SUCCESS OF SECOND BORE AT OTAIO	\$1,429,100	2024/25-2025/26
<b>Waihaorunga</b>				
Extreme	Treatment	Upgrade Waihaorunga Main and Tavendales Plants to comply with the Water Services Act, DWQAR and DWSNZ <ul style="list-style-type: none"> <li>• Upgrade Waihaorunga Main Treatment Plant site to Log 4 treatment.                             <ul style="list-style-type: none"> <li>○ Selective abstraction based on turbidity.</li> <li>○ Pre-treatment with an invalidated membrane</li> <li>○ 1µm Filter.</li> <li>○ UV reactor</li> <li>○ Disinfection – Sodium hypochlorite</li> <li>○ Install telemetry for data acquisition and control (SCADA)</li> </ul> </li> <li>• Connect Tavendale Intake Gallery to new Waihaorunga Main Treatment Plant, then boost treated water back to Tavendale booster.</li> </ul>	\$1,200,000	2025/26

Risk Level	Water Supply Area	Details of Proposed Works	Expected Cost	Intended date of Completion
<b>Waikakahi</b>				
Extreme	Source, Treatment, Distribution	<p>Upgrade Waikakahi Intake and Plant to comply with the Water Services Act, DWQAR and DWSNZ</p> <ul style="list-style-type: none"> <li>• Find a new raw water source – <i>A more suitable source with less influence from surrounding environment and contaminates</i> : <ul style="list-style-type: none"> <li>○ Shallow bore or gallery/bank-filtration close to the Waitaki River or irrigation scheme intakes.</li> <li>○ <b>Or</b>, Source raw water from irrigation scheme direct (Waitaki River water)</li> </ul> </li> <li>• Upgrade treatment plant at new site to Log 4 treatment. <ul style="list-style-type: none"> <li>○ Add selective abstraction based on turbidity.</li> <li>○ Pre-treatment with an invalidated membrane</li> <li>○ 1µm Filter.</li> <li>○ UV reactor</li> <li>○ Disinfection – Chlorine gas</li> <li>○ Continue using telemetry for data acquisition and control (SCADA)</li> </ul> </li> <li>• New rising main to Waikakahi reservoir</li> </ul> <p>STAFF ARE ACTIVELY TESTING ANOTHER SOURCE WHICH MAY PIVOT TREATMENT OPTIONS FOR THIS SUPPLY</p>	\$2,900,000	2025/26

## 7.5 Significant Negative Effects

**Error! Reference source not found.** below identifies the negative effects for the Waimate Community that the Water Activity may have on the social, economic, environmental or cultural well-being of the community. It indicates how the existing approach or proposed action to address these in the future. There are no significant negative effects shown to occur for the Water Service.

**Table 7-7: Negative Effects – Water Activity**

Effect	Status of Effect		Impact on Well-Being (existing situation)				Existing Approach or Proposed Action to Address
	Existing	Potential	Social	Economic	Environmental	Cultural	
<b>Water Treatment Plants</b>							
Discharge of treated backwash water to rivers	↔	↑	Minor	Mod	Mod	Minor	Maintain current consents for all WTP discharges Upgrade treatment plants to ensure ongoing compliance with resource consents
Disposal of Backwash solids to land	↔	↑	Minor	Minor	Mod	Minor	Solids dried then disposed of to landfill
Discharge of odour	↔	↓	Nil	Nil	Nil	Nil	High degree of odour control
<b>Pump Stations</b>							
Noise	↔	↔	Minor	Nil	Minor	Nil	All pumps reside in buildings with appropriate sound proofing
<b>Reticulation</b>							
Overflows	↔	↔	Mod	Minor	Minor	Minor	Result from mains breaks, these are infrequent and provided renewal programme is maintained effects will be minor other than disruption to consumers
<b>Reservoirs</b>							
Overflows	↔	↔	minor	minor	Mod	minor	Overfilling can result in discharge of treated water to the stormwater system. Shut off valves, pressure sensors and alarm systems are in place to prevent this
<b>Water Takes</b>							
Competition	↔	↑	Mod	Mod	Mod	Mod	The allocation of water is becoming an issue with competing needs for a finite resource Council is controlled through its resource consents but are developing Water Management Plan
Increased Demand	↔	↑	Mod	Mod	Mod	Mod	With planned growth so will the requirement for additional water. The combination of water reduction strategies, securing future water sources and monitoring demand will mitigate effects. This has the potential to become a significant negative effect if significant growth occurs

↑ Increasing ↔ Remaining the same ↓ Decreasing

## 7.6 Capital Programme Delivery Risks

Council has an ambitious capital programme driven by a number of factors:

- Continuation (and acceleration) of the active renewal programmes;
- Capital works needed to meet the requirements of the Water Services Act and associated secondary legislation / rules; and
- Capital works associated with compliance through the Water Services Act.

Particular pressure is exerted over the first three years of the 2025-34 Long Term Plan (Figures 8.1 – 8.4). In order to mitigate risks associated with ongoing programme delivery, Council has implemented a number of tactical responses:

- i. A Project Manager has been engaged to assist with timely delivery of proposed LTP projects through procurement assistance.
- ii. All capital works have been programmed for 2024/25 and 2025/26 and local (and national) contractors have been made aware of the timing. Where possible the programme has been modified to ensure successful and cost-effective procurement can be realised.
- iii. Council is aware that, that material supply are constrained due to demand pressure. Resultantly, Council is continues to address this issue by sourcing materials early and maintaining stock levels that can be drawn down on when projects commence. Sourcing materials early has also mitigated, to some extent, elevated pricing as raw materials become more scarce.
- iv. Procurement is now completed through the Government Electronic Tenders System (GETS) via Cotiss. This affords the ability to notify the wider contracting / consulting market of upcoming projects and will undoubtedly maximise submissions received once projects are tendered.

The Waimate district is fortunate to have significant contracting resource located within the district and at varying scale. In fact, one of the largest contractors in the South Island has its head office located within the Waimate town. Further afield, council is able to draw on further resource located to the North in Timaru and to the South in Oamaru.

As with any capital programme risks will always remain, even if mitigation has been employed. Known risks include:

- Dependent projects – Some proposed capital works are dependent on either technical investigations or other capital works. Delays in the latter could impact deliverability.
- Material Sourcing – Whilst proactive in sourcing materials, the risk associated with slow supply chains remain. There is also a risk associated with elevated pricing that could modify the scope of some projects.
- Compliance risks – A number of water supply compliance projects have been budgeted to meet compliance requirements as defined in the current DWSNZ. We note that Taumata Arowai is consulting on changes during the latter part of 2024 and early 2025. These changes could potentially have a significant impact on budgeted capital projects.
- Delay in increased levels of service associated with the upgrade of individual water schemes for compliance with the DWSNZ. Whilst it is unlikely that the level of service will reduce, the current LoS will be extended until upgrades are commissioned.

## 8.0 LIFECYCLE MANAGEMENT PLAN

This section applies the specific work programmes required to achieve the goals and standards outlined in Section 3 to Section 6. It presents the lifecycle management plan for the Water Services assets, and includes:

- Detailed management, operations, maintenance, renewal and development strategies
- Work programmes and associated financial forecasts

### 8.1 Asset Lifecycle

Assets have a lifecycle as they move through from the initial concept to the final disposal. Depending on the type of asset, its lifecycle may vary from 10 years to over 100 years. Key stages in the asset lifecycle are outlined in the diagram below:

Figure 8-1: The Asset Lifecycle




- Asset planning - when the new asset is designed. Decisions made at this time influence the cost of operating and maintaining the asset, and the lifespan of the asset. Alternative, non-asset solutions, should also be considered at this time.
- Asset creation or acquisition - when the asset is purchased, constructed or vested in Council. Capital cost, design and construction standards, commissioning the asset, and guarantees by suppliers influence the cost of operating the asset and the lifespan of the asset.
- Asset operations and maintenance - when the asset is operated and maintained. Operation relates to a number of elements including efficiency, power costs and throughput. This is usually more applicable to mechanical plant rather than static assets such as pipes. Maintenance relates to preventative maintenance where minor work is carried out to prevent more expensive work in the future, and reactive maintenance where a failure is fixed.

- Asset condition and performance monitoring - when the asset is examined and checked to establish the remaining life of the asset, what corrective action is required including maintenance, rehabilitation or renewal and within what timescale.
- Asset rehabilitation and renewal - when the asset is restored or replaced to ensure that the required Level of Service can be delivered.
- Asset disposal and rearrangement - When a failed or redundant asset is sold off, put to another use, or abandoned.

## 8.2 Lifecycle Management - An Overview

The Lifecycle Management Programmes cover the four key categories of work necessary to achieve the required outcomes from the Water Services activity. These programmes are:

**Figure 8-2: Lifecycle Management Programmes**



The Operations and Maintenance and Renewal Programmes are focused on maintaining the current service potential of assets, and are primarily driven by the condition of assets although asset performance is often an indicator of asset condition.

## 8.3 Management Programme

### 8.3.1 Introduction

Management and monitoring strategies set out the activities required to support the maintenance, operations cyclic renewal and asset development programmes. These activities include:

- Strategic Planning
- Data Management and Evaluation
- Business Processes
- Monitoring
- Financial Management

Strategic planning and a focus on meeting the needs of water scheme consumers drives the design of management processes which in turn are reflected in the level of performance that is achieved. Collection of data necessary to manage the water schemes effectively and processes for the analysis and interpretation of this data support all management activities.

### 8.3.2 Management Strategies

Table 8-1 sets out the management strategies.

**Table 8-1: Management Strategies**

Strategy	Objective/ Description
<b>Strategic Planning</b>	
Human Resources	Developing the professional skills of the staff through adequate training and experience Personal Development Plans will be agreed with staff each year and a register maintained to record training history. Staff are encouraged to belong to appropriate professional bodies and to attend appropriate conferences, seminars and training courses.
Strategic Alignment	This AMP will support the achievement of relevant Community Outcomes for Waimate District. Community Outcomes for Waimate District are set out in the LTP. The intended contribution of the Council water schemes to the achievement of Community Outcomes is clearly set out in this AMP.
Service Levels	Clear statement of Water Services provided and standards to be achieved as a basis for future consultation with the Community. In the first instance customer service standards have been developed as part of a wider performance management framework for the Water Services activity. This performance management framework incorporates: <ul style="list-style-type: none"> <li>– Customer Service Standards – Standards for the Water Services from the end users perspective.</li> <li>– Activity Service Standards – Key high level standards which reflect the Waimate District Community Outcomes and which enable the overall performance of the Water Services activity to be monitored.</li> <li>– Technical Standards – More detailed standards that can be used by Waimate District Council to monitor the performance of aspects the Water Services activity on an “as required” basis.</li> </ul>
Sustainable Management	Ensure all planning for the management, operation, maintenance, renewal and development of the water schemes is compatible with sustainable management principles. Council will pursue ways of limiting the use of natural resources including energy, valued landscapes (and other natural heritage) and adverse effects on waterways. This will involve auditing the systems and materials used, and developing ways to incorporate sustainable operation and development principles into its activities. For example, auditing power usage in pump stations, and using non-asset based solutions where possible.
<b>Data Management and Evaluation</b>	
Asset Management Systems	Optimise the application of Asset Management Systems over the short to medium term and develop functionality in line with business needs. Staff changes resulted in the neglect of this area. There is a significant portion of data held in the asset register in relation to private assets. Refinement of asset data requirements will occur as staff identify management applications for data and refine reporting capacity. WDC will review the adequacy of the systems for future asset management purposes and proactively introduce enhanced system functionality as justified by business needs to support a high standard of decision-making.
Network Modelling	Hydraulic network models exist. These models are operated by external consultants and are based in the InfoWorks modelling software. Computer models of the water scheme pipe network and utilities enables Council to: <ul style="list-style-type: none"> <li>– Determine accurately the existing capacity of the system.</li> <li>– Identify inadequate sections of the system.</li> </ul>



Strategy	Objective/ Description
	<ul style="list-style-type: none"> <li>- Operate the system in the most efficient manner.</li> <li>- Determine the impact of further development on the system.</li> <li>- Identify system upgrading requirements.</li> <li>- Compare options for upgrading the water schemes.</li> </ul>
Data Collection	<p>Data collection programmes (condition, performance, asset registers) closely aligned with business needs will be implemented in accordance with documented quality processes</p> <p>Data collection, maintenance and analysis is expensive and it is important that programmes and techniques are cost effective and consistent with business needs. Systematic processes will be further developed for the collection and upgrading of essential/critical data including:</p> <ul style="list-style-type: none"> <li>- Asset attribute information</li> <li>- Asset performance data</li> <li>- Asset condition data</li> </ul> <p>Staff changes have impacted on the Univerus Assets/GIS data acquisition, capturing, trending and analysis. This will increase as new assets are acquired through water treatment plant upgrades and will require improvement and refinement.</p> <p>Going forward Council will align its data collection and recording with the Metadata Standards</p>
GIS Data Quality Assurance	<p>GIS data will be the subject of defined quality assurance processes.</p> <p>Council will introduce quality processes intended to: ensure that all future data entered to the GIS system meets defined quality standards.</p>
Business Processes	
AMP Updates	<p><b>This AMP remains a strategic 'living' document and will be updated annually and reviewed at three yearly intervals or more frequently as necessary to incorporate significant improvements to asset management practices (as proposed in the improvement plan). The scope of the review will be influenced by changes in Community Outcomes for Waimate District, service standards, improved knowledge of assets, introduction of Asset Management improvements and corporate strategy/ policy and process.</b></p>
Risk Management	<p>Risk Management is an essential part of Asset Management. Water Services activity risks will be managed by developing a Risk Management Plan for the Water Services activity and the implementation of risk mitigation measures to maintain risk exposure at acceptable levels.</p> <p>Risk mitigation measures will include maintaining appropriate insurance cover, emergency response planning, condition monitoring of critical assets, preventative maintenance, use of telemetry, review and updating of WSPs and operations manuals, review of standards and physical works programmes.</p>
Infrastructure asset valuation	<p>Continue to perform valuations in a manner that is consistent with national guidelines and Council corporate policy.</p> <p>Asset valuations are the basis for several key asset management processes including asset renewal modelling and financial risk assessments. Valuations of the water schemes will be carried out based on data from the GIS and AMS systems to ensure auditability and alignment with other processes.</p>
Statutory Compliance	<p>Implement quality plans that identify legal obligations and processes adopted to achieve statutory compliance.</p> <p>Section 4.3 of this AMP sets out the legislative environment for the Water Services activity.</p>
Quality Assurance	<p>Document, review and implement quality processes for all key business activities in accordance with standard practices.</p> <p>Quality processes will cover activities such as reporting, data collection and management, contract monitoring, risk management, economic analysis, performance monitoring, strategic planning, customer contact, asset valuation, asset operation, work specification, etc.</p>
Monitoring	
Asset Performance	<p>Council will continue to monitor the performance of the water schemes assets as an input to asset renewal and asset development programmes. This monitoring includes:</p> <ul style="list-style-type: none"> <li>- Customer service requests</li> <li>- Asset failure records</li> <li>- Asset Maintenance records</li> <li>- Compliance with Resource Consents</li> </ul>

Strategy	Objective/ Description
	<ul style="list-style-type: none"> <li>- Water Treatment Plant effluent quality</li> <li>- Critical asset audits</li> </ul>
<b>Financial Management</b>	
Budgeting	<p>Prepare all expenditure programmes for the Water Services activity in accordance with Council funding and budget preparation policies and procedures.</p> <p>The different categories of expenditure within the financial programmes will be identified to enable the funding to be allocated in accordance with the Council’s policies.</p>
Financial management	<p>Manage the Water Services activity budget in accordance with statutes and corporate policy. This will involve:</p> <ul style="list-style-type: none"> <li>- Economic appraisal of all capital expenditure</li> <li>- Annual review of AMP financial programmes</li> <li>- Recording of significant deferred maintenance and asset renewals</li> <li>- Continuous monitoring of expenditure against budget</li> </ul>
Sustainable Funding	<p>Ensure the water schemes are managed in a financially sustainable manner over the long term. The financial requirements for the provision of the Water Services sustainably and to acceptable standards over the long term will be identified and provided for in draft budgets. These requirements include:</p> <ul style="list-style-type: none"> <li>- Management of the Water Services</li> <li>- Operation and maintenance of the water schemes</li> <li>- Asset replacement</li> <li>- Asset development to ensure that the ability of the water schemes to deliver an acceptable Level of Service is not significantly degraded by growth in Waimate District</li> </ul>

### 8.3.3 Management Standards

Council’s Water Services are managed in accordance with the following standards:

- Generally accepted accounting practice (GAAP) and more specifically with FRS-3 “Accounting for Property, Plant and Equipment” (to be superseded by NZ IAS 16).
- The International Asset Management Manual.
- Resource Consent Conditions for the Waimate District Water Supply Activity.
- The Council’s Health and Safety Plan.
- Council’s Quality Assurance Documents.
- Operations Manuals.
- Water Services (Drinking Water Standards for New Zealand) Regulations 2022

## 8.4 Operations and Maintenance Plan

### 8.4.1 Introduction

Operations and Maintenance strategies set out how the water schemes will be operated and maintained on a day-to-day basis to consistently achieve the optimum use of assets. Operations and Maintenance activities fall into the following categories, each having distinct objectives and triggering mechanisms:

**Operations** - Activities designed to ensure efficient utilisation of the assets, and therefore that the assets achieve their service potential. Operational strategies cover activities such as energy usage, control of mechanical and electrical plant, inspections and service management.

**Maintenance** - Maintenance strategies are designed to enable existing assets to operate to their service potential over their useful life. This is necessary to meet service standards, achieve target standards and prevent premature asset failure or deterioration. There are three types of maintenance:

**Programmed maintenance** - A base level of maintenance carried out to a predetermined schedule. Its objective is to maintain the service potential of the asset system.

**Condition maintenance (Proactive)** - Maintenance actioned as a result of condition or performance evaluations of components of the water scheme. Its objective is to avoid primary system failure.

**Response maintenance (Reactive)** - Maintenance carried out in response to reported problems or system defects. Its objective is to maintain day-to-day Levels of Service.

### 8.4.2 Method of Delivery

The operation and maintenance of Council's Water schemes are carried out using a combination of Council staff and external contractors. Council staff generally carry out operational activities and maintenance of a routine nature with external contractors being used for specialist activities such as electrical work, laboratory testing and major overhauls of mechanical equipment. From time to time Council may use the services of local drain layers, earthworks contractors or plant hire. This is done through a mix of quotations and tendering with Council staff overseeing works.

### 8.4.3 Operations and Maintenance Strategies

Table 8-2 sets out operations and maintenance strategies.

**Table 8-2: O&M Strategies**

Strategy	Objective/ Description
Routine Maintenance	Routine Maintenance is carried out, supervised and monitored by Council's in house operational unit
Repairs and Corrective Maintenance	Reactive maintenance is undertaken as quickly as practically possible to restore an asset to a satisfactory condition after a failure or an unsatisfactory condition has been detected that is likely to fail in the short term. Council provides customer support for any associated requests for work related to the assets. In the rural restricted schemes minor work is not tended to immediately to ensure multiple tasks can be performed during a single site visit as indicated in the response time requirements.
Redesign and Modification	Redesign may be necessary if an asset or system does not meet its operational objective. Similarly, modifications may be necessary to improve the operating characteristics. Redesign and modifications will be undertaken in a methodical manner to ensure alternative options are considered and optimum decisions made.
Operations	Operational activities are undertaken by Council in house operational unit unless specialised advice is required. Council staff are responsible for the determination and optimisation of planned and unplanned works, work methods and maintenance scheduling to achieve the target service standards. Work is performed to Council's standards and specifications.
Physical Works Monitoring	The operational unit consist of skilled staff that are well versed on Council standards and specifications. Work is managed and overseen by the Utilities Supervisor. Weekly meetings are held to ensure work are completed on time and to Council standards.
Operation of Utilities	Utilities such as treatment plants, pump stations and reservoirs are operated in terms of defined parameters and standards set out in quality system manuals. Water Services utilities will be operated in terms of these quality manuals.
Incident management	Council approach is an escalation process from minor to major, all incidence is managed by the Council staff. Involvement is also judged by the potential consequences or asset criticality.
System Control and Monitoring	Where available, the SCADA system provides surveillance of the Treatment Plants, Bores, Intakes, Reservoirs and Pumping stations in the water schemes and will provide alarms when equipment fails or when operating parameters are exceeded. The SCADA system also records operational data.

### 8.4.4 Priority Response times

The Priority Response times targets for the Water Service are presented in Table 8-3.

**Table 8-3: Priority Response Times**

Priority	Response	Completion
P1	1 Hour	24 Hours
P2	4 Hours	48 Hours
P3	1 Day	5 Days
P4	5 Days	10 Days
P5	Projects	Specific Dates

The following details the priority for the individual utilities alarms and callouts.

**Table 8-4: Alarm Priority**

Utility	Description	Priority
Water:	SCADA Alarm	As recorded
	Health Issues	P1
	Maintenance - Urgent	P1
	No Water - Urban	P1
	Water Leak Urgent	P1
	Water Quality	P2
	Locate Asset	P2
	No Water - Rural	P2
	Tank Overflowing - Rural	P2
	Low Pressure / Low Flow	P2
	Water Leak	P2
	Maintenance	P3
	Change Restrictor	P5
	General Enquiry	P4
Meter Read - Specific Date	P5	

### 8.4.5 Operations and Maintenance Standards

The following standards are applicable to the operation and maintenance of the water schemes:

- NZS4404: 2010 Land development and subdivision infrastructure adopted by Council as its Engineering Code of Practice (which provides standards for materials and construction of piped water schemes).
- Relevant Resource Consents and the Resource Management Act 1991.
- Transit New Zealand Guidelines 'Working on the Road'.
- Health and Safety Plans.
- Electrical Regulations 1993.
- Council quality assurance processes, including contract management procedures.

### 8.4.6 Council Utilities Staff Qualifications

Table 8-5 details the utilities staff qualifications as at January 2018.

**Table 8-5: Council Utilities Staff Qualifications**

Position	Water Treatment	Wastewater Treatment	Reticulation Maintenance (Water & Waste)	Drain Laying & Plumbing	Backflow Prevention	Traffic Management		Confined Spaces	Heights	Asbestos	Chlorine	Chemical Handlers
						STMS	TC					
<b>3 Waters Manager</b>	NZCE	C Grade Wastewater Treatment Cert.	-	-	-	-	-	-	-	-	-	-
<b>Utilities Supervisor</b>	Level 4. Diploma Level 5 (incomplete)	-	Level 3	-	Yes	Yes	-	Yes	Yes	Yes	Yes	Yes
<b>Utilities Technician</b>	Level 4	Level 4	Level 3	-	-	Yes	-	Yes	Yes	Yes	Yes	Yes
<b>Utilities Technician</b>	Level 4	Level 4	Level 3	-	-	-	Yes	Yes	Yes	Yes	Yes	Yes
<b>Utilities Technician</b>	-	-	Level 3 (Incomplete)	-	-	-	-	-	-	-	Yes	-
<b>Utilities Technician</b>	Level 4 (Incomplete)	Level 4	Level 3	-	-	-	-	-	-	-	Yes	Yes
<b>Utilities technician</b>	-	-	-	-	-	-	-	-	-	-	-	-
<b>Three Waters Administration Technician</b>	-	-	-	-	-	-	-	-	-	-	-	-

## NZ Water Competency Framework


Assessment of staffing levels needs to consider the skill requirements to meet the demands of the infrastructure that Council does and will own and operate.

Increases in the complexity of water and wastewater treatment plants will occur as drinking water and environmental standards increase. The complexity of these plants and their associated resource consent compliance will require skilled and trained engineers for their operation, maintenance and supervision. Council needs to stay abreast of any resource requirements and qualifications to ensure the most appropriate method for delivery of the required levels of service.

During 2020 Water New Zealand released its draft Competency Framework which describes what people should be able to do and what they need to know to competently undertake their work. The Competency Framework use treatment operator roles, the people who operate, monitor and maintain water and wastewater services, as a starting point. Network/Distribution operators are still to be developed.

The Water Industry Professionals Association (WIPA) was jointly established by the Water Industry Operations Group and Water New Zealand to provide a system of recording the professional development of people working in the water and wastewater industry to ensure a high level of competency within the industry was maintained. At the time of writing this Plan registration is voluntary but may become compulsory under the new regulatory framework.

The Competency Framework identifies nine areas as shown below.



(Source: Water NZ – Competency Framework)

It documents core skills and knowledge needed by operators to competently undertake work within the water industry. It is envisaged that the industry will be able to use the final document as a guide to:

- assess levels of staff training,
- develop training programmes,
- determine the knowledge and skills required by a workforce, or
- other matters related to staff competence.

Council will keep abreast of developments in this area to ensure staff training meets industry best practice and standards.

The following competency framework documents are available from-  
<https://www.waternz.org.nz/competence>

- Competency Framework – Overview
  - Purpose statement
  - Key roles
  - Framework map and units of competence
  - Each document records what staff should be able to do and what they need to know to competently undertake their work
- Competency Framework – Drinking Water Treatment Operator
  - need to understand water treatment theories and principles to ensure processes such filtration, disinfection, coagulation and clarification are maintained and the operation of these processes are monitored and controlled.
- Competency Framework – Drinking Water Distribution Operator
  - need to understand hydraulics, pressures, and flows in a network in order to detect leakage. They need to utilise hydraulic theories and practices to ensure faults are resolved quickly and hygienically, while safely managing traffic and excavations to safely complete work
- Competency Framework – Small Water Supplies
  - Owner/operator networked supplies ( $\leq 500$  people) and what they should be able to do and what they need to know to competently undertake their work
- Competency Framework – Wastewater Network Operator
- Competency Framework – Wastewater Treatment Operator

### 8.4.7 Summary of Ten Year Operations and Maintenance Budget Forecast

Water Activity annual maintenance and operations costs are projected to increase from \$3,704,407 (2024/25) to \$5,560,792 (2033/34) over the 10 year period. There is no deferred maintenance scheduled over the period with cost increases being driven by inflation and increased interest payments associated with major compliance upgrades.


**Table 8-6: Operations and Maintenance Budget Forecasts**

O&M Costs	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	Y9	Y10	10 Year Total
	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	
Cannington/Motukaika	140,122	174,894	231,301	239,525	246,430	251,769	258,049	263,755	270,588	291,451	2,367,882
Hook/Waituna	466,104	527,286	688,798	718,490	731,401	744,454	773,345	779,334	786,830	799,162	7,015,204
Lower Waihao	613,064	682,538	705,090	730,850	736,263	747,807	769,007	767,123	775,298	788,853	7,315,894
Otaio/Makikihi	412,903	416,966	428,129	448,528	453,892	459,991	477,962	484,147	498,862	516,236	4,597,616
Waihaorunga	199,345	239,565	301,026	314,429	323,055	328,761	336,065	341,066	346,058	350,391	3,079,760
Waikakahi	508,470	600,197	703,103	724,320	737,037	745,049	761,397	772,651	779,503	790,351	7,122,077
Waimate Urban	1,364,401	1,504,519	1,573,137	1,654,418	1,729,148	1,811,304	1,890,280	1,920,560	1,961,918	2,024,285	17,433,970
<b>Total</b>	<b>3,704,407</b>	<b>4,145,964</b>	<b>4,630,584</b>	<b>4,830,560</b>	<b>4,957,225</b>	<b>5,089,135</b>	<b>5,266,105</b>	<b>5,328,636</b>	<b>5,419,058</b>	<b>5,560,729</b>	<b>48,932,403</b>

Further budget information is located in Section 8.6.



Figure 8-3: Water Supplies Operations & Maintenance Costs



## 8.5 Renewal and Replacement Plan

### 8.5.1 Introduction

Cyclic renewal strategies are intended to provide for the progressive replacement of individual assets that have reached the end of their useful life. The rate of asset renewal is intended to maintain the overall condition of the asset system at a standard, which reflects its age profile, and ensures that the Community's investment in the District's Water Services infrastructure is maintained.

The level of expenditure on cyclic asset replacement varies from year to year, reflecting:

- The age profile
- The condition profile
- The ongoing maintenance demand
- Customer service issues
- The differing economic lives of individual assets

Failure to maintain an adequate renewal programme will be reflected in a greater decline in the overall standard of the system of assets than would be expected from the age profile of the asset system.

Cyclic renewal works fall into two categories:

**Rehabilitation:** Involves the major repair or refurbishment of an existing asset. An example is the relining of an existing pipeline. Rehabilitation produces an extension in the life of an asset. It does not provide for a planned increase in the operating capacity or design loading

**Renewal:** Does not provide for a planned increase to the operating capacity or design loading. Some minor increase in capacity may result from the process of renewal, but a substantial improvement is needed before system development is considered to have occurred

For the purpose of developing asset renewal programmes the water schemes assets have used the following components consistent with the asset valuation process:

- Water Lines (Pipes, Mains)
- Water Points, Water Service Lines (Property connections)
- Water Plant (Reservoirs, Treatment Plants, Pumping & Valve Stations & Buildings)

## 8.5.2 Renewal and Replacement Strategies

The following table sets out the water supply cyclic renewal strategies:

**Table 8-7: Renewal Strategies: Existing and Future**

Strategy	Objective/ Description
Identification of renewal needs	<p>Renewal/replacement needs are identified by analysing;</p> <ul style="list-style-type: none"> <li>• Condition reports (as shown in Section 8.5.3), maintenance records (asset failure and expenditure history), water leakage studies, water quality test results, request for service (RFS) records, and observations of the Council's engineering and maintenance staff and contractors that they employ.</li> <li>• Records of breakages are recorded in Univerus Assets that allows an overview of the short term issues.</li> <li>• Customer feedback is essential for monitoring asset performance and achieving levels of service. The feedback is quite often the early warning system that a problem maybe developing and can lead to more formal investigations.</li> </ul> <p>The short-term asset renewal programmes have been prepared from specific renewal needs identified from information received by Council maintenance staff.</p> <p>The long-term asset renewal forecasts are based on an assessment of remaining asset lives (from the 2024 valuation process) and use industry base lives as a default position where condition or maintenance records are lacking.</p> <p>Future renewal programmes will use the data obtained in the proposed pipe condition assessments and the updated Univerus Assets data.</p> <p>The future renewals strategy will incorporate a process that uses the numbers of breaks in a main as an indicator for inserting onto short term renewal programme.</p> <p>This for the Waimate urban scheme may be five breaks per year but may increase for the rural schemes.</p>
Prioritisation of renewal projects	<p>Decisions on renewal works consider the short and long-term effects on the operating and structural integrity of the system.</p> <p>Renewal works are designed and undertaken in accordance with industry standards (or known future standards) and system design loadings.</p> <p>Short-term renewal priorities are reassessed annually taking account of additional information that becomes available via breakage reports etc.</p>
Deferred Renewals	<p>The quantity and impact of deferred renewals will be tracked.</p> <p>The Council recognises that although the deferral of some items on cyclic renewal programmes will not impede the operation of many assets in the short term, repeated deferral will create a future Council liability, unless supported by new asset data.</p>
Inspections prior to major road works	<p>The condition of water scheme pipelines is inspected prior to major road works to identify the risk of the road being damaged by pipeline failure or the need for pipeline replacement in the short/medium term. Pipelines in poor condition may be programmed for replacement prior to or in conjunction with the road works or reseal programme subject to funding.</p>
Rider mains	<p>Where possible rider mains are installed in the grass berm to eliminate or limit the number of laterals across the road.</p>
Service connections	<p>Tobies (where remaining) are replaced with manifolds (dual check), meters and manifold boxes.</p>
Restrictors	<p>Restrictor checks are done on a random basis but with all restrictors checked as resources allow. Customers are expected to maintain filters with filters available from Council free of charge. Recently installed network meters allow monitoring of zones for leakage or tampering.</p>
Dedicated delivery main	<p>Renewals within the Waimate Urban water scheme will consider upgrading of the current system to provide a dedicated delivery main from the Waimate Urban Water Treatment Plants to the reservoir on Mill Road. This will allow a reduced pressure regime within the network and will assist to extend reticulation asset lives.</p>

### 8.5.3 Cyclic Renewal Standards

The following standards are applicable to the renewal of water schemes assets:

- NZS4404: 2010 Land development and subdivision infrastructure adopted by Council as its Engineering Code of Practice (which provides standards for materials and construction of piped water schemes).
- Relevant Resource Consents and the Resource Management Act 1991.
- Transit New Zealand Guidelines 'Working on the Road'.
- Health and Safety Plans.
- Electrical Regulations 1993.
- Council quality assurance processes, including contract management procedures.

The Standards will be reviewed regularly and updated to incorporate relevant experiences, legislative requirements and changes in best practice.

### 8.5.4 Condition Assessment of Cast Iron, AC, Old PE and Garnite PVC Pipes

Development of a Condition Assessment Strategy to identify which, where and when condition assessments will be performed is include as an Improvement item. This will be done in consideration of criticality, LoS, asset records, Council engineers visual assessment of failures and specialists assessments as required. Implementation of the Condition Assessment Strategy and resulting information collected will then inform the renewal plan.

#### Cast Iron Pipes – Waimate Urban Water Scheme

Opus has carried out a number of assessments on the condition of cast iron pipes since 1998. The Condition Assessment report of March 2011 stated the following regarding the effects of graphitisation on cast iron pipes:

*Graphitisation, a de-alloying process, occurs in corroded cast iron pipe. This process results in the iron being leached away, leaving behind a matrix of flake graphite which occupies approximately the same volume as the original casting. This graphite has minimal strength but often maintains structural integrity against moderate water and/or ground pressures. However, the beam strength of graphitised pipe is reduced and its ability to withstand pressure surges is compromised.*

*The process of graphitisation is rarely uniform and, as in the case of these samples, some parts of the pipe show little signs of graphitisation while at other areas the graphitisation has completely penetrated the pipe wall. The variability of the depth of graphitisation can be partly due to the protection afforded by the hot-dip bitumen coating.*

Based on assessments of the condition of 10 samples of cast iron pipes recovered from the Waimate Urban water supply network over the past 13 years, Opus concludes that:

- All of the 3" (DN 75) and 4" (DN 100) cast iron pipes would not have complied with the BS 78:1917 for cast iron pipes. They may have been made to special order to minimise shipping weight and purchase cost.
- We expect that all of these small bore cast iron pipes are probably in a similar condition and are nearing the end of their useful lifetime.
- Failures can be expected to show an increasing frequency over the coming years.
- Failures will generally be associated with beam type failures (circumferential cracking) as small diameter, graphitised cast iron pipes do not have much strength in bending, such as caused by traffic loads, ground settlement or wetting and drying of clay soils.

- Pressure surges cause longitudinal cracking or blow-outs of weakened pipes.
- Three of the 1998 samples had split longitudinally, indicating fairly severe graphitisation
- We would expect that there have been other failures in the intervening years.
- It is likely that the consolidated soils surrounding the pipe are assisting the pipe to resist the internal pressure, however, any significant changes e.g. in traffic loads, ground settlement or ground shaking/vibration will be likely to cause pipe failure.
- These pipes have lasted extremely well considering their generally thin and highly variable wall thickness.
- We do not believe that rehabilitation (e.g. relining with cement mortar or epoxy paint) is an option as the pipe is in a poor condition with advanced graphitisation.
- All of the cast iron pipes of this vintage in Waimate should be programmed for renewal within the next approximately 10 years.
- To avoid a large 'spike' in renewal spending, the "worst" pipelines should be considered for renewal within the next few years, and the remainder progressively replaced when failure rate and water supply interruption starts to cause customer resistance.

The replacement value of cast iron pipes in Waimate as indicated in the 2024 valuation, of \$7.6m (21.2km of pipe). If renewal were to occur over a 10-year period this amounts to an annual renewal of \$757,000 (about 2.1 km per year). Obtaining further information of break frequencies and performance may well extend this timeframe. DN75 pipes will not offer firefighting capacity and this should also be a consideration for future renewal programmes.

It is noted from inspection, maintenance and report records that the larger diameter cast iron pipes are not generally causing issues (perhaps attributable to their construction in the United Kingdom). The 225mm diameter cast iron pipe samples have shown the pipe is in good condition.

The following photo shows a cast iron pipe joint failure, these are lead packed and when failure occurs the joint is sawn off and replaced by a gibault joint.

**Figure 8-4: Cast Iron Pipe Failure**



### AC Pipes

Initially AC Condition samples from Waimate Urban taken during 1999 indicated that pipe failures should have been expected approximately 15 years from the date of the pipe evaluation - that is from 2014 onwards.

More recent AC Condition samples have indicated slightly longer timeframes, but have also identified areas where condition is not as expected. These are targeted for replacement in years 1 through 3.

As the AC pipe remaining life is effected by different:

- Pressure regimes with the schemes.
- Water quality.
- Diameter: Small diameter AC pipe has a very short life (35 – 45 years) but larger diameter may have significantly greater life.
- Quality of installation.

Council's maintenance staff has noted the softness of the pipes in the different schemes that is a very good indication that the pipes will need replacement in the shorter term rather than long term. To better understand the different AC pipe life a programme of assessing the condition of the pipes in all the schemes that contain AC pipe will occur. This condition data will be incorporated into Univerus Assets to allow future renewal programmes to be produced and increased confidence in future valuations.

### **Old PE Pipe**

The 2011 Valuation Report noted the following for old PE:

*Old PE pipelines have an average life of 36 years. As significant operational problems are not yet observed, the 45 year assigned life may be conservative. The life of Old PE pipes has a significant impact on depreciation as they make up more than half of the rural pipeline system.*

In January 2012 Opus reviewed the life of the old PE pipe and noted “*while a conservative mean useful life of 45 years might have been appropriate in the past, it is likely to be over-conservative now. A revised estimate of 60 years is proposed for the remaining older rural PE pipe*”.

To better understand the different “old PE pipe” life, a programme of assessing the condition of the pipes in all the schemes that contain Old PE pipe will occur. This condition data will be incorporated into Univerus Assets to allow future renewal programmes to be produced and increased confidence in future valuations. Additional monitoring of break frequency is an economic metric to further infer pipe condition.

Asset renewal over recent years has removed the majority of the poor batches of pipe leaving an asset with a longer asset life.

### **Garnite PVC Pipe**

Garnite was one of the first types of PVC pipe installed in the Waimate water supplies. These pipes have shown to be very brittle and prone to failure. Asset renewal over recent years has removed the majority of the poor batches of pipe leaving an asset with a longer asset life (50 years plus).

### **8.5.5 Pressure Management: Waimate Urban Water Scheme**

The report “Waimate Water Supply – Pressure Management” by Opus (July 2009) was carried out as a previous distribution model study in 2008 found that there was excessive leakage within the system that was subject to relatively high pressures (half the town exceeds 70m).

The report considered a reduction in maximum pressures by 33% and assumed a burst frequency reduction of approximately 50% would give an annual savings of \$6,000. These savings do not take into consideration the savings associated with delaying the renewal of mains within the urban area. The rough order of costs in 2009 was \$1.2m. Council has completed the process of replacing part

of the critical rising main between the reservoir and the Waimate town. The next stage is to implement pressure management zones through the use of pressure reducing valves and isolating private connections through valving and rider mains where appropriate.

### 8.5.6 Evidence Base

The 2024 asset valuation identified the accuracy of most roading asset data as “B” or “Reliable” (Data based on sound records, procedures, investigations and analysis, documented properly but has minor shortcomings, for example some data is old).

The 2024 valuation has indicated the following data confidence for 3 Waters:

**Table 8-8: 3 Waters Asset Data Confidence**

Confidence Level	Description	Accuracy	Condition	Quantity	Unit Cost	Base Life
A	Highly Reliable and Accurate	100%				
B	Reliable with Minor Inaccuracies	±5%		B	B+	B+
C	50% estimated	±20%	C			
D	Significant data estimated	±30%				
E	All data estimated	±40%				

From a valuation perspective the data reliability is considered (for all assets covered by the IS) to be “B” or +/- 5%. Council acknowledges that the reduced reliability associated with less accurate condition ratings (+/- 20%) could impact future financial forecasting. However, this is currently mitigated by empirical assessment of assets proposed for renewal.

Council acknowledges there are limitations with its data that affect decision-making. A commitment to improving data collection and analysis is indicated below. Additional part-time and full time roles have been added to the Council team to address data limitations and accuracy.

### 8.5.7 Base Life of Water Supply Assets

The 2024 valuation used the base life for Water Services assets as shown in Table 8-9 below.

**Table 8-9: Water Supply Key Asset Base Life Information**

Asset Class	Material/Asset	Life
WS Pipe Lines	AC	60
	CI	105
	Galv	60
	PE	65 - 100
	PVC	100
	mPVC	100
	Steel	80
	Unknown	60
WS Point	Fire hydrant	75
	Meter	15
	Manifold	20
	Valve	30 - 50
WS Plant	Building	20 - 80
	Electrical	1 - 50



Asset Class	Material/Asset	Life
	Monitoring Equipment	3 - 40
	Pumps	10 - 20

A comprehensive asset base life record is kept in the council asset data system, Univerus Assets.


### 8.5.8 Long Term Water Renewals

As noted in Section 8.5.2 the renewals profile is based on an asset useful life. At present asset useful lives are based primarily on book values with some adjustment for known risk factors. These will be refined over time by determining evidence-based useful lives using a combination of condition and performance data.

#### Long Range 100 Year Renewal Profile

The chart below provides an overview of the long range one hundred year water supply renewals profile, based on WDC Univerus Assets asset information. This information indicates a \$58.4 million renewals investment over the hundred year period 2024-2125.

Figure 8-5: Water Renewals - 100 Years




The Univerus Assets information indicates a theoretical backlog based on baselife. For the purposes of renewals planning this is smoothed over the ten year period in Figure 7-77 below.

The chart below summarises the one hundred year water supply renewals across the key asset components:




**Figure 8-6 : 100 Year Water Supply Renewals by Key Asset Component Type**



**Thirty Year Renewal Forecast**

The chart below provides an overview of the thirty year water supply renewals profile based on WDC Univerus Assets asset information. This information indicates a \$29.05 million renewals investment over the thirty year period 2024-2034.

**Figure 8-7: Water Supply Renewals Profile - 30 Year**



The chart above has spread any theoretical backlog over the first 10 years and the dashed line represents the 10 year average renewal requirement.

The table below details the thirty year renewals profile per water supply scheme, based on the WDC Univerus Assets asset information.


Table 8-10: 30 Year Renewal Expenditure Forecasts by Supply– All Assets

SchemeName	Remaining Life	ws_line	ws_plant	ws_point	Total
Waimate Urban	0 or less	6,541,576	147,817	348,831	7,038,223
	1 - 5	621,500	167,284	20,709	809,494
	6 - 10	1,107,647	331,480	197,556	1,636,683
	11 - 15	215,657	406,222	595,374	1,217,253
	16 - 20	2,785,893	539,781	1,149,092	4,474,765
	21 - 25	1,202,817	87,548	67,755	1,358,121
	26 - 30	812,531	378,976	28,641	1,220,148
<b>Waimate Urban Total</b>		<b>13,287,620</b>	<b>2,059,108</b>	<b>2,407,959</b>	<b>17,754,687</b>
Lower Waihao	0 or less		129,131	159,306	288,437
	1 - 5		84,274	5,372	89,646
	6 - 10		35,768	6,248	42,016
	11 - 15	55,655	215,608	7,349	278,611
	16 - 20	366,204	555,109	32,253	953,567
	21 - 25		18,109	38,498	56,607
	26 - 30	7,753	436,694	16,073	460,520
<b>Lower Waihao Total</b>		<b>429,612</b>	<b>1,474,693</b>	<b>265,099</b>	<b>2,169,404</b>
Waikakahi	0 or less		166,500	143,943	310,444
	1 - 5		177,373	9,375	186,749
	6 - 10	598,019	56,698	2,813	657,530
	11 - 15	592,451	39,345	2,355	634,151
	16 - 20	8,895	26,473	24,233	59,601
	21 - 25		12,343	9,126	21,469
	26 - 30	47,878	10,150	6,055	64,083
<b>Waikakahi Total</b>		<b>1,247,243</b>	<b>488,882</b>	<b>197,901</b>	<b>1,934,026</b>
Cannington Motukaika	0 or less		107,658	57,147	164,805
	1 - 5		13,705		13,705
	6 - 10	191,584	7,588	4,676	203,848
	11 - 15	189,688		838	190,526
	16 - 20			1,464	1,464
	21 - 25		89	3,001	3,089
	26 - 30		2,490	930	3,419
<b>Cannington Motukaika Total</b>		<b>381,272</b>	<b>131,530</b>	<b>68,056</b>	<b>580,858</b>
Otaio Makikihi	0 or less		167,775	174,636	342,411
	1 - 5	279,883	74,552	15,493	369,928
	6 - 10	483,920	314,012	1,849	799,781
	11 - 15		61,251	9,011	70,262
	16 - 20		10,439	26,553	36,992
	21 - 25	706,741	79,476	16,341	802,559
	26 - 30	45	75,286	14,196	89,526
<b>Otaio Makikihi Total</b>		<b>1,470,589</b>	<b>782,792</b>	<b>258,079</b>	<b>2,511,459</b>
Hook Waituna	0 or less		116,977	416,089	533,066
	1 - 5		90,299	6,252	96,551
	6 - 10	1,053,708	156,556	6,938	1,217,202
	11 - 15	1,213,757	23,726	6,928	1,244,411
	16 - 20	8,776	20,630	43,574	72,980
	21 - 25	108	60,057	37,734	97,899
	26 - 30	29,956	25,820	27,635	83,411
<b>Hook Waituna Total</b>		<b>2,306,304</b>	<b>494,064</b>	<b>545,151</b>	<b>3,345,520</b>
Waihaorunga	<b>0 or less</b>		<b>183,543</b>	<b>40,577</b>	<b>224,120</b>
	1 - 5		12,417	1,086	13,503
	6 - 10		91,626	1,763	93,389

SchemeName	Remaining Life	ws_line	ws_plant	ws_point	Total
	11 - 15		21,631	1,596	23,227
	16 - 20	246,486	12,416	737	259,639
	21 - 25		3,864	4,252	8,116
	26 - 30	6,665	22,908		29,573
<b>Waihaorunga Total</b>		<b>253,151</b>	<b>348,405</b>	<b>50,011</b>	<b>651,566</b>
<b>Grand Total</b>		<b>19,375,791</b>	<b>5,779,474</b>	<b>3,792,255</b>	<b>28,947,520</b>

The chart below summarises the thirty year water renewal requirement

**Figure 8-8: 30 Year Water Renewals by Asset Group**




### 8.5.9 Ten Year Water Renewals Planning

As noted in Section 7.5.1, the following key asset components listed below. These components are consistent with the asset valuation process:

- Water Lines (Pipes, Mains)
- Water Points, Water Service Lines (Property connections)
- Water Plant (Reservoirs, Treatment Plants, Pumping & Valve Stations & Buildings)

The asset renewal planning analyses the asset data by these three asset groups. The charts below provide an overview of the water renewals planning and analysis of the asset data system replacement costs, average replacement costs and LTP budgets over the 20 year horizon

**Figure 8-9: Water Renewals Planning Chart**



- The chart shows a declining average ten year renewals requirement over the 30 year period.
- The Water asset data indicates a theoretical renewals backlog of approximately 9 million dollars. The chart above shows this smoothed over the next ten years.
- The majority of the backlog is cast iron (61%) and asbestos cement (24%) pipe, with an estimated replacement value of \$7.65 million based on the asset data replacement costs.
- The asset information indicates a \$15.2 million renewals requirement over the next ten years.
- The 2024-2034 renewals budget is \$10.7 million. This is adequate to cover the immediate known renewals priorities and retain rates increases to an acceptable level.
- Future renewals forecasting in subsequent LTPs will be refined based on ongoing asset condition assessments and fault trends.

The renewals profile is based on an asset useful life. At present asset useful lives are based primarily on book values with some adjustment for known risk factors. These will be refined over time by determining evidence-based useful lives using a combination of condition and performance data

The following section covers the ten year renewals budget (2024-2034):

### 8.5.10 Summary of Ten Year Water Renewals Budget Forecast


The following table details the ten year renewal programme (2024-2024). Detailed budgets are found in Section 8.6.

**Table 8-11: Ten Year Water Renewals Budget Forecast Summary**

Capital- Renewals	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	Y9	Y10	10 Year Total
	Enhanced AP 2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	
5110 - Cannington/Motukaika	29,600	62,000	15,728	11,591	-	55,501	71,635	74,211	5,823	42,880	368,968
5130 - Hook/Waituna	17,150	68,800	35,980	43,202	55,404	195,078	54,073	96,816	28,647	33,971	629,121
5140 - Lower Waihao	30,000	58,700	13,878	1,581	8,606	5,596	2,910	5,709	-	-	126,980
5150 - Otaio/Makikihi	24,000	14,400	23,644	26,343	105,428	20,849	166,776	150,935	173,511	510,754	1,216,639
5160 - Waihaorunga	42,000	25,000	23,644	100,102	54,005	33,138	33,803	55,601	35,168	35,872	438,332
5170 - Waikakahi	35,000	38,600	49,344	46,363	51,638	46,635	14,551	-	480,939	492,937	1,256,007
5310 - Waimate Urban	559,000	358,000	384,472	378,278	679,906	675,388	692,847	817,457	715,003	780,385	6,040,736
<b>Total</b>	<b>736,750</b>	<b>625,500</b>	<b>546,690</b>	<b>607,458</b>	<b>954,988</b>	<b>1,032,186</b>	<b>1,036,595</b>	<b>1,200,728</b>	<b>1,439,089</b>	<b>1,896,798</b>	<b>10,076,782</b>

It should be noted that the water treatment plants and other Renewal/LOS funded projects are included in the capital programme in Section 7.6.3.

**Figure 8-10: 10 Year Renewals Programme Chart Summary**



## 8.6 Asset Development Plan

### 8.6.1 Introduction

Asset development provides for a planned increase in the service capability of the water scheme to:

- Close gaps between the current capability of the water scheme and target service standards.
- Accommodate growth.

Asset development and asset renewal can occur simultaneously. The purpose of asset renewal is to prevent a decline in the service potential of the assets whereas asset development is concerned with the service improvements, measured by asset performance.

### 8.6.2 Asset Development Strategies

The table below sets out the strategies used for developing capital development programmes for the Water Services. These strategies are intended to progressively close gaps between target service standards (taking account of demographic and economic growth projections) and the current service capability of the asset system.

**Table 8-12: Development Strategies**

Strategy	Objective/ Description
Identification of development needs	Asset development needs are identified from analysis of; Demand forecasts, System performance monitoring (pressure, flow, leakage rates, etc.), Network modelling, risk assessments (Risk Management Plan), and customer service requests. A provisional forward capital works development programme is maintained and updated in in conjunction with updates of the AMPs.
Development Project Categorisation	Development Projects will be separated into projects to close service gaps and projects required to accommodate growth. Development projects to close service gaps are generally funded entirely by Waimate District Council. Development projects to accommodate growth may be partly or wholly funded through Development Contributions.
Prioritisation of development projects	Development projects are justified and prioritised using a risk based process Decisions on development works consider the short and long-term effects on the operating and structural integrity of the water schemes system.

Strategy	Objective/ Description
	<p>In determining the requirement for capital or asset development works the short and long-term effects on the operating and structural integrity of the system are considered, together with any forecast increase in loading upon the system.</p> <p>All feasible options, including non-asset demand management options and the use of second-hand plant, are considered. Development works are designed and undertaken in accordance with industry standards (or known future standards) and system design loadings.</p>
Project Approval	<p>A long-term development programme is prepared from projects meeting the assessment criteria, and all projects are approved through the Annual Plan process.</p> <p>The actual timing of asset development works will reflect the community's ability to meet the cost, as determined through the Annual Plan process.</p> <p>Scheduled projects meeting assessment criteria not funded are listed on the forward works programme for the following year.</p>
Project design	<p>All asset development works will be designed and constructed in accordance with current adopted industry standards (or known future standards) and system design loading.</p> <p>In determining capital or asset development work requirements the short and long-term effects on the operating and structural integrity of the system are considered, together with the demands of any forecast increase in loading upon the system.</p> <p>The system will be designed to minimise supply disruptions as far as practically possible by building in an appropriate level of redundancy.</p> <p>The standardisation of designs and specifications will be considered in the interest of facilitating replacement and operational simplicity.</p>
Vested Assets	<p>The risk, cost and benefits of accepting any new privately funded assets constructed in association with property development will be considered on a case by case basis in approval decisions.</p> <p>Such assets will be accepted into public ownership when satisfactorily completed in accordance with approvals given. Council will not contribute to the cost of such work unless there are exceptional service standard or equity issues.</p>

### 8.6.3 Summary of Ten Year Capital Budget Forecast

The main focus for Council is to:

- Improve water treatment for all schemes to comply with the Water Services Act, the DWQAR and NZDWS.
- Achieving compliance requires significant capital works to upgrade the treatment processes, estimated to cost \$9.21million.



The water treatment plant upgrades fall into three broad categories:

- Building better treatment plants to treat the water that is currently used.
- Finding new more easily accessible and easily treated water and treating this.
- Augmenting supplies for economies of scale.


The preferred option will be selected by considering the cost to build, run and continue producing very high quality water in compliance with New Zealand standards and legislative requirements.

**Table 8-13: 10 Year Water Capital Budget Forecast Summary**

New Capital	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	Y9	Y10	10 Year Total
	Enhanced AP 2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	
Cannington/Motukaika	-	1,215,000	-	-	62,396	-	-	-	323,731	330,208	1,931,336
Hook/Waituna	215,100	3,754,900	39,064	-	43,032	43,892	-	-	64,048	65,329	4,225,365
Lower Waihao	221,100	150,000	-	-	129,096	-	-	157,555	-	166,292	824,043
Otaio/Makikihi	89,000	179,250	67,077	68,754	174,979	-	-	171,940	-	-	751,000
Waihaorunga	-	1,264,000	77,100	-	-	-	-	-	-	-	1,341,100
Waikakahi	38,000	2,979,000	-	-	-	-	-	82,202	-	-	3,099,202
Waimate Urban	1,356,000	943,000	10,280	915,721	858,466	-	-	-	-	-	4,083,467
<b>Total</b>	<b>1,919,200</b>	<b>10,485,150</b>	<b>193,521</b>	<b>984,475</b>	<b>1,267,969</b>	<b>43,892</b>	<b>-</b>	<b>411,697</b>	<b>387,779</b>	<b>561,829</b>	<b>16,255,512</b>

It should be noted that the water treatment plants and other Renewal/LOS funded projects are included in the table above. The 2025/26 expenditure is provisional and may be subject to change following conclusion of enquiries with Taumata Arowai.

**Figure 8-11: 10 Year Water Capital Budget Forecast Summary Charts**



## 8.7 Disposal Plan

### 8.7.1 Introduction

The development of Asset Management Systems and use of Asset Condition / Performance data allows better planning for the disposal of assets through rationalisation of asset stock or when assets become uneconomic to own and operate.

All pipeline renewals identified in this Lifecycle Management Plan have a corresponding disposal either through the pipes being removed and disposed of at the landfill, or being left in the ground if the Water Services are refurbished using 'no-dig' techniques or the asset is replaced in a new location. Disposals are recorded within Univerus Assets and the GIS. Buried assets remain in the ground unless economic to remove or they pose a potential hazard.

In all cases asset disposal processes must comply with Council's legal obligations under the Local Government Act 2002, which covers:

- Public notification procedures required prior to sale
- Restrictions on the minimum value recovered
- Use of revenue received from asset disposal

When considering disposal options all relevant costs of disposal will be considered, including:

- Evaluation of options
- Consultation/advertising
- Obtaining resource consents
- Professional service, including engineering, planning and legal survey
- Demolition/making safe
- Site clearing, decontamination, and beautification

### 8.7.2 Asset Disposal Strategies

The following table details the disposal strategies.

**Table 8-14: Disposal Strategies**

Strategy	Objective/ Description
Asset Disposal	<p>Assess each proposal to dispose of surplus or redundant assets on an individual basis, subject to the requirements of the relevant legislation</p> <p>Asset disposal will comply with the requirements of the Local Government Act 2002 and in particular the requirement for councils to retain a capability to provide Water Services</p> <p>Redundant pipes are removed where their alignment clashes with replacement pipelines or where their existence is considered dangerous. Abandoned water scheme pipelines have possible future value for other purposes (such as ducting for cabling). As the extent of this value (if any) is uncertain it is not recognised in the asset valuation</p> <p>When a water scheme asset is abandoned or replaced the Geographic Information System and fixed asset register are updated. A system of job number creation and asset identification is used to document this process</p>
Residual Value	The residual value (if any) of assets, which are planned to be disposed of, will be identified and provided for in financial projections

## **8.8 Sustainability within Council**

In addition to managing the assets in an economically sustainable way, Council will also manage its internal operations to optimise their cost, efficiency and effectiveness, so that in the long term the costs of administering the infrastructure are sustainable.

While the overall view of this is not a subject for this plan, the management of the asset services delivery unit is relevant.

### **8.8.1 Staffing Levels**

Currently the Water and Wastes Group has twelve full time equivalent employees. This includes the role of Asset Manager which encompasses a wider footprint of activities and the Utilities Business unit of six FTE

The greater emphasis being placed on the responsible management, distribution, operation and maintenance of existing and future resources will add to the tasks of the Water and Wastes Group. Compliance with the requirements of the Water Services Act, Water Services (DWSNZ) Regulations 2022, Drinking Water Quality Assurance Rules and increased Regional Rules (LWRP) will ask a great deal of effort and prudent decision making from the Water and Wastes staff.

The Water Services Act will impose an increased demand on human resources to meet the compliance with the requirements of the Water Services Act. It will place an ongoing demand on human resources to monitor and report on Water Services Act compliance. The current staffing levels are supplemented by outsourcing. However, outsourcing still requires scoping, input and supervision from Council staff and does not exonerate staff from outsourced work.

Staff changes have impacted on the Univerus Assets/GIS data acquisition, capturing, trending and analysis. This will increase as new assets are acquired through water treatment plant upgrades.

Because of the above, assessment of staffing requirements will be required on an annual basis to ascertain the appropriate requirements for the increased workload. Assessment needs to consider the level of staffing coverage required to implement all of the Water and Wastes Group functions including internal management, information systems management, project management, design, supervision, construction, operations and maintenance.

### **8.8.2 Skills**

In addition to staffing numbers, assessment of staffing levels needs to consider the skill requirements to meet the demands of the infrastructure that Council does and will own and operate.

Increases in the complexity of facilities such as water treatment plants and pump stations are occurring. This will require skilled and trained staffs for operation, maintenance and supervision. A review of Council policy on resourcing the operations and maintenance is required to ascertain the most appropriate method for delivery of the required levels of service should be considered.

Refer to Section 8.4.6

### **8.8.3 Training**

Training of staff is presently on an ad-hoc basis with no structured long term development plans for the individual staff members in the asset management field. The link between asset life, and the ability to deliver of levels of service with the skills of the people who plan, design, install, operate

and maintain the assets is inevitable. It is crucial that the skill gaps of staff, contractors and service providers are identified; that there are structured training programmes to close these gaps; and that the effectiveness of the training provided is evaluated. Training programmes should be designed and reviewed for each individual – not for a business unit, contractor or service provider as an entity. Refer to Section 8.4.6.

#### **8.8.4 Succession Planning**

Succession planning within any business is considered necessary to reduce the risk associated with staff leaving the organisation. Succession planning allows institutional knowledge to be passed on, and assists in ensuring continuity of organisational culture.

Local Authorities have traditionally not been particularly successful at implementing succession planning techniques and practices. In previous decades the pool of experienced local authority and ex-public service engineers available meant that the negative effects of poor succession planning were not experienced. With a shrinking pool of experienced engineers, and near full employment these effects are now being experienced by more local authorities. Whilst there is always potential for staff in key positions to move on to further their careers, succession planning can help to mitigate the effects of this. Succession planning techniques can include:

- Sourcing replacement staff from within the organisation wherever possible
- Comprehensive personal career development plans in place for all relevant staff. This can include identifying weaknesses in training and experience and attempting to address those weaknesses by use of mentoring, relevant projects and continuing professional development programmes etc.
- Identifying likely staff retirements, promotions, resignations or position changes on an annual basis. Identifying potential internal staff to fill those positions, providing those staff with projects that extend them, and giving them relevant experience for filling the positions

No formal succession planning is implemented at present by Council. It is important that the current knowledge of existing staff on the Wastewater Services is continuously captured within Univerus Assets and supporting asset management tools. This will reduce the risk to service continuation as a result of unplanned staff absences and any future retirements or resignations.

#### **8.8.5 Efficient Use of Energy within Councils 3Water Facilities**

The 3 Waters uses a significant proportion of the Council total energy consumption via their extensive range of facilities. Instigation of energy management through the use of the Energy Efficiency and Conservation Authority (EECA) methodologies and subsidies will assist in reducing total energy consumption. Where new plant is to be installed, Council staff take the opportunity to use modern energy efficient devices such as variable speed drives, soft starters.

##### **Efficient Operation of Facilities**

The Council operates a SCADA system that allows the operation of the facilities (WTP and majority of water pump stations) remotely allowing efficiency monitoring and running the plant in off peak situations where it is practical to do so.

## 9.0 FINANCIAL SUMMARY

*This Section sets out financial statements, funding strategy, depreciation forecast and charges for the Water Services in Waimate District.*

### 9.1 Financial Strategy

This AMP will provide the substantiation for budget forecasts put forward in the LTP (2025-2034) for Water Services assets. Council will:

- Implement an improvement approach to asset management planning in the short term. A 10 year improvement plan is included in each AMP. Improvement projects will be monitored monthly by the Asset Group Manager.
- Prepare, maintain and periodically review an AMP outlining sustainable long-term asset management strategies. The AMP will typically be reviewed three-yearly in advance of the LTP. Annual amendments or updates may be undertaken if significant asset management changes occur.
- Report variations in the adopted annual plan budgets against the original AMP forecasts and explain the Level of Service implications of budget variations.

### 9.2 Development Contributions

Please refer to Financial Policy 404 - Financial Contributions Policy.

Council has expressed a desire to rationalise capital contributions across the three waters activities. A number of discrete “connection fees” currently exist with some at a level that discourage growth. With the proposed ring-fencing of the three waters activities, opportunities exist to review pricing structures and methodologies to ensure equity across the activities.

### 9.3 Depreciation

#### 9.3.1 Background

The introduction of accrual accounting during the early 1990’s changed the way in which local authorities accounted for their assets, particularly long life assets i.e. pipes and roads. This meant that instead of cash based accounting where the replacement/renewal cost of an asset is recognised only when it wears out, local authorities were required to spread the cost, and any reduction in the value of these assets over its useful life.

*Section 100 subsection 1 of the LGA 2002 states: “A local authority must ensure that each year’s projected operating revenues are set at a level sufficient to meet that year’s projected operating expenses.”*

*This requirement to set operating revenues at a level sufficient to meet operating expenses includes depreciation as Section 111 obliges councils to follow generally accepted accounting practice (GAAP) which includes a definition of “operating expenses.” As depreciation is defined as an operational expense it must be included with other operational costs, including interest, when a council sets its operating revenue.*

*GAAP defines depreciation as follows:*

*Depreciation is the systematic allocation of the depreciable amount of an asset over its useful life.<sup>6</sup>*

Therefore, depreciation measures the annual consumption of an asset so that the reduction in its value is accounted for as it is consumed. The purpose of depreciation is not to provide for the

---

<sup>6</sup> Source: Depreciation in the local government context, July 2011. Local Government New Zealand

replacement of the asset, although this is a consequence of depreciation. Depreciation ensures that each year’s ratepayers pay their way.

The basic value of an asset reduces in accordance with the wearing out or consumption of benefits over the assets life arising from use, the passage of time, or obsolescence. This reduced value is called the depreciated value. It is accounted for by the allocation of the cost (or revalue amount) of the asset less its residual value over its useful life.

The decline in service potential is thus provided on a straight line basis on all fixed assets. Therefore Council complies with the requirements of FRS3 and NZIAS 16 and funds asset depreciation.

The Council revalues its assets every three years to keep them up to date and this means that depreciation charge reflects the cost of replacing the asset. It is the valuers role to appropriately identify the level of depreciation, though this will be better achieved through more robust data e.g. condition assessment.

### 9.3.2 Level of Depreciation Funding


The annual water depreciation from the 2024 valuation report is \$838,857. The bulk of this is funded through targeted rates associated with the water supplies. Where schemes are experiencing funding difficulties, only part of the depreciation is funded. This is the case where significant improvements in LoS are predicted in the shorter term. This will be reassessed when the upgrades are complete and useful lives have been reassessed.

## 9.4 Valuations

### 9.4.1 2024 Valuation Summary

Valuations of the 3 Waters infrastructure were carried out in June 2024 and is summarised in the chart below. The chart provides an overview of the valuation per Water activity, with Water having the largest asset value of \$57.52 million followed by Wastewater with \$42.27 million and then Stormwater with a value of \$7.50 million:

Figure 9-1: 3 Waters 2024 Valuation




### 2024 Water Valuation Information

A summary of the 2024 Water valuation is presented in the tables and charts below.

**Table 9-1: 2024 Water Valuation Summary**

Scheme	ORC	ODRC	Annual Depreciation
Non Pipe Assets	\$8,499,209	\$5,262,744	\$260,500
Pipe Assets	\$49,018,712	\$24,171,836	\$578,357
<b>Total Water</b>	<b>\$57,517,921</b>	<b>\$29,434,580</b>	<b>\$838,857</b>


**Figure 9-2: 2024 Water Valuation Summary Chart**



**Table 9-2: 2024 Valuation Summary by Water Supply**

Scheme	ORC	ODRC	Annual Depreciation
Waimate Urban	\$30,104,603	\$14,203,970	\$403,695
Cannington Motukaika	\$1,233,767	\$462,944	\$15,018
Hook Waituna	\$6,586,371	\$2,809,542	\$97,349
Lower Waihao	\$6,286,235	\$4,619,194	\$121,638
Otaio Makikihi	\$6,451,049	\$3,853,708	\$100,176
Waihaorunga	\$1,403,428	\$683,424	\$20,974
Waikakahi	\$5,329,281	\$2,775,987	\$76,932
SCADA	\$123,188	\$25,811	\$3,075
<b>Total Water</b>	<b>\$57,517,921</b>	<b>\$29,434,580</b>	<b>\$838,857</b>

**Figure 9-3: 2024 Valuation Summary Chart by Water Supply**





### Change in Water Optimised Replacement Cost (ORC) from 2022 to 2024

The ORC increase from the 2022 valuation to 2024 was \$7,044,306 or 13.96%.

Revaluation movements are attributed to inflationary factors, unit rate reviews, additions and deletions to the network, values of renewals, amendments, and depreciation of asset values that existed as of 30 June 2022.

### 2024 Valuation Improvements Identified

Based on Beca's observations from completing the 2024 valuation, they recommend that WDC review the following:

Higher priorities are:

- Capture and verify stormwater and wastewater manhole diameters and depths to replace the unknowns.
- Further explore the use of engineering estimating cost build-up techniques to support unit cost reviews.
- Set one base life for lines, plant, and points with similar attributes then remove the duplicate base lives.

Lesser priorities are:

- Set a minimum RUL of 1 so when the 2.5% Base Life Adjusted RUL < 1 it prevents AFD exceeding DRC.
- Capture and verify laterals with install dates, materials, and diameters to replace the lateral plant valuation.
- Use CCTV condition data to estimate remaining lives for poor or very poor condition assets for valuations.
- When entering new assets into Univerus, avoid numbering and/or text renaming of the otherwise uniquely identified Univerus generated Asset IDs.

### 9.4.2 Data Confidence Levels

The quantity and quality of the data for the 2024 valuation is shown in Table 9-3.

**Table 9-3: Assessment of Confidence Levels**

Asset	Quantity	Replacement Cost	Life Expectancy	Condition
Water assets	B	B <sup>+</sup>	B <sup>+</sup>	C

It is accepted that most condition data across the data is anecdotal hence the C rating, however, it has not been taken into the overall data confidence grade as condition was not used to adjust remaining useful life. Taking condition out of the assessment, we consider a data confidence of B (reliable) is appropriate for this valuation.

## 9.5 How We Fund Our Activity

The following table summarises the ways in which the water activity is funded:

**Table 9-4: Water Funding Sources**

Activity	Funding method
Operations and Maintenance	<ul style="list-style-type: none"> <li>• Individual scheme rates</li> <li>• Water usage via water meters</li> </ul>
Renewals	<ul style="list-style-type: none"> <li>• Depreciation</li> <li>• Loans (either internal or external)</li> </ul>
Capital	<ul style="list-style-type: none"> <li>• Development/Financial contributions</li> <li>• Private or Community contributions</li> <li>• Government Subsidies / Funding initiatives</li> <li>• Loans (either internal or external)</li> </ul>

## 9.6 10 Year LTP Financial Projections and Budget Forecasts

### 9.6.1 Background

The Water Services Acts Repeal Act was enacted in February 2024, and included a number of transitional arrangement(s) for local authorities. The Act will include transitional arrangements for local authorities to include water services provision in their 2024-34 long-term plans, including:

an  
*...provisions allowing local authorities to defer their 2024-2034 long-term plan by a year, replaced by an 'enhanced' annual plan for the 2024/25 financial year. A council must make a decision to do so by 30 April 2024, and if it does not, it may be authorised to defer its plan by Order in Council.*

Based on this, Council decided to defer the 2024-34 Long-term Plan for one year and consulted on a 2024-25 Enhanced Annual Plan with the additions laid out in the new legislation and adopts a Long-Term Plan (2025-34) by 30 June 2025.

The financial budget forecasts in this AMP cover:

- 2024/25 Enhanced Annual Plan budgets
- 2025/26 -2033/34 LTP budgets

The budgets are based on financial projections covering the lifecycles of the assets. The longer-range renewals profiles are included in Section 7.5 to highlight any major expenditure likely to occur in the next planning horizon.

The financial budget forecasts for the Water Services activity are detailed under the under the following:

- Operations and Maintenance
- Capital works – Growth
- Capital Works – Increased Level of Service
- Capital Works – Renewals
- Capita Works – Vested Assets

It needs to be noted that the Water capital budgets do not exactly match the predicated capital expenditure from the 2024 valuations (book value) in Section 8.4.1. This is due to the following reasons:

- Assessment of pipe, adjustment for known risk factors, and actual number of breaks/leaks (Section 7.5.2)
- Positive impacts of the renewal work already done i.e. reductions in breaks/leaks
- The ability to all do the physical works required (staffing)
- The ability to finance all assets that have that fallen due for renewal, which includes those assets that have well past their useful lives and were not renewed at time of expiry

The budgets in the following sections are the inflated budgets as per the inflation indices in the LTP Assumptions.

### 9.6.2 10 Year Water Budget Forecast Summary

The table and charts below summarise the Water 2024-2034 budgets:

**Table 9-5: 10 Year LTP Budget Forecasts**

	Enhanced AP 2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	Total
Operating Expenditure	3,704,407	4,145,964	4,630,584	4,830,560	4,957,225	5,089,135	5,266,105	5,328,636	5,419,058	5,560,729	48,932,403
Capital (LOS/AD/REN)	2,655,950	11,110,650	740,211	1,591,933	2,222,957	1,076,078	1,036,595	1,612,425	1,826,868	2,458,627	26,332,294
<b>Total</b>	<b>6,360,357</b>	<b>15,256,614</b>	<b>5,370,795</b>	<b>6,422,493</b>	<b>7,180,182</b>	<b>6,165,213</b>	<b>6,302,700</b>	<b>6,941,061</b>	<b>7,245,925</b>	<b>8,019,356</b>	<b>75,264,698</b>

**Figure 9-4: Summary of 10 Year Maintenance & Operations and Capital (Including Renewals) Forecasts**





Figure 9-5: 10 Year Water Capex and Opex Summary



### 9.6.3 10 Year Operations and Capital Financial Statements

The budget tables below detail the Water Supplies 2024-2034 Operations and Capital budget forecasts, including inflation.

As the renewal works are progressed the existing maintenance expenditure will decrease markedly. This will of course be offset by the increased operational costs as a result of the DWSNZ upgrade works i.e. higher labour, electricity and treatment consumables costs.

#### Cannington / Motukaika Supply

**Table 9-6: Detailed Maintenance & Operational Expenditure Forecasts: Cannington / Motukaika (figures are inflated)**

5110 - Cannington/Motukaika	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Operating Revenue</b>	<b>-113,130</b>	<b>-141,397</b>	<b>-176,732</b>	<b>-220,901</b>	<b>-242,985</b>	<b>-267,278</b>	<b>-275,296</b>	<b>-283,554</b>	<b>-292,061</b>	<b>-312,501</b>	<b>-2,325,834</b>
511001505 - Targeted Rate - Water	-113,067	-141,334	-176,667	-220,834	-242,917	-267,209	-275,225	-283,482	-291,987	-312,426	-2,325,149
511007101 - Dividend - SC Power	-63	-63	-65	-66	-68	-69	-71	-72	-73	-75	-685
511007305 - Internal Interest	-	-	-	-	-	-	-	-	-	-	-
<b>Operating Expenditure</b>	<b>140,122</b>	<b>174,894</b>	<b>231,301</b>	<b>239,525</b>	<b>246,430</b>	<b>251,769</b>	<b>258,049</b>	<b>263,755</b>	<b>270,588</b>	<b>291,451</b>	<b>2,367,882</b>
5110322 - Advertising and Notices	200	200	206	211	215	219	224	228	233	238	2,174
5110333 - General Expenses	531	531	546	560	571	583	594	606	618	631	5,771
5110336 - LAPP Disaster Fund	3,856	4,557	4,685	4,802	4,902	5,000	5,101	5,203	5,307	5,413	48,825
5110356 - Telephone Expenses	134	134	138	141	144	147	150	153	156	159	1,456
5110357 - Utilities charges	34,000	40,800	41,582	42,381	43,166	43,928	45,526	45,427	46,162	46,910	429,882
511040313 - Depreciation	27,415	54,018	54,018	55,219	58,737	58,737	60,035	63,436	66,795	71,622	570,031
511040405 - Internal Interest	-1,850	-1,113	2,119	4,605	5,489	7,949	9,255	11,154	12,951	10,471	61,032
511040406 - Internal Loan - internal interest	-	-	49,023	49,199	50,014	50,439	50,396	49,530	48,578	64,295	411,473
5110405 - Insurance	1,603	1,129	1,161	1,190	1,215	1,239	1,264	1,289	1,315	1,341	12,744
5110422 - Electricity - Cannington	4,600	4,600	4,729	4,847	4,949	5,048	5,149	5,252	5,357	5,464	49,993
511042405 - Internal Rent	7,967	9,512	9,767	10,483	10,680	10,685	11,439	11,200	11,103	12,080	104,917
5110425 - Rates	663	716	780	800	817	833	850	867	884	902	8,110
5110501 - Asset Mgt Plan	2,642	2,642	2,716	2,784	2,842	2,899	2,957	3,016	3,077	3,138	28,714
5110504 - Consultants	1,000	1,000	1,028	1,054	1,076	1,097	1,119	1,142	1,165	1,188	10,868
5110506 - Contractors	1,000	1,000	1,028	1,054	1,076	1,097	1,119	1,142	1,165	1,188	10,868
5110508 - Line Maintenance	2,271	2,271	2,335	2,393	2,443	2,492	2,542	2,593	2,645	2,697	24,681
5110510 - Operational Maintenance	2,068	2,068	2,126	2,179	2,225	2,269	2,315	2,361	2,408	2,456	22,475
5110511 - Pump Maintenance	3,393	3,393	3,488	3,575	3,650	3,723	3,798	3,874	3,951	4,030	36,875
5110512 - Water Testing	5,100	5,100	5,243	5,374	5,487	5,596	5,708	5,823	5,939	6,058	55,427
5110516 - Operational Contractor system support	3,000	3,200	3,392	3,477	3,550	3,621	3,694	3,768	3,843	3,920	35,465
5110517 - Monitoring consents and compliance	500	500	514	527	538	549	560	571	582	594	5,434

5110 - Cannington/Motukaika	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
5110520 - Source / Headworks	4,637	4,637	4,767	4,886	4,988	5,088	5,190	5,294	5,400	5,508	50,395
5110601 - HR Costs - 8125	893	972	1,314	1,511	1,393	1,469	1,462	1,667	1,525	1,603	13,809
511060101 - 8126 - Health & Safety O/H Recoveries	847	863	891	917	942	966	989	1,011	1,033	1,091	9,549
5110602 - Corporate Services Costs - 8120	3,621	3,615	4,050	4,202	4,270	4,363	4,439	4,499	4,606	4,628	42,293
5110604 - Utilities Costs - 8140	14,458	9,938	10,228	11,218	10,911	11,302	11,421	11,562	12,289	12,002	115,329
5110606 - Asset Management Unit Costs - 8160	5,180	7,856	8,227	8,398	8,526	8,843	8,996	9,091	9,194	9,515	83,827
5110608 - Network Costs	4,356	4,836	5,027	5,195	5,034	4,851	4,904	5,016	5,202	5,065	49,486
5110609 - CEO & Finance Costs - 8110	2,422	2,431	2,552	2,627	2,688	2,780	2,841	2,892	2,945	3,003	27,179
5110611 - Support - Asset Manager	3,615	3,489	3,624	3,717	3,891	3,955	4,015	4,088	4,162	4,242	38,798
<b>Operating (Surplus) / Deficit</b>	<b>26,992</b>	<b>33,497</b>	<b>54,569</b>	<b>18,624</b>	<b>3,445</b>	<b>-15,509</b>	<b>-17,247</b>	<b>-19,800</b>	<b>-21,473</b>	<b>-21,050</b>	<b>42,049</b>

Table 9-7: Detailed Capital Expenditure Forecasts: Cannington/Motukaika (figures are inflated)

Cannington Motukaika -5110	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Level of Service</b>	-	15,000	-	-	-	-	-	-	-	-	15,000
511076011 - Cannington - Pratts turbidity meter	-	15,000	-	-	-	-	-	-	-	-	15,000
<b>Renewal</b>	<b>29,600</b>	<b>62,000</b>	<b>15,728</b>	<b>11,591</b>	-	<b>55,501</b>	<b>71,635</b>	<b>74,211</b>	<b>5,823</b>	<b>42,880</b>	<b>368,968</b>
511076001 - Cannington - Renewals	11,000	48,000	11,308	11,591	-	55,501	71,635	74,211	5,823	42,880	331,948
511076004 - Cannington - Pratts Pumphouse - Pump 1 renewal	-	-	4,420	-	-	-	-	-	-	-	4,420
511076006 - Cannington - Renewal maintenace of weir	-	14,000	-	-	-	-	-	-	-	-	14,000
511076007 - Cannington - Pratts pumphouse power supply	18,600	-	-	-	-	-	-	-	-	-	18,600
<b>Renewal/ Level of Service</b>	-	<b>1,200,000</b>	-	-	<b>62,396</b>	-	-	-	<b>323,731</b>	<b>330,208</b>	<b>1,916,336</b>
511076002 - Cannington - Drinking Water compliance upgrade	-	1,200,000	-	-	-	-	-	-	-	-	1,200,000
511076009 - Cannington - 80mm Line "Slip Line" (700m x 125mm PE)	-	-	-	-	-	-	-	-	323,731	330,208	653,939
511076012 - Cannington - Dwyer 63OD 1494m 4OOD 929m and PRV	-	-	-	-	62,396	-	-	-	-	-	62,396
<b>Total Capital Expenditure</b>	<b>29,600</b>	<b>1,277,000</b>	<b>15,728</b>	<b>11,591</b>	<b>62,396</b>	<b>55,501</b>	<b>71,635</b>	<b>74,211</b>	<b>329,554</b>	<b>373,088</b>	<b>2,300,304</b>

Section 9: Financial Summary

**Hook / Waituna Supply**

**Table 9-8: Detailed Maintenance & Operational Expenditure Forecasts: Hook/Waituna (Figures are inflated)**

5130 - Hook/Waituna	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Operating Revenue</b>	<b>-463,398</b>	<b>-526,626</b>	<b>-588,128</b>	<b>-656,905</b>	<b>-733,814</b>	<b>-755,630</b>	<b>-778,099</b>	<b>-801,236</b>	<b>-813,359</b>	<b>-825,667</b>	<b>-6,942,862</b>
513001505 - Rates Appropriation - Targeted	-453,772	-508,225	-569,211	-637,516	-714,019	-735,439	-757,502	-780,228	-791,931	-803,810	-6,751,653
513002501 - Works - Application fee	-1,085	-2,000	-2,056	-2,107	-2,152	-2,195	-2,239	-2,283	-2,329	-2,376	-20,821
513005101 - Recoveries - General	-4,884	-6,000	-6,168	-6,322	-6,455	-6,584	-6,716	-6,850	-6,987	-7,127	-64,093
513007101 - Dividend - SC Power	-401	-401	-412	-423	-431	-440	-449	-458	-467	-476	-4,358
513007305 - Internal Interest	-	-	-	-	-	-	-	-	-	-	-
5130081 - Capital Contributions - Water	-3,256	-10,000	-10,280	-10,537	-10,758	-10,973	-11,193	-11,417	-11,645	-11,878	-101,937
<b>Operating Expenditure</b>	<b>466,104</b>	<b>527,286</b>	<b>688,798</b>	<b>718,490</b>	<b>731,401</b>	<b>744,454</b>	<b>773,345</b>	<b>779,334</b>	<b>786,830</b>	<b>799,162</b>	<b>7,015,204</b>
5130322 - Advertising and Notices	213	213	219	224	229	234	238	243	248	253	2,315
5130333 - General Expenses	1,063	1,063	1,093	1,120	1,144	1,166	1,190	1,214	1,238	1,263	11,553
5130336 - LAPP Disaster Fund	13,482	15,933	16,379	16,789	17,141	17,483	17,834	18,191	18,554	18,925	170,710
5130356 - Telephone Expenses	414	414	426	436	445	454	463	473	482	492	4,499
5130357 - Utilities charges	105,000	126,000	128,415	130,883	133,308	135,660	140,595	140,291	142,559	144,869	1,327,578
513040313 - Depreciation	107,235	151,775	152,330	160,333	164,293	165,840	174,496	179,069	179,145	188,467	1,622,982
513040405 - Internal Interest Expense	-18,813	-10,684	1,170	7,017	9,882	12,334	9,912	9,750	10,663	11,011	42,242
513040406 - Internal Loan - internal interest	-	-	138,270	138,765	141,064	142,263	153,573	150,995	148,157	143,419	1,156,505
5130405 - Insurance	10,764	7,947	8,170	8,374	8,549	8,720	8,895	9,073	9,254	9,439	89,186
5130422 - Electricity	13,000	13,000	13,364	13,698	13,985	14,265	14,551	14,842	15,139	15,441	141,285
513042405 - Internal Rent	23,714	28,321	29,082	31,220	31,807	31,825	34,074	33,359	33,071	35,986	312,459
5130425 - Rates	3,156	3,408	3,714	3,807	3,887	3,965	4,044	4,125	4,207	4,292	38,604
5130501 - Asset Mgt Plan	9,153	6,000	6,168	6,322	6,455	6,584	6,716	6,850	6,987	7,127	68,362
5130504 - Consultants	2,000	2,000	2,056	2,107	2,152	2,195	2,239	2,283	2,329	2,376	21,736
5130506 - Contractor - Other	1,594	1,594	1,639	1,680	1,715	1,749	1,784	1,820	1,856	1,893	17,324
5130508 - Line Maintenance	1,800	1,800	1,850	1,897	1,936	1,975	2,015	2,055	2,096	2,138	19,563
5130510 - Operational Maintenance	2,068	2,068	2,126	2,179	2,225	2,269	2,315	2,361	2,408	2,456	22,475
5130511 - Pump Maintenance	2,000	2,000	2,056	2,107	2,152	2,195	2,239	2,283	2,329	2,376	21,736
5130512 - Water Testing	6,618	6,618	6,803	6,973	7,120	7,262	7,408	7,556	7,707	7,861	71,925
5130514 - Water purchases	28,000	28,000	28,784	29,504	30,122	30,724	31,340	31,968	32,606	33,258	304,307
5130516 - Operational Contractor system support	8,900	9,400	10,177	10,432	10,650	10,863	11,081	11,303	11,529	11,759	106,094
5130517 - Monitoring consents and compliance	500	500	514	527	538	549	560	571	582	594	5,434
5130520 - Source / Headworks	5,315	5,315	2,570	2,634	2,690	2,743	2,798	2,854	2,911	2,970	32,800
5130601 - HR Costs - 8125	3,484	3,790	5,125	5,894	5,432	5,728	5,700	6,502	5,948	6,252	53,856



## Section 9: Financial Summary

513060101 - 8126 - Health & Safety O/H Recoveries	3,303	3,366	3,474	3,577	3,672	3,766	3,855	3,944	4,030	4,253	37,241
5130602 - Corporate Services Costs - 8120	12,786	12,766	14,302	14,840	15,081	15,408	15,675	15,888	16,267	16,344	149,358
5130604 - Utilities Costs - 8140	74,548	51,244	52,737	57,845	56,261	58,279	58,889	59,619	63,365	61,888	594,675
5130606 - Asset Management Unit Costs - 8160	13,269	20,122	21,073	21,511	21,839	22,651	23,042	23,286	23,549	24,372	214,715
5130608 - Network Costs	17,566	19,499	20,269	20,948	20,299	19,559	19,774	20,227	20,976	20,423	199,540
5130609 - CEO & Finance Costs - 8110	8,553	8,583	9,012	9,276	9,494	9,817	10,032	10,213	10,399	10,606	95,985
5130611 - Support - Asset Manager	5,419	5,230	5,432	5,571	5,833	5,929	6,018	6,128	6,239	6,359	58,159
<b>Operating (Surplus) / Deficit</b>	<b>2,706</b>	<b>660</b>	<b>100,670</b>	<b>61,585</b>	<b>-2,414</b>	<b>-11,176</b>	<b>-4,753</b>	<b>-21,902</b>	<b>-26,528</b>	<b>-26,505</b>	<b>72,343</b>

Table 9-9: Detailed Capital Expenditure Forecasts: Hook / Waituna (Figures are inflated)

Hook Waituna - 5130	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Level of Service</b>	<b>70,000</b>	<b>2,396,900</b>	-	-	-	-	-	-	-	-	<b>2,466,900</b>
513076020 - Hook / Waituna - pH Online analysers	19,000	-	-	-	-	-	-	-	-	-	19,000
513076021 - Hook / Waituna - Source / WTP generator	51,000	6,000	-	-	-	-	-	-	-	-	57,000
513076022 - Hook / Waituna - PVC Tavistock Hook supply link	-	2,390,900	-	-	-	-	-	-	-	-	2,390,900
<b>Renewal</b>	<b>17,150</b>	<b>68,800</b>	<b>35,980</b>	<b>43,202</b>	<b>55,404</b>	<b>195,078</b>	<b>54,073</b>	<b>96,816</b>	<b>28,647</b>	<b>33,971</b>	<b>629,121</b>
513076001 - Hook / Waituna - Renewals	11,150	62,700	31,868	43,202	55,404	195,078	52,954	96,816	28,647	33,971	611,789
513076012 - Hook / Waituna - Simmons Pumphouse pump renewal	-	-	4,112	-	-	-	-	-	-	-	4,112
513076014 - Hook / Waituna - Flow meter replacement	6,000	6,100	-	-	-	-	1,119	-	-	-	13,219
<b>Renewal/ Level of Service</b>	<b>145,100</b>	<b>1,358,000</b>	<b>39,064</b>	-	<b>43,032</b>	<b>43,892</b>	-	-	<b>64,048</b>	<b>65,329</b>	<b>1,758,465</b>
513076005 - Hook / Waituna - Drinking water compliance upgrade	109,100	1,320,000	-	-	-	-	-	-	-	-	1,429,100
513076016 - Hook / Waituna - Line renewal Intake to O'Donnells	-	-	-	-	43,032	43,892	-	-	64,048	65,329	216,301
513076018 - Hook / Waituna - Line renewal upper Nortons Reserve Rd	-	38,000	39,064	-	-	-	-	-	-	-	77,064
513076019 - Hook / Waituna - Line renewal Manchesters and Molloys Rd	36,000	-	-	-	-	-	-	-	-	-	36,000
<b>Total Capital Expenditure</b>	<b>232,250</b>	<b>3,823,700</b>	<b>75,044</b>	<b>43,202</b>	<b>98,436</b>	<b>238,970</b>	<b>54,073</b>	<b>96,816</b>	<b>92,694</b>	<b>99,300</b>	<b>4,854,485</b>

## Lower Waihao Supply

Table 9-10: Detailed Maintenance &amp; Operational Expenditure Forecasts: Lower Waihao (figures are inflated)

5140 - Lower Waihao	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Operating Revenue</b>	<b>-499,980</b>	<b>-583,442</b>	<b>-660,872</b>	<b>-720,585</b>	<b>-741,416</b>	<b>-762,768</b>	<b>-784,749</b>	<b>-807,367</b>	<b>-819,947</b>	<b>-832,727</b>	<b>-7,213,853</b>
514001505 - Targeted Rate - Water	-417,308	-500,770	-575,885	-633,474	-652,478	-672,052	-692,214	-712,980	-723,675	-734,529	-6,315,366
514002501 - Works - Application fee	-651	-651	-669	-686	-700	-714	-729	-743	-758	-773	-7,075
514002502 - Works - Connection Fees	-651	-651	-669	-686	-700	-714	-729	-743	-758	-773	-7,075
514005101 - Recoveries - General	-5,426	-5,426	-5,578	-5,717	-5,837	-5,954	-6,073	-6,195	-6,319	-6,445	-58,970
514007101 - Dividend - SC Power	-560	-560	-576	-590	-602	-614	-627	-639	-652	-665	-6,086
514007305 - Internal Interest	-	-	-	-	-	-	-	-	-	-	-
5140081 - Capital Contributions - Water	-4,884	-4,884	-5,021	-5,146	-5,254	-5,359	-5,467	-5,576	-5,687	-5,801	-53,080
5140102 - Internal Water Recoveries	-70,500	-70,500	-72,474	-74,286	-75,844	-77,360	-78,911	-80,490	-82,097	-83,740	-766,201
<b>Operating Expenditure</b>	<b>613,064</b>	<b>682,538</b>	<b>705,090</b>	<b>730,850</b>	<b>736,263</b>	<b>747,807</b>	<b>769,007</b>	<b>767,123</b>	<b>775,298</b>	<b>788,853</b>	<b>7,315,894</b>
5140322 - Advertising and Notices	213	213	219	224	229	234	238	243	248	253	2,315
5140333 - General Expenses	2,000	2,000	2,056	2,107	2,152	2,195	2,239	2,283	2,329	2,376	21,736
5140336 - LAPP Disaster Fund	8,084	9,554	9,822	10,067	10,278	10,484	10,694	10,908	11,126	11,348	102,364
5140356 - Telephone Expenses	3,702	3,702	3,806	3,901	3,983	4,062	4,144	4,227	4,311	4,397	40,234
5140357 - Utilities charges	170,000	204,000	207,910	211,905	215,832	219,640	227,630	227,137	230,809	234,549	2,149,412
514040313 - Depreciation	114,508	159,497	159,536	171,501	172,908	172,908	185,830	187,541	187,541	202,340	1,714,110
514040405 - Internal Interest	-163	4,510	13,337	12,044	8,116	9,429	3,706	-2,615	-2,875	-10,210	35,280
514040406 - Internal Loan - internal interest	102,218	94,464	94,024	95,004	97,279	98,866	99,599	98,755	97,780	95,578	973,565
5140405 - Insurance	12,104	11,315	11,632	11,923	12,173	12,416	12,665	12,918	13,176	13,440	123,762
5140422 - Electricity	25,000	22,000	22,616	23,181	23,668	24,141	24,625	25,117	25,619	26,132	242,098
514042405 - Internal Rent	15,865	18,943	19,453	20,881	21,272	21,284	22,787	22,309	22,117	24,064	208,976
5140425 - Rates	2,121	2,290	2,496	2,558	2,612	2,664	2,718	2,772	2,827	2,884	25,943
5140501 - Asset Mgt Plan	8,995	8,000	8,224	8,430	8,606	8,778	8,954	9,134	9,316	9,502	87,940
5140504 - Consultants	1,034	1,034	1,063	1,090	1,112	1,135	1,157	1,181	1,204	1,228	11,238
5140506 - Contractors	2,126	2,126	2,186	2,240	2,287	2,333	2,380	2,427	2,476	2,525	23,106
5140508 - Line Maintenance	2,000	2,000	2,056	2,107	2,152	2,195	2,239	2,283	2,329	2,376	21,736
5140510 - Operational Maintenance	8,500	8,500	8,738	8,956	9,144	9,327	9,514	9,704	9,898	10,096	92,379
5140511 - Pump Maintenance	2,000	2,000	2,056	2,107	2,152	2,195	2,239	2,283	2,329	2,376	21,736
5140512 - Water Testing	6,017	6,017	6,185	6,340	6,473	6,602	6,735	6,870	7,007	7,254	65,500
5140516 - Operational Contractor system support	8,900	9,400	10,177	10,432	10,650	10,863	11,081	11,303	11,529	11,759	106,094
5140517 - Monitoring consents and compliance	500	500	514	527	538	549	560	571	582	594	5,434

5140520 - Source / Headworks	1,860	1,860	1,912	1,960	2,001	2,041	2,082	2,124	2,166	2,209	20,215
5140601 - HR Costs - 8125	2,921	3,178	4,298	4,943	4,555	4,803	4,780	5,452	4,988	5,243	45,160
514060101 - 8126 - Health & Safety O/H Recoveries	2,770	2,823	2,913	2,999	3,079	3,158	3,233	3,307	3,379	3,566	31,228
5140602 - Corporate Services Costs - 8120	15,972	15,947	17,865	18,538	18,839	19,248	19,580	19,846	20,320	20,416	186,570
5140604 - Utilities Costs - 8140	49,909	34,307	35,306	38,726	37,666	39,016	39,425	39,913	42,421	41,433	398,123
5140606 - Asset Management Unit Costs - 8160	13,630	20,669	21,646	22,096	22,433	23,267	23,669	23,920	24,190	25,035	220,554
5140608 - Network Costs	14,176	15,736	16,357	16,905	16,381	15,784	15,958	16,323	16,928	16,481	161,028
5140609 - CEO & Finance Costs - 8110	10,684	10,722	11,257	11,587	11,859	12,263	12,531	12,758	12,990	13,249	119,899
5140611 - Support - Asset Manager	5,419	5,230	5,432	5,571	5,833	5,929	6,018	6,128	6,239	6,359	58,159
<b>Operating (Surplus) / Deficit</b>	<b>113,084</b>	<b>99,096</b>	<b>44,218</b>	<b>10,265</b>	<b>-5,154</b>	<b>-14,961</b>	<b>-15,741</b>	<b>-40,244</b>	<b>-44,649</b>	<b>-43,874</b>	<b>102,040</b>

Table 9-11: Detailed Capital Expenditure: Lower Waihao (figures are inflated)

Lower Waihao - 5140	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Level of Service</b>	<b>76,000</b>	<b>70,000</b>	-	-	-	-	-	-	-	-	<b>146,000</b>
514076009 - Lower Waihao - Telemetry - Lower Waihao boost renewal	38,000	-	-	-	-	-	-	-	-	-	38,000
514076014 - Lower Waihao - Source / WTP generator	-	70,000	-	-	-	-	-	-	-	-	70,000
514076015 - Lower Waihao - pH Online analysers	38,000	-	-	-	-	-	-	-	-	-	38,000
<b>Renewal</b>	<b>30,000</b>	<b>58,700</b>	<b>13,878</b>	<b>1,581</b>	<b>8,606</b>	<b>5,596</b>	<b>2,910</b>	<b>5,709</b>	-	-	<b>126,980</b>
514076001 - Lower Waihao - Renewals	28,000	13,000	13,878	1,581	6,455	5,596	1,679	5,709	-	-	75,897
514076007 - Lower Waihao - Lower Waihao Reservoir telemetry renewal	2,000	-	-	-	2,152	-	-	-	-	-	4,152
514076008 - Lower Waihao - Lower Waihao boost pump 3 renewal	-	5,500	-	-	-	-	-	-	-	-	5,500
514076010 - Lower Waihao - Flow meter renewal	-	6,200	-	-	-	-	1,231	-	-	-	7,431
514076017 - Lower Waihao - Booster generator	-	34,000	-	-	-	-	-	-	-	-	34,000
<b>Renewal/ Level of Service</b>	<b>145,100</b>	<b>80,000</b>	-	-	<b>129,096</b>	-	-	<b>157,555</b>	-	<b>166,292</b>	<b>678,043</b>
514076004 - Lower Waihao - Glenavy Township mains renewal	-	70,000	-	-	111,130	-	-	137,004	-	144,555	462,689
514076005 - Lower Waihao - Glenavy Township restrictor renewal	-	10,000	-	-	17,966	-	-	20,551	-	21,737	70,253
514076012 - Lower Waihao - Glenavy line renewal	145,100	-	-	-	-	-	-	-	-	-	145,100
<b>Total Capital Expenditure</b>	<b>251,100</b>	<b>208,700</b>	<b>13,878</b>	<b>1,581</b>	<b>137,702</b>	<b>5,596</b>	<b>2,910</b>	<b>163,263</b>	-	<b>166,292</b>	<b>951,022</b>

**Otaio / Makikihi Supply**

**Table 9-12: Detailed Maintenance & Operational Expenditure: Otaio / Makikihi (figures are inflated)**

5150 - Otaio/Makikihi	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Operating Revenue</b>	<b>-379,592</b>	<b>-416,966</b>	<b>-428,129</b>	<b>-448,528</b>	<b>-453,892</b>	<b>-459,991</b>	<b>-477,962</b>	<b>-484,147</b>	<b>-498,862</b>	<b>-516,236</b>	<b>-4,564,305</b>
515001505 - Targeted Rate - Water	-371,374	-400,601	-414,142	-432,965	-436,649	-449,396	-461,821	-469,057	-485,062	-502,706	-4,423,772
515002501 - Works - Application fee	-547	-1,000	-1,028	-1,054	-1,076	-1,097	-1,119	-1,142	-1,165	-1,188	-10,415
515005101 - Recoveries - General	-2,713	-4,000	-4,112	-4,215	-4,303	-4,389	-4,477	-4,567	-4,658	-4,751	-42,185
515007101 - Dividend - SC Power	-475	-475	-488	-501	-511	-521	-532	-542	-553	-564	-5,162
515007305 - Internal Interest	-1,769	-890	1,921	743	-595	6,386	1,181	2,578	4,220	4,851	18,624
5150081 - Capital Contributions - Water	-2,713	-10,000	-10,280	-10,537	-10,758	-10,973	-11,193	-11,417	-11,645	-11,878	-101,394
<b>Operating Expenditure</b>	<b>412,903</b>	<b>416,966</b>	<b>428,129</b>	<b>448,528</b>	<b>453,892</b>	<b>459,991</b>	<b>477,962</b>	<b>484,147</b>	<b>498,862</b>	<b>516,236</b>	<b>4,597,616</b>
5150322 - Advertising and Notices	213	213	219	224	229	234	238	243	248	253	2,315
5150333 - General Expenses	803	803	825	846	864	881	899	917	935	954	8,727
5150336 - LAPP Disaster Fund	6,872	8,122	8,349	8,558	8,738	8,912	9,091	9,273	9,458	9,647	87,021
5150356 - Telephone expenses	1,594	1,594	1,639	1,680	1,715	1,749	1,784	1,820	1,856	1,893	17,324
5150357 - Utilities charges	72,000	86,400	88,056	89,748	91,411	93,024	96,408	96,199	97,754	99,338	910,339
5150358 - Vehicle Costs	120	120	123	126	129	132	134	137	140	143	1,304
515040303 - Depreciation - Plant & Machinery	1,499	1,199	959	768	614	491	393	314	252	201	6,691
515040313 - Depreciation	119,300	117,871	118,525	128,049	129,845	129,922	139,395	141,993	141,993	152,224	1,319,118
515040406 - Internal Loan - internal interest	-	-	-	-	-	-	-	-	7,785	8,908	16,693
5150405 - Insurance	11,500	8,581	8,821	9,042	9,231	9,416	9,605	9,797	9,993	10,193	96,178
5150422 - Electricity	51,000	51,000	52,428	53,739	54,866	55,962	57,084	58,227	59,390	60,578	554,273
515042405 - Internal Rent	15,865	18,943	19,453	20,881	21,272	21,284	22,787	22,309	22,117	24,064	208,976
5150425 - Rates	2,874	3,104	3,382	3,467	3,539	3,610	3,683	3,756	3,831	3,908	35,154
5150501 - Asset Mgt Plan	9,633	7,000	7,196	7,376	7,531	7,681	7,835	7,992	8,152	8,315	78,710
5150504 - Consultants	1,551	1,551	1,594	1,634	1,669	1,702	1,736	1,771	1,806	1,842	16,856
5150506 - Contractors	1,594	1,594	1,639	1,680	1,715	1,749	1,784	1,820	1,856	1,893	17,324
5150508 - Line Maintenance	2,000	2,000	2,056	2,107	2,152	2,195	2,239	2,283	2,329	2,376	21,736
5150510 - Operational Maintenance	3,619	3,619	3,720	3,813	3,893	3,971	4,051	4,132	4,214	4,299	39,332
5150511 - Pump Maintenance	2,126	2,126	2,186	2,240	2,287	2,333	2,380	2,427	2,476	2,525	23,106
5150512 - Water Testing	8,000	8,000	8,224	8,430	8,606	8,778	8,954	9,134	9,316	9,502	86,945
5150516 - Operational Contractor system support	6,000	6,300	6,785	6,954	7,100	7,242	7,387	7,535	7,686	7,839	70,829
5150517 - Monitoring consents and compliance	700	700	720	738	753	768	784	799	815	831	7,608
5150520 - Source / Headworks	1,059	1,059	1,089	1,116	1,139	1,162	1,185	1,209	1,233	1,258	11,509

5150601 - HR Costs - 8125	2,293	2,495	3,374	3,881	3,576	3,771	3,753	4,281	3,916	4,116	35,456
515060101 - 8126 - Health & Safety O/H Recoveries	2,175	2,216	2,287	2,355	2,418	2,479	2,538	2,596	2,653	2,800	24,518
5150602 - Corporate Services Costs - 8120	13,308	13,287	14,886	15,446	15,697	16,037	16,315	16,536	16,931	17,011	155,454
5150604 - Utilities Costs - 8140	43,255	29,733	30,599	33,564	32,644	33,815	34,169	34,592	36,766	35,909	345,048
5150606 - Asset Management Unit Costs - 8160	8,217	12,461	13,050	13,321	13,524	14,027	14,269	14,420	14,583	15,093	132,966
5150608 - Network Costs	11,216	12,450	12,941	13,375	12,961	12,489	12,626	12,915	13,393	13,040	127,406
5150609 - CEO & Finance Costs - 8110	8,902	8,934	9,379	9,654	9,881	10,218	10,441	10,630	10,823	11,039	99,903
5150611 - Support - Asset Manager	3,615	3,489	3,624	3,717	3,891	3,955	4,015	4,088	4,162	4,242	38,798
<b>Operating (Surplus) / Deficit</b>	<b>33,311</b>	<b>0</b>	<b>-0</b>	<b>-0</b>	<b>0</b>	<b>-0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>-0</b>	<b>33,311</b>

Table 9-13: Detailed Capital Expenditure: Otaio / Makikihi (figures are inflated)

Otaio Makikihi - 5150	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Level of Service</b>	<b>89,000</b>	<b>34,000</b>	-	-	-	-	-	-	-	-	<b>123,000</b>
515076013 - Otaio / Makikihi - pH Online analysers	38,000	-	-	-	-	-	-	-	-	-	38,000
515076014 - Otaio / Makikihi - Source / WTP generator	51,000	34,000	-	-	-	-	-	-	-	-	85,000
<b>Renewal</b>	<b>24,000</b>	<b>14,400</b>	<b>23,644</b>	<b>26,343</b>	<b>105,428</b>	<b>20,849</b>	<b>166,776</b>	<b>150,935</b>	<b>173,511</b>	<b>510,754</b>	<b>1,216,639</b>
515076002 - Otaio / Makikihi - Renewals	19,000	13,000	8,224	26,343	105,428	20,849	161,179	150,935	173,511	510,754	1,189,222
515076009 - Otaio / Makikihi - Flow meter replacement	5,000	1,400	-	-	-	-	5,597	-	-	-	11,997
515076011 - Otaio / Makikihi - Consent volume review	-	-	15,420	-	-	-	-	-	-	-	15,420
<b>Renewal/Level of Service</b>	<b>-</b>	<b>145,250</b>	<b>67,077</b>	<b>68,754</b>	<b>174,979</b>	<b>-</b>	<b>-</b>	<b>171,940</b>	<b>-</b>	<b>-</b>	<b>628,000</b>
515076005 - Otaio / Makikihi - Makikihi township mains renewal	-	135,250	67,077	68,754	163,791	-	-	157,555	-	-	592,426
515076006 - Otaio / Makikihi - Makikihi township restrictor renewal	-	10,000	-	-	11,188	-	-	14,385	-	-	35,574
<b>Total Capital Expenditure</b>	<b>113,000</b>	<b>193,650</b>	<b>90,721</b>	<b>95,096</b>	<b>280,407</b>	<b>20,849</b>	<b>166,776</b>	<b>322,875</b>	<b>173,511</b>	<b>510,754</b>	<b>1,967,639</b>

## Waihaorunga Supply

Table 9-14: Detailed Maintenance &amp; Operational Expenditure: Waihaorunga (figures are inflated)

5160 - Waihaorunga	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Operating Revenue</b>	<b>-193,911</b>	<b>-232,643</b>	<b>-279,129</b>	<b>-307,020</b>	<b>-337,702</b>	<b>-341,081</b>	<b>-344,495</b>	<b>-341,066</b>	<b>-346,058</b>	<b>-350,391</b>	<b>-3,073,495</b>
516001505 - Targeted Rate - Water	-193,658	-232,390	-278,868	-306,754	-337,430	-340,804	-344,212	-340,778	-345,763	-350,090	-3,070,746
516007101 - Dividend - SC Power	-253	-253	-260	-267	-272	-278	-283	-289	-295	-301	-2,750
<b>Operating Expenditure</b>	<b>199,345</b>	<b>239,565</b>	<b>301,026</b>	<b>314,429</b>	<b>323,055</b>	<b>328,761</b>	<b>336,065</b>	<b>341,066</b>	<b>346,058</b>	<b>350,391</b>	<b>3,079,760</b>
5160322 - Advertising and Notices	213	213	219	224	229	234	238	243	248	253	2,315
5160333 - General Expenses	531	531	546	560	571	583	594	606	618	631	5,771
5160336 - LAPP Disaster Fund	4,128	4,879	5,016	5,141	5,249	5,354	5,461	5,570	5,682	5,795	52,274
5160356 - Telephone Expenses	127	127	131	134	137	139	142	145	148	151	1,380
5160357 - Utilities charges	44,000	52,800	53,812	54,846	55,862	56,848	58,916	58,788	59,739	60,707	556,318
516040313 - Depreciation	26,579	59,739	62,956	65,066	66,447	66,687	68,744	72,257	72,512	74,730	635,718
516040405 - Internal Interest	5,788	5,617	971	1,212	5,434	6,700	7,075	7,483	9,289	9,955	59,524
516040406 - Internal interest - Internal loans	-	-	56,565	61,118	62,135	62,669	62,622	61,553	60,377	58,426	485,465
5160405 - Insurance	3,251	2,404	2,471	2,533	2,586	2,638	2,691	2,745	2,799	2,855	26,974
5160422 - Electricity	19,000	19,000	19,532	20,020	20,440	20,849	21,267	21,692	22,126	22,568	206,494
516042405 - Internal Rent	7,967	9,512	9,767	10,483	10,680	10,685	11,439	11,200	11,103	12,080	104,917
5160425 - Rates	671	725	790	809	826	843	860	877	894	912	8,207
5160501 - Asset Mgt Plan	5,614	5,614	5,771	5,915	6,040	6,160	6,284	6,410	6,538	6,668	61,014
5160504 - Consultants	1,135	1,135	1,167	1,196	1,221	1,245	1,270	1,296	1,322	1,348	12,335
5160506 - Contractors	2,551	2,551	2,622	2,688	2,744	2,799	2,855	2,912	2,971	3,030	27,725
5160508 - Line Maintenance	1,000	1,000	1,028	1,054	1,076	1,097	1,119	1,142	1,165	1,188	10,868
5160510 - Operational Maintenance	1,654	1,654	1,700	1,743	1,779	1,815	1,851	1,888	1,926	1,965	17,976
5160511 - Pump Maintenance	1,063	1,063	1,093	1,120	1,144	1,166	1,190	1,214	1,238	1,263	11,553
5160512 - Water Testing	7,100	7,100	7,299	7,481	7,638	7,791	7,947	8,106	8,268	8,433	77,164
5160516 - Operational Contractor system support	2,800	3,000	3,187	3,266	3,335	3,402	3,470	3,539	3,610	3,682	33,291
5160517 - Monitoring consents and compliance	800	800	822	843	861	878	895	913	932	950	8,694
5160520 - Source / Headworks	1,000	1,000	1,028	1,054	1,076	1,097	1,119	1,142	1,165	1,188	10,868
5160601 - HR Costs - 8125	1,593	1,734	2,344	2,696	2,485	2,620	2,607	2,974	2,721	2,860	24,633
516060101 - 8126 - Health & Safety O/H Recoveries	1,511	1,540	1,589	1,636	1,680	1,723	1,763	1,804	1,843	1,945	17,033
5160602 - Corporate Services Costs - 8120	7,600	7,588	8,501	8,821	8,964	9,159	9,317	9,444	9,669	9,715	88,777
5160604 - Utilities Costs - 8140	26,967	18,537	19,077	20,925	20,352	21,081	21,302	21,566	22,921	22,387	215,114

5160606 - Asset Management Unit Costs - 8160	8,238	12,493	13,084	13,356	13,559	14,063	14,307	14,458	14,621	15,132	133,312
5160608 - Network Costs	7,764	8,619	8,959	9,259	8,972	8,645	8,740	8,940	9,271	9,027	88,196
5160609 - CEO & Finance Costs - 8110	5,084	5,102	5,356	5,513	5,643	5,835	5,963	6,071	6,181	6,304	57,052
5160611 - Support - Asset Manager	3,615	3,489	3,624	3,717	3,891	3,955	4,015	4,088	4,162	4,242	38,798
<b>Operating (Surplus) / Deficit</b>	<b>5,434</b>	<b>6,922</b>	<b>21,897</b>	<b>7,409</b>	<b>-14,647</b>	<b>-12,320</b>	<b>-8,430</b>	<b>-0</b>	<b>-0</b>	<b>-0</b>	<b>6,265</b>

Figure 9-6: Detailed Capital Expenditure: Waihaorunga (figures are inflated)

Waihaorunga - 5160	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Level of Service</b>	-	<b>64,000</b>	<b>30,840</b>	-	-	-	-	-	-	-	<b>94,840</b>
516076006 - Waihaorunga - Chlorine and turbidity analyser	-	-	30,840	-	-	-	-	-	-	-	30,840
516076007 - Waihaorunga - Source / WTP generator	-	47,000	-	-	-	-	-	-	-	-	47,000
516076008 - Waihaorunga - Melford reservoir telemetry	-	17,000	-	-	-	-	-	-	-	-	17,000
<b>Renewal</b>	<b>42,000</b>	<b>25,000</b>	<b>23,644</b>	<b>100,102</b>	<b>54,005</b>	<b>33,138</b>	<b>33,803</b>	<b>55,601</b>	<b>35,168</b>	<b>35,872</b>	<b>438,332</b>
516076001 - Waihaorunga - Renewals	13,000	25,000	23,644	100,102	21,516	-	-	-	-	-	183,262
516076002 - Waihaorunga - Pump replacements	29,000	-	-	-	32,489	33,138	33,803	55,601	35,168	35,872	255,071
<b>Renewal/ Level of Service</b>	-	<b>1,200,000</b>	<b>46,260</b>	-	-	-	-	-	-	-	<b>1,246,260</b>
516076003 - Waihaorunga - Drinking water compliance upgrade	-	1,200,000	-	-	-	-	-	-	-	-	1,200,000
516076005 - Waihaorunga - New board and telemetry	-	-	46,260	-	-	-	-	-	-	-	46,260
<b>Total Capital Expenditure</b>	<b>42,000</b>	<b>1,289,000</b>	<b>100,744</b>	<b>100,102</b>	<b>54,005</b>	<b>33,138</b>	<b>33,803</b>	<b>55,601</b>	<b>35,168</b>	<b>35,872</b>	<b>1,779,432</b>

Section 9: Financial Summary

**Waikakahi Supply**

**Table 9-15: Detailed Maintenance & Operational Expenditure: Waikakahi (figures are inflated)**

5170 - Waikakahi	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Operating Revenue</b>	<b>-578,584</b>	<b>-628,095</b>	<b>-665,774</b>	<b>-714,875</b>	<b>-740,557</b>	<b>-756,754</b>	<b>-761,397</b>	<b>-772,651</b>	<b>-779,503</b>	<b>-790,351</b>	<b>-7,188,540</b>
517001505 - Targeted Rate - Water	-545,691	-600,260	-660,286	-709,808	-734,651	-749,344	-751,833	-759,745	-765,569	-794,206	-7,071,393
517002501 - Works - Application fee	-325	-325	-334	-342	-350	-357	-364	-371	-378	-386	-3,532
517005101 - Recoveries - General	-6,512	-3,000	-3,084	-3,161	-3,227	-3,292	-3,358	-3,425	-3,494	-3,563	-36,116
517007101 - Dividend - SC Power	-813	-813	-836	-857	-875	-892	-910	-928	-947	-966	-8,836
517007305 - Internal Interest	-24,591	-23,045	-565	-21	-754	-2,155	-4,204	-7,438	-8,357	9,544	-61,587
5170081 - Capital Contributions - Water	-651	-651	-669	-686	-700	-714	-729	-743	-758	-773	-7,075
<b>Operating Expenditure</b>	<b>508,470</b>	<b>600,197</b>	<b>703,103</b>	<b>724,320</b>	<b>737,037</b>	<b>745,049</b>	<b>761,397</b>	<b>772,651</b>	<b>779,503</b>	<b>790,351</b>	<b>7,122,077</b>
5170322 - Advertising and Notices	213	213	219	224	229	234	238	243	248	253	2,315
5170333 - General Expenses	1,000	1,000	1,028	1,054	1,076	1,097	1,119	1,142	1,165	1,188	10,868
5170336 - LAPP Disaster Fund	9,705	11,469	11,790	12,085	12,338	12,585	12,837	13,094	13,356	13,623	122,882
5170356 - Telephone expenses	4,400	4,400	4,523	4,636	4,734	4,828	4,925	5,023	5,124	5,226	47,820
5170357 - Utilities charges	79,000	94,800	96,617	98,474	100,298	102,068	105,781	105,552	107,258	108,996	998,844
517040313 - Depreciation	86,878	174,021	174,088	180,741	188,415	188,452	195,475	203,851	203,851	211,428	1,807,198
517040406 - Internal Loan - internal interest	-	-	87,571	86,369	86,150	85,094	83,098	79,629	75,930	71,185	655,027
5170405 - Insurance	7,716	5,685	5,844	5,990	6,116	6,238	6,363	6,491	6,620	6,753	63,816
5170422 - Electricity	70,000	70,000	71,960	73,759	75,306	76,811	78,351	79,919	81,515	83,146	760,767
517042201 - Electricity - Hurst Tank 17 Supply	558	558	574	588	600	612	625	637	650	663	6,064
517042405 - Internal Rent	15,865	18,943	19,453	20,881	21,272	21,284	22,787	22,309	22,117	24,064	208,976
5170425 - Rates	2,334	2,521	2,747	2,815	2,875	2,932	2,991	3,051	3,112	3,174	28,551
5170501 - Asset Mgt Plan	8,357	7,000	7,196	7,376	7,531	7,681	7,835	7,992	8,152	8,315	77,434
5170504 - Consultants	1,063	1,063	1,093	1,120	1,144	1,166	1,190	1,214	1,238	1,263	11,553
5170506 - Contractor - Other	1,126	1,126	1,158	1,186	1,211	1,236	1,260	1,286	1,311	1,337	12,237
5170508 - Line Maintenance	1,500	1,500	1,542	1,581	1,614	1,646	1,679	1,713	1,747	1,782	16,302
5170510 - Operational Maintenance	1,500	1,500	1,542	1,581	1,614	1,646	1,679	1,713	1,747	1,782	16,302
5170511 - Pump Maintenance	1,000	1,000	1,028	1,054	1,076	1,097	1,119	1,142	1,165	1,188	10,868
5170512 - Water Testing	5,000	5,000	5,140	5,269	5,379	5,487	5,597	5,709	5,823	5,939	54,341
5170514 - Water purchases	70,500	70,500	72,474	74,286	75,844	77,360	78,911	80,490	82,097	83,740	766,201
5170516 - Operational Contractor system support	5,600	5,900	6,374	6,533	6,670	6,803	6,940	7,079	7,220	7,364	66,482
5170517 - Monitoring consents and compliance	700	700	720	738	753	768	784	799	815	831	7,608
5170520 - Source / Headworks	1,994	1,994	2,050	2,101	2,145	2,188	2,232	2,277	2,322	2,368	21,671
5170601 - HR Costs - 8125	3,257	3,543	4,791	5,510	5,078	5,355	5,329	6,079	5,561	5,845	50,348



517060101 - 8126 - Health & Safety O/H Recoveries	3,088	3,147	3,247	3,344	3,433	3,521	3,604	3,687	3,768	3,976	34,815
5170602 - Corporate Services Costs - 8120	18,538	18,509	20,736	21,516	21,865	22,340	22,726	23,035	23,585	23,696	216,544
5170604 - Utilities Costs - 8140	65,328	44,906	46,214	50,691	49,302	51,070	51,605	52,245	55,527	54,234	521,121
5170606 - Asset Management Unit Costs - 8160	10,189	15,452	16,183	16,519	16,771	17,394	17,695	17,882	18,084	18,716	164,884
5170608 - Network Costs	16,046	17,812	18,515	19,136	18,543	17,867	18,063	18,477	19,162	18,656	182,279
5170609 - CEO & Finance Costs - 8110	12,400	12,445	13,065	13,448	13,764	14,233	14,544	14,807	15,076	15,377	139,162
5170611 - Support - Asset Manager	3,615	3,489	3,624	3,717	3,891	3,955	4,015	4,088	4,162	4,242	38,798
<b>Operating (Surplus) / Deficit</b>	<b>-70,114</b>	<b>-27,898</b>	<b>37,329</b>	<b>9,445</b>	<b>-3,520</b>	<b>-11,705</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>-0</b>	<b>-66,463</b>

Figure 9-7: Detailed Capital Expenditure: Waikakahi (figures are inflated)

Waikakahi - 5170	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Level of Service</b>	<b>38,000</b>	<b>79,000</b>	-	-	-	-	-	-	-	-	<b>117,000</b>
517076019 - Waikakahi - Source / WTP generator	-	79,000	-	-	-	-	-	-	-	-	79,000
517076020 - Waikakahi - pH Online analysers	38,000	-	-	-	-	-	-	-	-	-	38,000
<b>Renewal</b>	<b>35,000</b>	<b>38,600</b>	<b>49,344</b>	<b>46,363</b>	<b>51,638</b>	<b>46,635</b>	<b>14,551</b>	-	<b>480,939</b>	<b>492,937</b>	<b>1,256,007</b>
517076001 - Waikakahi - Renewals	35,000	22,000	31,354	37,933	51,638	24,689	14,551	-	480,939	492,937	1,191,041
517076015 - Waikakahi - Telemetry Waikakahi Reservoir	-	-	-	8,430	-	-	-	-	-	-	8,430
517076016 - Waikakahi - Pump renewals	-	13,000	17,990	-	-	-	-	-	-	-	30,990
517076017 - Waikakahi - Flow meter renewals	-	3,600	-	-	-	-	-	-	-	-	3,600
517076022 - Waikakahi - Consenting	-	-	-	-	-	21,946	-	-	-	-	21,946
<b>Renewal/ Level of Service</b>	-	<b>2,900,000</b>	-	-	-	-	-	<b>82,202</b>	-	-	<b>2,982,202</b>
517076003 - Waikakahi - Drinking water compliance upgrade	-	2,900,000	-	-	-	-	-	-	-	-	2,900,000
517076021 - Waikakahi - Dog Kennel Road renewals 2,719m	-	-	-	-	-	-	-	82,202	-	-	82,202
<b>Total Capital Expenditure</b>	<b>73,000</b>	<b>3,017,600</b>	<b>49,344</b>	<b>46,363</b>	<b>51,638</b>	<b>46,635</b>	<b>14,551</b>	<b>82,202</b>	<b>480,939</b>	<b>492,937</b>	<b>4,355,209</b>

Section 9: Financial Summary

**Waimate Urban Supply**

**Table 9-16: Detailed Maintenance & Operational Expenditure: Waimate Urban (figures are inflated)**

5310 - Waimate Urban	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Operating Revenue</b>	<b>-1,308,996</b>	<b>-1,434,073</b>	<b>-1,573,289</b>	<b>-1,650,457</b>	<b>-1,731,198</b>	<b>-1,815,878</b>	<b>-1,904,758</b>	<b>-1,942,855</b>	<b>-1,981,708</b>	<b>-2,040,483</b>	<b>17,383,695</b>
531001505 - Targeted Rate - Water	-1,250,771	-1,375,848	-1,513,434	-1,589,105	-1,668,559	-1,751,987	-1,839,587	-1,876,379	-1,913,905	-1,971,324	16,750,900
531002501 - Works - Application fee	-1,085	-1,085	-1,115	-1,143	-1,167	-1,191	-1,214	-1,239	-1,263	-1,289	-11,792
531002503 - Works - Metered Supply Charges	-16,279	-16,279	-16,735	-17,153	-17,513	-17,863	-18,221	-18,586	-18,957	-19,336	-176,922
531007101 - Dividend - SC Power	-1,499	-1,499	-1,541	-1,580	-1,613	-1,645	-1,678	-1,711	-1,746	-1,781	-16,291
5310081 - Capital Contributions - Water	-11,942	-11,942	-12,276	-12,583	-12,847	-13,104	-13,367	-13,634	-13,906	-14,185	-129,787
5310102 - Internal Water Recoveries	-28,000	-28,000	-28,784	-29,504	-30,122	-30,724	-31,340	-31,968	-32,606	-33,258	-304,307
531041202 - Rates Remissions	580	580	596	611	624	636	649	662	675	689	6,303
<b>Operating Expenditure</b>	<b>1,364,401</b>	<b>1,504,519</b>	<b>1,573,137</b>	<b>1,654,418</b>	<b>1,729,148</b>	<b>1,811,304</b>	<b>1,890,280</b>	<b>1,920,560</b>	<b>1,961,918</b>	<b>2,024,285</b>	<b>17,433,970</b>
5310322 - Advertising and Notices	531	531	546	560	571	583	594	606	618	631	5,771
531033103 - Computer Support	2,895	2,895	2,976	3,050	3,114	3,177	3,240	3,305	3,371	3,439	31,463
5310333 - General Expenses	8,000	8,000	8,224	8,430	8,606	8,778	8,954	9,134	9,316	9,502	86,945
5310336 - LAPP Disaster Fund	16,797	19,851	20,407	20,917	21,356	21,783	22,219	22,664	23,116	23,579	212,689
5310356 - Telephone expenses	2,171	2,171	2,232	2,288	2,336	2,382	2,430	2,479	2,528	2,579	23,595
5310357 - Utilities Charges	180,000	216,000	220,140	224,370	228,528	232,560	241,020	240,498	244,386	248,346	2,275,848
531040302 - Depreciation - Buildings	82	91	91	105	105	105	120	120	120	138	1,077
531040303 - Depreciation - Plant & Machinery	1,489	802	722	650	585	526	473	426	384	345	6,402
531040305 - Depn - Office Equipment	2,423	1,939	1,551	1,241	993	794	635	508	407	325	10,816
531040313 - Depreciation	415,034	456,122	456,417	501,652	517,583	517,583	554,169	558,990	558,990	598,502	5,135,042
531040319 - Amorisation on intangible assets	-	16,617	13,294	10,635	8,508	6,806	5,445	4,356	3,485	2,788	71,934
531040405 - Internal Interest	1,985	-1,115	415	5,036	608	4,066	491	173	1,220	594	13,474
531040406 - Waimate Urban Water - Internal Loan interest	200,596	275,210	316,866	320,991	379,946	444,309	471,940	488,684	510,200	522,661	3,931,403
5310405 - Insurance	18,362	14,098	14,493	14,855	15,167	15,470	15,780	16,096	16,417	16,746	157,482
5310422 - Electricity	90,000	90,000	92,520	94,833	96,822	98,757	100,737	102,753	104,805	106,902	978,129
531042405 - Internal Rent	23,714	28,321	29,082	31,220	31,807	31,825	34,074	33,359	33,071	35,986	312,459
5310425 - Rates	13,812	14,917	16,255	16,661	17,011	17,351	17,698	18,053	18,413	18,781	168,951
5310501 - Asset Mgt Plan	9,563	9,563	9,831	10,077	10,288	10,493	10,704	10,918	11,136	11,359	103,932
5310504 - Consultants	3,000	3,000	3,084	3,161	3,227	3,292	3,358	3,425	3,494	3,563	32,604
5310506 - Contractors	5,000	5,000	5,140	5,269	5,379	5,487	5,597	5,709	5,823	5,939	54,341
5310508 - Line Maintenance	2,000	2,000	2,056	2,107	2,152	2,195	2,239	2,283	2,329	2,376	21,736
5310510 - Operational Maintenance	8,000	8,000	8,224	8,430	8,606	8,778	8,954	9,134	9,316	9,502	86,945

Section 9: Financial Summary

5310511 - Pump Maintenance	2,000	2,000	2,056	2,107	2,152	2,195	2,239	2,283	2,329	2,376	21,736
5310512 - Water Testing	9,978	9,978	10,257	10,514	10,734	10,949	11,168	11,392	11,619	11,852	108,442
5310516 - Operational Contractor system support	12,600	13,300	14,289	14,646	14,954	15,252	15,558	15,870	16,187	16,510	149,167
5310517 - Monitoring consents and compliance	2,000	2,000	2,056	2,107	2,152	2,195	2,239	2,283	2,329	2,376	21,736
5310601 - HR Costs - 8125	8,177	8,896	12,030	13,835	12,751	13,445	13,379	15,262	13,961	14,675	126,411
531060101 - 8126 - Health & Safety O/H Recoveries	7,753	7,902	8,153	8,396	8,619	8,840	9,050	9,257	9,459	9,983	87,412
5310602 - Corporate Services Costs - 8120	31,682	31,633	35,439	36,772	37,369	38,181	38,841	39,368	40,308	40,499	370,093
5310604 - Utilities Costs - 8140	163,590	112,451	115,726	126,937	123,461	127,888	129,227	130,828	139,048	135,809	1,304,965
5310606 - Asset Management Unit Costs - 8160	33,874	51,369	53,798	54,915	55,753	57,825	58,825	59,448	60,119	62,220	548,145
5310608 - Network Costs	40,814	45,306	47,094	48,673	47,165	45,446	45,945	46,997	48,738	47,452	463,630
5310609 - CEO & Finance Costs - 8110	21,193	21,269	22,330	22,985	23,524	24,326	24,858	25,307	25,767	26,282	237,840
5310611 - Support - Asset Manager	25,285	24,403	25,344	25,995	27,217	27,664	28,080	28,591	29,108	29,669	271,357
<b>Operating (Surplus) / Deficit</b>	<b>55,405</b>	<b>70,446</b>	<b>-152</b>	<b>3,961</b>	<b>-2,050</b>	<b>-4,574</b>	<b>-14,478</b>	<b>-22,295</b>	<b>-19,790</b>	<b>-16,198</b>	<b>50,275</b>

Table 9-17: Detailed Capital Expenditure: Waimate Urban (figures are inflated)

5310 - Waimate Urban	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Growth</b>	<b>1,248,000</b>	<b>708,000</b>	-	<b>568,000</b>	<b>568,000</b>	-	-	-	-	-	<b>3,092,000</b>
531076024 - Urban Water - Booster Bakers/Court/Hunts/Fitzmaurice Road	540,000	-	-	-	-	-	-	-	-	-	540,000
531076025 - Urban Water - Extension Bakers/Court/Hunts/Fitzmaurice Road	-	-	-	568,000	568,000	-	-	-	-	-	1,136,000
531076028 - Urban Water - Te Kiteroa Main, Booster and Reservoir	708,000	708,000	-	-	-	-	-	-	-	-	1,416,000
<b>Level of Service</b>	<b>108,000</b>	<b>165,000</b>	<b>10,280</b>	<b>347,721</b>	<b>290,466</b>	-	-	-	-	-	<b>921,467</b>
531076001 - Urban Water - Rising main renewals Queen Street	-	165,000	-	-	-	-	-	-	-	-	165,000
531076031 - Urban Water - Manchester's treatment plant generator	47,000	-	-	-	-	-	-	-	-	-	47,000
531076033 - Urban Water - Timaru Road treatment plant generator	61,000	-	-	-	-	-	-	-	-	-	61,000
531076034 - Urban Water - Pressure management High Street rising mains	-	-	10,280	284,499	290,466	-	-	-	-	-	585,245
531076035 - Urban Water - Pressure management Queen/High Street	-	-	-	63,222	-	-	-	-	-	-	63,222
<b>Renewal</b>	<b>559,000</b>	<b>358,000</b>	<b>384,472</b>	<b>378,278</b>	<b>679,906</b>	<b>675,388</b>	<b>692,847</b>	<b>817,457</b>	<b>715,003</b>	<b>780,385</b>	<b>6,040,736</b>
531076001 - Urban Water - Rising main renewals	358,000	358,000	383,444	377,225	660,541	673,742	687,250	701,004	715,003	729,309	5,643,518
531076003 - Urban Water - AC water main renewals	58,000	-	1,028	1,054	19,364	1,646	5,597	-	-	33,258	119,947
531076004 - Urban Water - CI water main renewals	-	-	-	-	-	-	-	116,453	-	-	116,453
531076008 - Urban Water - Timaru Road pump renewals	43,000	-	-	-	-	-	-	-	-	-	43,000
531076021 - Urban Water - Waimate Reservoir cover replacement	100,000	-	-	-	-	-	-	-	-	-	100,000
531076033 - Urban Water - Resource consenting	-	-	-	-	-	-	-	-	-	17,817	17,817
<b>Renewal/Level of Service</b>	<b>-</b>	<b>70,000</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>70,000</b>
531078002 - Urban Water - Software and code upgrades	-	70,000	-	-	-	-	-	-	-	-	70,000
<b>Total Capital Expenditure</b>	<b>1,915,000</b>	<b>1,301,000</b>	<b>394,752</b>	<b>1,293,999</b>	<b>1,538,372</b>	<b>675,388</b>	<b>692,847</b>	<b>817,457</b>	<b>715,003</b>	<b>780,385</b>	<b>10,124,203</b>

**Other Rural Schemes**

**Table 9-18: Detailed Maintenance & Operational Expenditure: Cattle Creek (figures are inflated)**

5120 - Cattle Creek	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Operating Revenue</b>	<b>-2,064</b>	<b>-2,064</b>	<b>-2,064</b>	<b>-2,064</b>	<b>-2,064</b>	<b>-2,064</b>	<b>-2,064</b>	<b>-2,064</b>	<b>-2,064</b>	<b>-2,064</b>	<b>-20,643</b>
5120011 - General Rates	-1,139	-1,079	-1,037	-1,002	-1,184	-1,142	-1,095	-1,044	-998	-954	-10,674
512007305 - Internal Interest Income	107	47	5	-31	152	110	63	12	-34	-78	353
Total Operating Revenue	-1,032	-1,032	-1,032	-1,032	-1,032	-1,032	-1,032	-1,032	-1,032	-1,032	-10,321
<b>Operating Expenditure</b>	<b>1,032</b>	<b>1,032</b>	<b>1,032</b>	<b>1,032</b>	<b>1,032</b>	<b>1,032</b>	<b>1,032</b>	<b>1,032</b>	<b>1,032</b>	<b>1,032</b>	<b>10,321</b>
512040313 - Depreciation	1,032	1,032	1,032	1,032	1,032	1,032	1,032	1,032	1,032	1,032	10,321
512040405 - Internal Interest	-	-	-	-	-	-	-	-	-	-	-
<b>Operating (Surplus) / Deficit</b>	<b>-1,032</b>	<b>-1,032</b>	<b>-1,032</b>	<b>-1,032</b>	<b>-1,032</b>	<b>-1,032</b>	<b>-1,032</b>	<b>-1,032</b>	<b>-1,032</b>	<b>-1,032</b>	<b>-10,321</b>

**Table 9-19: Detailed Maintenance & Operational Expenditure: Downlands (figures are inflated)**

5210 - JV - Downlands	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Operating Revenue</b>	<b>- 506,536</b>	<b>- 495,659</b>	<b>- 513,517</b>	<b>- 528,808</b>	<b>- 556,670</b>	<b>- 602,430</b>	<b>- 590,813</b>	<b>- 593,371</b>	<b>- 614,932</b>	<b>- 618,534</b>	<b>- 5,621,271</b>
521001505 - Targeted Rate - Water	- 430,787	- 418,243	- 434,321	- 447,794	- 473,876	- 517,893	- 504,588	- 505,418	- 525,306	- 527,203	- 4,785,428
5210075 - Sundry Sales	- 75,750	- 77,416	- 79,196	- 81,014	- 82,794	- 84,536	- 86,226	- 87,953	- 89,627	- 91,331	- 835,843
<b>Operating Expenditure</b>	<b>506,536</b>	<b>495,659</b>	<b>513,517</b>	<b>528,807</b>	<b>556,670</b>	<b>602,430</b>	<b>590,814</b>	<b>593,371</b>	<b>614,932</b>	<b>618,533</b>	<b>5,621,269</b>
5210333 - General Expenses	188,128	181,393	180,337	182,979	187,000	190,935	194,750	198,651	202,432	207,794	1,914,397
521040313 - Depreciation	223,978	223,978	243,240	243,240	243,240	260,024	260,024	260,024	276,145	276,145	2,510,038
521040403 - Downlands Interest Expense	94,430	90,289	89,940	102,588	126,430	151,471	136,040	134,696	136,355	134,594	1,196,835
<b>Operating (Surplus) / Deficit</b>	<b>- 0 -</b>	<b>0 -</b>	<b>0 -</b>	<b>0 -</b>	<b>0 -</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0 -</b>	<b>0 -</b>	<b>0 - 2</b>

**Table 9-20: Detailed Maintenance & Operational Expenditure: Hakataramea (figures are inflated)**

5220 - JV - Hakataramea	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Operating Revenue</b>	<b>-24,630</b>	<b>-24,630</b>	<b>-25,261</b>	<b>-25,841</b>	<b>-26,339</b>	<b>-26,824</b>	<b>-27,320</b>	<b>-27,826</b>	<b>-28,340</b>	<b>-28,865</b>	<b>-265,877</b>
522005101 - Recoveries - General	-22,552	-22,552	-23,183	-23,763	-24,261	-24,746	-25,242	-25,748	-26,262	-26,787	-245,097
522007301 - Interest Income	-2,078	-2,078	-2,078	-2,078	-2,078	-2,078	-2,078	-2,078	-2,078	-2,078	-20,780
<b>Operating Expenditure</b>	<b>35,773</b>	<b>40,373</b>	<b>41,260</b>	<b>42,128</b>	<b>42,942</b>	<b>43,732</b>	<b>45,094</b>	<b>45,313</b>	<b>46,101</b>	<b>46,905</b>	<b>429,621</b>
5220324 - Audit fees	271	271	279	286	292	297	303	309	316	322	2,945
5220333 - General Expenses	1,000	1,000	1,028	1,054	1,076	1,097	1,119	1,142	1,165	1,188	10,868
5220357 - Utilities Charges	23,000	27,600	28,129	28,670	29,201	29,716	30,797	30,730	31,227	31,733	290,803
5220506 - Contractors	11,276	11,276	11,592	11,882	12,131	12,373	12,621	12,874	13,131	13,394	122,549
5220512 - Water Testing	226	226	232	238	243	248	253	258	263	268	2,456
<b>Operating (Surplus) / Deficit</b>	<b>11,143</b>	<b>15,743</b>	<b>15,998</b>	<b>16,287</b>	<b>16,603</b>	<b>16,908</b>	<b>17,773</b>	<b>17,488</b>	<b>17,761</b>	<b>18,040</b>	<b>163,744</b>

**Table 9-21: Detailed Capital Expenditure: Downlands (figures are inflated)**

5210 - JV - Downlands	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Renewal</b>											
521076001 - Downlands Rural Water scheme various renewals	168,000	250,390	609,482	676,726	698,537	226,792	233,159	293,202	240,920	245,488	3,642,696
<b>Total Capital Expenditure</b>	<b>168,000</b>	<b>250,390</b>	<b>609,482</b>	<b>676,726</b>	<b>698,537</b>	<b>226,792</b>	<b>233,159</b>	<b>293,202</b>	<b>240,920</b>	<b>245,488</b>	<b>3,642,696</b>

**Table 9-22: Detailed Capital Expenditure: Cattle Creek (figures are inflated)**

5120 - Cattle Creek	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	10 Year Total
<b>Renewal</b>											
512076002 - Cattle Creek - Consenting	-	-	-	5,269	-	-	-	-	-	-	5,269
<b>Total Capital Expenditure</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>5,269</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>5,269</b>

The table above details the three other rural schemes within the Waimate District. Please note the Downlands water scheme is operated and managed by the Timaru District Council, with Waimate District Council having a 14% stake holding in the scheme but no direct involvement apart from the collection of water rates on those properties.

Hakataramea Valley and Cattle Creek rural water schemes have not been included in this AMP as they are administered and operated privately by an incorporated society.

### 9.6.4 3 Waters 2024-2034 Renewals and Capital Summary


The following details the summary of new capital and renewals for all three services for the 2024-34 period.

**Table 9-23: 3 Waters 2024 -2034 Renewals and Capital Summary**

3 Waters	Enhanced AP 2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	Total
Renewals	1,446,045	2,881,576	2,146,752	3,641,146	3,238,516	1,889,401	1,651,904	2,339,109	2,781,108	3,550,499	25,566,056
Levels of Service	685,835	8,781,498	235,415	563,948	609,055	301,237	28,045	364,817	300,506	508,065	12,378,420
Growth	1,350,050	783,000	25,700	808,715	611,054	345,650	-	271,725	-	315,955	4,511,848
<b>Total</b>	<b>3,481,930</b>	<b>12,446,073</b>	<b>2,407,867</b>	<b>5,013,809</b>	<b>4,458,625</b>	<b>2,536,288</b>	<b>1,679,949</b>	<b>2,975,650</b>	<b>3,081,614</b>	<b>4,374,518</b>	<b>42,456,324</b>

The 2025/2026 programme is predominantly treatment upgrades and is provisional subject to further discussion and agreement with Taumata Arowai. Should the programme proceed, it is considered achievable.


**Figure 9-8: 3 Waters 2024-34 Renewals and Capital Projects**



**Table 9-24: 3 Waters 2024-34 Capital Programme**

Utility	2024/25	2025/26	2026/27	2027/28	2028/29	2029/30	2030/31	2031/32	2032/33	2033/34	Total
Water	2,823,950	11,361,040	1,349,693	2,304,429	2,964,549	1,302,870	1,269,754	1,905,627	2,067,788	2,704,115	30,053,815
Wastewater	444,880	835,033	1,006,774	2,646,158	1,494,076	1,233,418	410,195	1,067,740	1,011,498	1,650,211	11,799,982
Stormwater	213,100	250,000	51,400	63,222	-	-	-	2,283	2,329	20,193	602,527
<b>Total</b>	<b>3,481,930</b>	<b>12,446,073</b>	<b>2,407,867</b>	<b>5,013,809</b>	<b>4,458,625</b>	<b>2,536,288</b>	<b>1,679,949</b>	<b>2,975,650</b>	<b>3,081,614</b>	<b>4,374,518</b>	<b>42,456,324</b>

**Figure 9-9: 3 Waters 2024-34 Capital Programme**



## 9.7 Key Financial Forecasts Assumptions and Uncertainties

### 9.7.1 Overview

Forecasting assumptions and uncertainties are essential in the operation of Council's assets to indicate the levels of risks associated with those assumptions. Where necessary additional strategies can be implemented to reduce the risk.

The LGA 2002 - Schedule 10, Part 1 (11) requires the Council to clearly define all the significant forecasting assumptions and risks that underlie the financial estimates, assumptions concerning the useful life of significant assets and an estimate of the potential effects of the uncertainty on the financial estimates provided.

Appendix C details the significant forecasting assumptions for the utilities.

### 9.7.2 Financial Forecasting Confidence

The following table provide an assessment of the confidence in, and the accuracy of the 20-year financial forecast and supporting asset data. Table 9-26 and Table 9-27 detail the general meaning of the grades:

**Table 9-25: Financial Forecast Confidence Level**

Activity	Confidence Grade	Accuracy
Operations/Maintenance	B	2
Depreciation	B	2
Overheads		2
Funding Costs	C	3
Capital Expenditure	B	3
Debt Repayment	C	3
Overall	B	3

The overall confidence level is 'B' or reliable. Data is based on sound records, procedures, investigations and analysis which is documented but has some shortcomings and gaps that may impact on the confidence of long term financial forecasts.

The overall accuracy is 3 indicating that the accuracy of the financial forecasts is +/- 20%.

**Table 9-26: Confidence Grades**

Confidence Grade	General Meaning
A	<b>Highly Reliable</b> Data based on sound records, procedures, investigations and analysis, which is properly documented and recognised as the best method of assessment
B	<b>Reliable</b> Data based on sound records, procedures, investigations and analysis which is properly documented but has minor shortcomings for example the data is old, some documentation is missing and reliance is placed on unconfirmed reports or some extrapolation
C	<b>Uncertain</b> Data based on sound records, procedures, investigations and analysis which is incomplete or unsupported, or extrapolation from a limited sample for which grade A or B is available
D	<b>Very Uncertain</b> Data is based on unconfirmed verbal reports and/or cursory inspection and analysis



Accuracy ratings are made using the criteria outlined in:

**Table 9-27: Accuracy Ratings**

Grade	Description	Accuracy
1	Accurate	100%
2	Minor inaccuracies	+ / - 5%
3	50% estimated	+ / - 20%
4	Significant data estimated	+ / - 30%
5	All data estimated	+ / - 40%

**10.0 PROCESSES AND ASSET MANAGEMENT PRACTICES**

*This section outlines the information available on the assets, information systems used and process used to make decisions on how the asset will be managed. It also provides details on planning for monitoring the performance of the AMP.*

### 10.1 Organisation Structure

Figure 10-1: Council Management Structure





Figure 10-2: Water and Waste Unit Structure



## 10.2 AMP Review and Monitoring

### 10.2.1 Monitoring Approach

Council has developed this AMP based on its current knowledge of customer requirements, the configuration of the existing and future network to meet customer requirements, current asset information and the strategies to achieve customer requirements.

To further develop a meaningful AMP, including supporting processes, systems and data, Council recognise the need for a more structured approach. This approach includes:

Council's firm commitment to implement and develop the AMP.

Incorporate this AMP as a tactical plan within Council's planning framework.

Review of the AMPs by internal staff and suitably qualified external consultants.

Aiming to produce an AMP that meets the requirements of the community.

Benchmarking key performance indicators against similar external TLAs.

A corporate commitment to implementing and maintaining suitable Asset Management information systems.

Adopting a team approach to the preparation of future AMPs in order to maximise the buy-in of internal staff and sharing of specialised knowledge.

### 10.2.2 Timetable for Audit and Review

The programme for future Asset Management reviews of this AMP is in Table 10-1.

**Table 10-1: Timetable for Audit and Review**

Activity	Target Date
Improvement Plan reviewed annually by all staff directly involved and focusing on key business issues	30 June each year
Report on Improvement Plan	30 June each year
AMP updates involving members of staff involved in preparing specific aspects of the AMP	30 June each year
Internal AMP peer review by staff not directly involved in preparation of AMP	30 June each year
Adoption of AMP by Council	30 June every 3 years
External benchmarking by internal staff	Annually
Audit NZ external audit	As required by Audit NZ

### 10.2.3 Utilisation of AMPs

Historically AMPs have been carried out for regulatory requirements and not used on an ongoing basis. Table 10-2 below details the methodologies for the ongoing implementation and updating of AMPs within Council to ensure the 3 Waters AMPs are used to their full potential.

**Table 10-2: Methodologies for the Ongoing Implementation and Updating of AMPs**


Methodologies	Output
Continuation of the organisational culture of asset management	The asset management culture needs be supported by the Chief Executive and senior managers in conjunction with the elected Council. Effective stewardship and management of Council major investment (assets) will not occur in the long term without a culture of asset management.
Resourcing of Asset Management Programmes	Asset management programmes must be adequately resourced.
Roles and Responsibilities of Council Staff	The roles and responsibilities of Council staff as they relate to the AMPs implementation need to be defined in respect to the ongoing use of the plans as this

Methodologies	Output
	<p>will assist the AMP to remain relevant and current. To enable this to occur the following is required.</p> <ul style="list-style-type: none"> <li>- The AMPs adopted/accepted by staff down to a defined level.</li> <li>- Council Staff to know what's in the plans and how it could affect their day to day Work.</li> <li>- Council Staff to understand the reasons for the AMP and the implications for the long-term use of them.</li> <li>- Understand all the reporting requirements for Levels of Service and Internal Benchmarking.</li> <li>- Training required in the use of the AMP (what's in it, how work is done, ongoing requirements for monitoring, review and updating).</li> <li>- Instigation of processes to encourage Council Staff to use the AMP.</li> </ul>

### 10.3 Business Processes

Figure 10-3 below details the data systems that are presently used within Council and their relationship with other systems.

**Figure 10-3: Council Data Systems**



#### 10.3.1 Univerus Assets

Council uses the Univerus Assets Asset Management system for its Asset Information System. Univerus Assets have been used since 2005 and is a web/GIS based asset management system. This has greatly improved the information on the scheme assets and enhance the future AMP and Asset Valuations. Some of the outputs from Univerus Assets includes:

- Complete asset register for the scheme.
- Completion of asset valuations.

- Maintenance can be entered into the database. Cumulative costs of maintenance on each asset can be assessed.
- Predictive analysis to indicate when assets should be replaced.
- Condition monitoring of assets.
- Complete “what if” scenarios to determine the optimal time to replace assets.

Univerus Assets was selected for the following reasons:

- Ease of use
- Simple functionality
- Low initial fee structure
- Low ongoing fee structure

**Table 10-3: Univerus Assets Functionality and Utilisation by Council**

Register Functions	Utilisation
Water	Water lines, points and plant details
Wastewater	Wastewater lines, points and plant details
Stormwater	Stormwater lines, points and plant details
Maintenance History	Cumulative maintenance costs of an asset. Maintenance history is also linked to the asset in GIS
Valuation	Used on an annual basis
Criticality	To be populated
Condition & Performance	Scores held in register

Data will be collected continually throughout the year and entered into Univerus Assets.

### Metadata Standards

A Central Government funded project is the ‘Metadata Standards’ which sets national metadata standards for the 3-waters (potable, waste and storm) network, and for residential and light commercial buildings. This is to ensure the correct asset data is collected and in the correct manner. The roll out of these data standards is expected to start mid 2017.

Going forward Council will align its data collection and recording with the Metadata Standards. However, the existing data will be held and only aligned with the standards over time as more current information is captured.

### 10.3.2 GIS

Plans for reticulation and facilities for the three utilities are entered onto ArcMap as they are received. Where information is received from contractors on the utilities services then ArcView is updated. Council does not have a robust system of ensuring that all subdivision plans are of the required standard prior to importing into ArcView.

#### Asset Data

The majority of asset quantity, location and pipe size data are held in the GIS system. There are a number of quality assurance processes are used to ensure the reliability of the data recorded. These processes include:

**Table 10-4: GIS Data**

Item	Details
Sampling of assets contained in the GIS / AMS	Using field tests to check the reliability of pipe capture, pipe quantities and pipe size within the GIS/AMS

Item	Details
Coverage testing	Checks by Asset Managers that assets captured in particular areas reconcile with the services known to be provided
Continuity checks	These are carried out in GIS to identify breaks in the piping networks and gaps in the data
Historical and new data	GIS capture of historical data has been derived from professional engineering and survey plans, from Council record sheets or Council staff knowledge. The ongoing capture of asset data is derived from engineering as-built plans. All As-built plans received by Council are required to comply with strict specifications and all data entered into the GIS/AMS is the subject of quality assurance processes

Recent staff changes have impacted greatly on the quality of data within the Univerus Assets/GIS systems. It is proposed as part of future improvements in the management programme section of this AMP to develop and implement formal quality assurance systems for existing and new GIS data.

### 10.3.3 Network Modelling

Computer models (InfoWorks) of the water schemes exist. This enables Council to:

- Determine accurately the existing capacity of the schemes
- Identify inadequate sections of the schemes
- Operate the system in the most efficient manner
- Determine the impact of further development on the schemes
- Identify system upgrading requirements
- Compare options for upgrading the water schemes

The network models are operated and maintained by Opus International Consultants Ltd. During 2021 Council engaged One Water Modelling (OWM) to update their water model stock to 2021 to assess any capacity issues in the networks and ability to service future growth. Refer to Section 6.7.4 2021 Model Project.

### 10.3.4 Complaints Database

The Council operates a complaints database through a 'Request for Service System' via Univerus Assets. This records all complaints associated with the 3 Waters, Roading activities and Parks and Reserves and provides useful information for trending and analysis of system performance and highlights issues.

The database has now been updated such that service requests can now be analysed by relevant performance measures (Levels of Service) and priority response times included within Univerus Assets. Further development of the system is required to allow retrospective entry of after-hours information and also escalation. Council is working with the developer of the system to develop this.

### 10.3.5 SCADA System

#### Background

Council operates an Abbey Systems Telemetry or SCADA (Supervisory Control and Data Acquisition) system. The system is used to monitor & control critical aspects of treatment plants and pump stations, 17 sites are presently monitored that include:

## Section 10: Processes and Asset Management Practices

- 1 WWTPs
- 2 Wastewater pump stations
- 7 Water intakes and treatment plants (WTP)
- 5 Reservoirs
- 3 Water pump stations

SCADA is available to the Waimate Urban water scheme and Lower Waihao, Otaio, Hook Waituna, and Waikakahi rural water schemes. Upgrades to all the rural water supplies in the near future will result in SCADA being available to all water schemes.

Two of the sites in Otaio-Makikhi are presently inactive, as the sites are not used in the present supply configuration. The sites are Otaio Gorge Plant and Otaio Reservoir.



Table 10-5: Scheme SCADA Details

SCHEME	FACILITY	METER	SCADA REPORT														ALARMING	
			Pump Start/Stop	Pump Hours	Level	Flow & Volume	Turbidity	FAC Residual	Cl <sub>2</sub> Dose	pH	Conductivity	Temperature	UV Transmittance	UV Dose	Pressure	Intruder/ Operator	Outgoing alarms	Flashing Light
Waimate Urban	Manchester Rd Bore		✓	✓	✓	✓	✓	✓		✓	✓			✓	✓	✓	✓	
	Timaru Rd Bore		✓	✓	✓	✓	✓	✓		✓		✓	✓		✓		✓	
	Mill Rd Reservoir				✓	✓		✓									✓	
Cannington Motukaika	Cannington Plant				✓	✓	✓	✓		✓		✓			✓		✓	
	Pratts Pump Station (Lambs) Reservoir																	✓
Hook Waituna	Hook Intake Treatment Plant		✓	✓		✓	✓	✓		✓			✓	✓	✓		✓	
	Simmons Pump Station																	✓
	Simmons Reservoir																	
	Brownleas Pump Station																	
	O'Donnells Pump Station																	
	O'Donnells Reservoir																	
	Garlands Rd (Tekit) Pump Station																	✓

Section 10: Processes and Asset Management Practices

SCHEME	FACILITY	METER	SCADA REPORT														ALARMING	
			Pump Start/Stop	Pump Hours	Level	Flow & Volume	Turbidity	FAC Residual	Cl <sub>2</sub> Dose	pH	Conductivity	Temperature	UV Transmittance	UV Dose	Pressure	Intruder/ Operator	Outgoing alarms	Flashing Light
	Garlands Rd (Tekit) Reservoir																	
Lower Waihao	Lower Waihao Intake & Plant		✓	✓		✓	✓	✓	✓	✓			✓					✓
	Pykes Rd Pump Station		✓	✓		✓												✓
	Lower Waihao Reservoir				✓													✓
Otaio Makikihi	Otaio Gorge Rd Intake & Plant		A	A		A		A		A								A
	Otaio Reservoir				A													A
	Tavistock Bore & Plant		✓	✓	✓	✓	✓	✓		✓	✓			✓	✓			✓
	Campbell Forrest Pump Station		✓	✓	✓	✓												✓
Waihaorunga	Main Intake & Plant		✓	✓		✓	✓	✓		✓					✓			✓
	Main Reservoir																	
	Melford Pump Station																	
	Melford Reservoir																	
	Takitu Pump Station																	

SCHEME	FACILITY	METER	SCADA REPORT														ALARMING	
			Pump Start/Stop	Pump Hours	Level	Flow & Volume	Turbidity	FAC Residual	Cl <sub>2</sub> Dose	pH	Conductivity	Temperature	UV Transmittance	UV Dose	Pressure	Intruder/ Operator	Outgoing alarms	Flashing Light
	Takitu Reservoir																	
	Tavendales Plant					✓	✓	✓		✓		✓			✓		✓	✓
	Tavendales Reservoir																	
Waikakahi	Waikakahi (Stonewall) Intake & Plant		✓	✓		✓	✓	✓	✓	✓		✓						✓
	Waikakahi Reservoir				✓													✓
	Claytons Pump Station																	
	Dog Kennel Pump Station		✓	✓		✓												✓
	Calytons Reservoir				✓													✓
A = Available but not in use																		

The system is used for:

- Monitoring the operation of sites.
- Reporting, trending and analysing historical data.
- Alarm monitoring (operators are informed of alarms via text messages to mobile phones).
- Some control functions.

Monitoring of Water and Wastewater schemes by the Council's SCADA system has grown to the point that without the current SCADA system, maintaining the existing Levels of Service would be difficult. SCADA has given the ability for Council to ascertain faults and instigate repairs without affecting the service to the consumer has significantly increased efficiency and reliability of the utility schemes.

The SCADA system is a critical system in Council's operation and service delivery.

In late 2016 the SCADA system was reviewed and the automated pump "start/stop's" controls were removed from the Master and Backup PC's, and programmed into the individual remote SCADA PLC's (RTU's) on site. This has improved the resilience and reliability of the system, by having the associated pumps and reservoirs talking directly to each other, to initiate starts and stops, without the dependency on the Master or Backup PC's.

### **Future Strategy for Council's SCADA**

Council's strategy for the ongoing use of SCADA is:

- Maintain a SCADA system at a high level to ensure system reliability and ongoing reporting ability.
- Increase availability of information to the Engineering staff in a format that will enable increased efficiencies in operation and management.
- Develop the reporting functions of the system.
- Develop further use of the system to control treatment plants.
- Continue to integrate the system with Lutra ID for compliance reporting and soft alarming



## 11.0 IMPROVEMENT PLAN

*This section details the improvements to Asset Management systems that will increase the level of confidence in the AMP.*

### 11.1 Asset Management Improvement Process

#### Background

Council is committed to ongoing improvement in the quality of its Water Services management practices. This is reflected in the implementation of asset management systems and associated data collection and maintenance requirements.

This Improvement Plan is integral to that approach, quantifying current business practice and measuring progress toward an identified future position. The Improvement Plan is focused on the key areas of:

- Information Management
- Scheme Knowledge
- Renewals and Risk assessments

#### Purpose of the Improvement Plan

The purpose of the Improvement Plan is to:

- Identify, develop and implement Asset Management planning processes.
- Identify and prioritise ways to cost-effectively improve the quality of the AMP.
- Identify indicative time-scales, priorities, and human and financial resources required to achieve Asset Management planning objectives.

The Improvement Plan is subject to constant reappraisal and change. While reappraisal is an ongoing process, the Improvement Plan will form the basis of the Water Services annual business planning.

### 11.2 Improvement Programme

Council is committed to ongoing improvement in the quality of its asset management practices until appropriate practice levels are achieved. This is reflected in the current improvement programme detailed in this section.

#### Recent AM Improvements Completed

Recent AM improvement items completed are detailed in the table below:

**Table 11-1: Recent AM Improvements Completed**

Water Activity	AM Area	No	Improvement Item	Completed	Comment
All	Level of Service (LOS)	1	Improvements to Council's Request for Service System via Univerus Assets, to enable interrogation of service request system to analyse customer complaints and identification of problem area	Y	Service requests can now be analysed by relevant performance measure and priority response times included within the Univerus Assets set-up.
All	Growth	6	Continue to develop the existing population projections process that is Council approved and used across all areas of council	Y	Process in place (yet to be formally adopted by Council).
All	Financial	23	Review asset materials codes and size ranges to see if there is scope for rationalising the information, both to assist with valuation and for general asset management purposes	Y	Completed
All	AM Practices	26	It is proposed as part of future improvements in the management of Univerus Assets/GIS - to ensure sufficient resources are available (both internal and external) to enable the full use of Univerus Assets/GIS for the operation, management and administration of the utility services	Y	Occurred during the 2014 / 15 Financial Year

**AM Improvement Priority**

The improvement priority was carried out using the key areas of:

- Legislative requirements
- Level of Service achievement
- Where the assessed risk was considered high

**Table 11-2: AM Improvement Programme**

Activity	AM Area	No	Improvement Item	Completed	Comment	2025-2034 Improvement Plan	Year(s)
All	Level of Service (LOS)	2	Review and evaluate LOS Options by investigating the effects of varied LOS (financial, environmental etc.) as part of next LTP process	N	Levels of service to be reviewed as part of next LTP process	Monitoring	2024/25-2027/28
All	Demand	4	Review if increased demand (population/demographics effects etc.) can be provided by existing infrastructure or addition assets/upgrades required (a watching brief)	N	As new population figures / demographics / development information becomes available, Council is actively reviewing existing infrastructure / services to ensure LOS are met.	Ongoing	2024/25-2027/28
Water	Growth	5	Continue to implement demand management programme in-conjunction with the leak detection program	N	Demand management will be achieved by a combination of pressure management and developing policy in relation	Ongoing	2024/25-2027/28
Water	Growth	7	Leak detection in Waimate urban reticulation every three years	N	Ongoing work, Council has a watching brief on Midnight flow.	Ongoing – leak detection is planned for 2021/22. Water loss monitoring will Continue. Other forms of leak detection/water loss will be implemented in 2021/22 such as consumer service meters (RF).	2024/25-2027/28



Activity	AM Area	No	Improvement Item	Completed	Comment	2025-2034 Improvement Plan	Year(s)
All	Sustainability	9	Assess staffing levels to ensure sufficient resources to meet demand	N	Ongoing work	Currently there are major changes in water legislation, regulation and potentially standards and solutions. These changes will impact the way 3 water services are managed and operated their supplies and networks. Increase compliance and greater expectations around levels of service will mean reviewing staffing levels on a regular basis until July 2024, to be assured of meeting legislation, regulation requirements.	2024/25-2027/28
All	Risk	10	A Council wide risk policy to be developed	N	Risks have been identified in a methodical manner through the Audit Committee.	Ongoing risk reviews	2024/25-2027/28
Water	Risk	12	Development and Implementation of Water Safety Plans and Improvements	N	Currently approved water safety plans for Waimate Urban, Cannington-Motukaika, Waihaorunga, Waikakahi. Submitted Hook-Waituna, Lower Waihao. Under development, Otaio Makikihi	Water safety plans are either being implemented (4) or undergoing review (1) and assessment (2) currently. Some capital works proposed in the 2021-31 LTP are still subject to approval. Implementation and review on five year cycle.	2024/25-2027/28
All	Risk	13	Develop Business Continuity and Emergency Management Plan (for rapid and structured response to emergency failures and significant hazards) and ensure review control process is carried out	N	Major developments in communication of significant issues have been made.	Ongoing	2024/25-2027/28

Section 11: Improvement Plan

Activity	AM Area	No	Improvement Item	Completed	Comment	2025-2034 Improvement Plan	Year(s)
W and WW	Lifecycle	14	To better understand the different AC pipe life a programme of assessing the condition of the pipes in all the schemes that contain AC pipe will occur	N	Ongoing work with A number of samples taken and analysed	Ongoing	2024/25-2027/28
Water	Lifecycle	15	To better understand the different “old PE pipe” life, a programme of assessing the condition of the pipes in all the schemes that contain Old PE pipe will occur.	N	Ongoing work	Ongoing	2024/25-2027/28
Water	Lifecycle	16	The location and extent of Garnite PVC pipes are required to be found and the information shown in both Univerus Assets and GIS. This will allow greater understanding of the future renewals programme for this type of pipe.	-	As these are encountered the asset database is updated	On going	2024/25-2027/28
All	Lifecycle	17	Continue condition assessment of plant assets to better understand future renewals programme for above ground assets	N	Condition assessments to be carried out	Ongoing	2024/25-2027/28
All	Lifecycle	19	Develop a Condition Assessment Strategy		To identify which, where and when condition assessments will be performed in consideration of criticality, LoS, asset records, Council engineers’ visual assessment of failures and specialists assessments as required.	Ongoing – Staff training has occurred in condition assessment.	2024/25-2027/28

Activity	AM Area	No	Improvement Item	Completed	Comment	2025-2034 Improvement Plan	Year(s)
All	Lifecycle	20	Develop a comprehensive renewal programmes based on analysis of condition and capacity once condition assessments have been carried out	N	Condition assessments to be carried out as part of the improvement of data quality	Ongoing – Staff training has occurred in condition assessment.	2024/25-2027/28
All	Lifecycle	21	Review and document operations and maintenance strategies based on criticality and risk	N	Ongoing work	Ongoing	2024/25-2027/28
All	Lifecycle	22	Formalise and update the existing maintenance schedules and procedures quality procedures, contingency and operation and maintenance manuals	N	Utilisation of Univerus Assets to Schedule maintenance alongside formalising by means of manuals is required	Carry over – issues with implementation of Univerus Assets Version 4. Schedule still to be implemented	2024/25-2027/28
All	Lifecycle	31	Align the asset data in Univerus Assets with the criticality assessment ratings	N	Ongoing work	Carry over – Complete with urgency to enable comparison of age predicted model with condition and performance weightings.	2024/25-2027/28
All	Lifecycle	32	Consider and implement recommendations from criticality assessment	N	Ongoing work	Ongoing	2024/25-2027/28
All	Lifecycle	33	Revisit criticality assessment	N	The Havelock North Water Enquiry and 3 Waters review may require a review of the criticality assessment to ensure the focus remains correct.	Maintain a watching brief on recommendations and legislation to ensure criticality assessments remain pertinent.	2024/25-2027/28
All	Lifecycle	34	N/A	N	Systematically assess 3W's data reliability and present in a table	Complete systematic reliability analysis for 3W's assets. Once established utilise predictive modelling with condition and performance weightings to better understand longer term renewal requirements.	2024/25-2027/28

Section 11: Improvement Plan

Activity	AM Area	No	Improvement Item	Completed	Comment	2025-2034 Improvement Plan	Year(s)
All	Financial	24	Continue to keep good records of construction costs, especially for rural pipelines, to provide better information for future valuation updates.	N	Ongoing work	Ongoing	2024/25-2027/28
All	Financial	25	Updating asset inventory to reflect changes resulting from capital works and continue to do so.	N	Ongoing work	Ongoing	2024/25-2027/28
All	AM Practices	27	Council continues to maintain the Univerus Assets asset database and improve accuracy of data through review and modification of collection, storage, and auditing with prioritising on criticality including the development of Data management standard	N	Ongoing work	Ongoing	2024/25-2027/28
All	AM Practices	28	Complete data capture and update records for underground assets - to the asset management systems and ensure adequate resources are available for data entry and ongoing data maintenance	N	Ongoing work	Ongoing	2024/25-2027/28
All	AM Practices	29	Continue to and complete data capture and update records for all facilities assets - to asset management systems	N	Ongoing work	Ongoing	2024/25-2027/28

Activity	AM Area	No	Improvement Item	Completed	Comment	2025-2034 Improvement Plan	Year(s)
All	Improvement Programme	30	Develop long term improvement programme to achieve the Council's appropriate practice policy	N	Ongoing work	Asset Management sophistication and Maturity Index assessments need to be completed prior to next generation 2024	2024/25-2027/28
All	Legislation/Policy	35	Continue to monitor and respond to Government 3 Waters reform programme- Local Water Done Well	N	Ongoing work	Ongoing	2024/25-2027/28

### 11.2.1 Monitoring Approach

Council has developed this AMP based on an integrated asset management planning approach that includes:

- The configuration of networks to meet customer requirements, now and in the future.
- Current asset information.
- Well-developed strategies to achieve customer requirements.

The further development of Council’s asset management approach including supporting processes, systems and data will be needed to meet the appropriate level of asset management practice as set out in Council’s Asset Management Policy. This Policy will be reviewed periodically to take into account legislative and other national practice changes.

### 11.2.2 Timetable for Audit and Review

The programme for future AM reviews of this plan is presented in Table 11-3.

**Table 11-3: Timetable for Audit and Review**

Activity	Target Date
Improvement Plan reviewed annually by all staff directly involved and focusing on key business issues	30 June each year
Report on Improvement Plan	30 June each year
AMP updates involving members of staff involved in preparing specific aspects of the AMP	30 June each year
Adoption of AMP by Council	30 June every 3 years
Audit NZ external audit	As required by Audit NZ

# Appendix A Individual System Description & Overview

## A.1 Waimate Urban Scheme

### Overview

The reticulation network is supplied from two groundwater bores with one reservoir that supplies 24 hours emergency supply capacity. Manchester Road bore, drilled in 1972, is the predominantly used bore and treatment involves chlorine dosing. Timaru Road bore, commissioned in 2000, originally only used during times of peak water demand during the summer months and treatment includes; chlorine dosing, lime dosing (when required) and an automatic valveless gravity filter to remove iron. However, since the implementation of pressure management both bores operate permanently.

The approximate length for the reticulation network is 88.6 km. A total of 55% of the pipe reticulation network will reach the end of its expected economic lives within the next 30 years.

Approximately 8.7 km of AC and 13km of CI will reach the end of its expected economic lives within the first ten years of this plan.

### History

After much consideration by the Council in the early years the nineteenth century, a High Pressure water Supply system was eventually installed in 1906. The scheme has grown progressively since that date with major additions between 1950 and 1970.

The source of this supply was the Waimate Stream, which rises in a large valley on the eastern side of the Hunter Hills some 762 metres high. The point selected for the Intake was in Kelcy's Bush, some eight kilometres from and 183 metres above the town and just opposite the present car park area, but an exceptionally heavy rainfall event damaged the head-works during the period of construction. Therefore, the intake was moved another 60 metres approx. further upstream to the current picnic area. It is important to also note that not only was the original head works damaged in the heavy rain event, but also the then new pipe line to town, at Garland's Bridge.

The old concrete head works remains are still visible at both of these sites. At the second site at the current picnic area, there is a junction pit and from there a 225 millimetre tile pipe and in places steel runs to the top of the hill in Atwill Park just near the bend in the road. From this point a 150 millimetre, cast iron main went down to the old Reservoir, which had a capacity of 2,273 cubic metres and was 68 metres above the town. It is recorded that the Reservoir held sufficient for three days' supply, which would give a demand of approximately 758 cubic metres per day.

From the old Reservoir a 150 millimetre, cast iron main went down to a point in Mill Road just opposite the Belt Street intersection where it is reduced to 100 millimetres and continued down Mill Road to Queen Street. 100 millimetre distribution mains branch off at the intersections of Belt, Rhodes, Harris, Shearman and Queen Streets and three inch pipes supply Opie Street and the Streets to the west of Mill Road. From these primary distribution mains, the water was carried to as far as Uretane (Mrs. Ruddenklau's property - 1937). In the South, Timaru Road (Mr. Cottee's - 1937). In the east, Parsonage Road (Mr. Barclay's - 1937). In the north, High Street (Mr. Hunt's in the north-west - 1937), as well as all the area lying in between these widely separated points.

A report states that the pipes were capable of delivering 2455 cubic metres per day to town, or approximately 1.6 cubic metres per minute (26.5 litres per second). The pressure when tested in town after completion was: Opie Street 565 kPa, Queen Street 737 kPa, and Lower High Street 910 kPa.

A lot of the original cast iron main from 1906 is still in operation today around the Waimate Township. On 8 December 1914, owing to the shortage of water, the question of procuring additional supplies was considered by the Council. Two proposals were discussed, one to take a pipe from Sanders Falls



Creek and the other to obtain supplies from Hayes Creek near the Reservoir. On January 26, 1915 it was decided to lay a pipeline to Sanders Falls.

On 18 January 1924, it was decided to measure the flow of water in the stream. The point selected was the Rook Pool. The reported result were a flow of 663.7 litres per minute (11.1 litres per second) or 956 cubic metres per day.

A recommendation from a report in 1928, written by Mr. Fletcher Roberts, a Civil Engineer from Dunedin, was that the intake be moved 1046 metres upstream to the Rock Pool, and that an additional 200 millimetre pipeline be laid from the Reservoir to town via Allen Street and High Street to Queen Street. Also that a flow meter be installed at the new Intake in order to obtain some accurate data on the flow of the stream.

On 26 August 1930, the Council decided to proceed with the first mentioned recommendation, which was the shifting of the Intake to the Rock Pool. Works started that year and by November 1931 completed.

At this time, the worldwide economic depression became felt in New Zealand, and unfortunately, the additional 200 millimetre pipe recommendation was held in abeyance. Later in 1935, a 225 millimetre cast iron main was installed from the old Reservoir to township to improve flow. The Rock Pool Intake was still in use and maintained until 1999, and the old Waimate Reservoir until the year 2000.

In the early 1970's a number of bores were drilled by A M Bisley & Co Ltd. One of those bores was the Number 3 bore, also known as Manchesters Road Bore, which was drilled in February 1972. When commissioned it jointly supplied Waimate Urban Supply.

In 1998, the Waimate District Council bought Tony Halbraken's farm (Timaru Road) and subdivided off the new bore that had been drilled on the property, including an easement for access, and then sold the rest of the farm. The bore was drilled by Washington's Drilling in February 1997 and was only partially developed (31.5 hours), 21 March 1998. The Council got Washington's Drilling back on the 22 May 1998, to continue developing the bore for another 20 hours. The Timaru Road bore was commissioned in 1999.

When Timaru Rd Bore was commissioned, the process was similar to Manchesters Road Bore, where abstraction and distribution were the same process with chlorination added as it left the plant. At this point, the Rock Pool and Saunders Fall were abandoned by the Council. Local farmers on Mill Road, with consent, took on the old Kelcy bush intakes for stock water (only).

In year 2,000 a 2,600 m<sup>3</sup> capacity lined and covered, earth pond type reservoir was constructed to replace the original concrete and masonry reservoir that had served Waimate for approximately 90 years.

By 2002 widespread consumer complaints about the staining of laundry and white ware became a significant issue. This was due to the raw water quality coming out of the Timaru Road Bore. From an analyses carried out in 1999 the manganese content was 0.7mg/l, and the dissolved iron content at 0.25mg/L. The elevated levels of manganese and dissolved iron was the cause of the issue, and was exacerbated by gas chlorination creating precipitate.

This led to a decision by Council to upgrade the Timaru Road Bore site with a new treatment plant to remove the manganese and dissolved iron.

## Appendix A:

### Individual System Description & Overview

The plant was upgraded and commissioned in June 2002. It included chlorine as the oxidizer for the removal of manganese and dissolved iron, an Automatic Valve-less Gravity (AVG) Filter, pH correction lime dosing unit, 2 times 30,000 litre balance tanks, a wet well with two submersible reticulation pumps, upgraded block building and back wash pond.

By 14 January 2003, problems began. A 100mm of fine bore sand was found on top of filter bed media. This build up caused premature and multiple backwashing. The sand was scraped off and removed. The blinding of the filter bed occurred another five times and 6.7m<sup>3</sup> approximately, of bore sand in total was removed.

Because of the bore sand in the Timaru Road Bore the filter bed from 2009 is annually checked and scraped. The depth of the bore sand currently found on the filter bed media ranges around 20 to 30 mm.

In 2005 due to the AVG filter bed being blinded with bore sand, two new soak holes are bored to drain away the excess backwash effluent/supernatant.

About this time in 2005, Waimate consumers began lodging taste and odour complaints when the plant was running.

In 2006 lime dosing for pH correction stopped. It is not understood why it was stopped. With current pH levels for raw water around 7.7 and treated 7.4, plus the naturally occurring alkalinity (117 g/m<sup>3</sup>) in the raw water, there is no need for lime dosing to correct pH.

In addition, staff in 2006 stopped using Timaru Road Bore and Treatment Plant as the duty/main source and supply for Waimate because of taste and odour complaints. When the plant was running the chlorine residual ranged between 0.2 to 0.4 mg/l leaving the plant.

From 2003 written records on site about process became vague and by 2006 non-existent.

In 2007 and 2008, there were major staff changes. A new Supervisor and two new water operators, and at the end of 2008, a returning Engineer. Work was started on getting the Timaru Road Bore and Treatment Plant functioning properly again.

At this time the Timaru Road Bore and Treatment Plant was suffering from:

- Multiple backwashes (3x a day).
- Incorrect flow rate through filter (169m<sup>3</sup>/hr).
- Bore sand, causing the clogging filter bed.
- Smell of Hydrogen Sulphide off the raw water from bore.
- Dark black/brown coloured backwashes.
- Taste and odour compliant when the bore and plant was operational.
- No maintenance program being actioned.
- Water main breakages in township.

Each of these issues were investigated and corrected by:

- Correcting the flow rate to a maximum of 150m<sup>3</sup>/hour reduced the number of backwashing actions from per day to per week.
- Annual cleaning the filter bed stopped the blinding of the bed and contributed to reducing the number of backwashing actions from per day to per week.
- By recognizing the hydrogen sulphide in the raw water, it lead to the discovery of the causes of the taste and odour complaints, and the thick dark black/brown coloured backwashes.

Because of the low chlorine dose and lack of use, the filter bowl started to breed sulphide/sulphate eating bacteria, which lead to a thick dark black/brown coloured backwashes and taste and odour complaints. There is also may have been a possibility of poor oxidization of the manganese and dissolved iron in the raw water, which also creates taste and odour issues.

This lead to upping the chlorine dose so that there was a chlorine residual of 0.7 to 0.8 mg/l at the underdrain of the filter bowl (post treatment), and setting up the plant to run daily. This meant that the manganese, dissolved iron and hydrogen sulphide were oxidized properly and prevented any growth in the filter bowl, plus the running the plant daily also prevented the growth of the bacteria. After these actions, the taste and odour issues were significantly reduced.

- Regular weekly visits and maintenance as required, plus the introduction of regular manual backwashes to keep the filter bed healthy. All Staff are now trained in the new plant procedure.
- Reducing the reticulation pump outgoing set-point pressure from 12 Bar, which was too high for the aging infrastructure, to 10.3 Bar. This lead to a significant reduction in water main breakages in township.

During 2013 to 2018 About 4.3 km's of new 200mm PVC rising main has been installed from High Street and Queen Street intersection up High Street to Allan Street and along, then from Mill Road and Allan Street intersection, under the Waimate Creek Bridge to the Waimate Reservoir. This has been done to improve flow up to the Mill Road Reservoir, and part of the process to improve pressure management in the Waimate Urban supply.

Since 2016 Council have been renewing water mains pipe, laterals and Tobies (point of supply) in the Waimate urban area. To date, about 4 km of old cast iron and AC pipe have been renewed with 100 millimetre PVC pipe. All tobies and laterals have also been replaced with 20 millimetre MDPE OD pipe and Acuflo manifold units (dual check) with flow meters.

On the 21 December 2014 the Manchester Bore plant building caught on fire, damaging the electrics and interrupting delivery and chlorination. A temporary building to house new equipment was erected on 22 December 2014 and became operational on 23 December 2014. The cause was electrical and could have been either a fault or excessive heat generation of electrical control equipment.

After reapplying for full "Secure Bore" status after five years in 2017, Manchesters Bore was unable to fulfil criterion 2 of the DWSNZ 2005 revised 2018). This was because of the age of the bore, plus no construction details when A.M.Bisley & Co. Ltd. drilled the bore in 1973. The full "Secure Bore" status was revoked on the 23 November 2017.

With loosing "Secure Bore" status it was decided not to retry for bore security again, but to put in a multiple barrier approach to treatment, to assure secure and safe drinking water supply for the Waimate town community. This deciosn not to try for "Secure Bore" status was due to the Havelock North event in 2016, and the fact that "Secure Bore" status is not good science, and very hard to prove satisfactorily.

First stage was to replace the old Manachester Bore (J40/0022) with a new 300mm bore (CA19/0055), 3 metres east of the existing bore on the railway embankment, which was commissioned September 2018. The new bore tapped into the same aquifer with the screen set between 79.1 to 83.1 metres.

As part of that process a retaining wall was then built on the north side of the old railway embankment to increase space for a new treatment plant on the embankment. This was completed March 2019.

## Appendix A:

### Individual System Description & Overview

The contract for the new treatment plant soon followed with the new treatment plant being constructed at the end of 2019. The plant was completed and commissioned 5 December 2019.

The new Plant relies on a secure borehead, Ultraviolet (UV) irradiation of microbiological organisms (protozoa & bacteria) and disinfection of treated water to the distribution



*Manchester Bore Treatment Plant December 2019*

The plant has been operational since completion in December 2019 with some minor operational compliance functions that need to be completed by council staff to achieve full compliance (manual monitoring of UVT, Secure Borehead report).

As the Council had decided to move away from “Secure Bore” status as a barrier, work started in late 2020 on Timaru Road bore to upgrade the treatment process to Ultraviolet (UV) irradiation for microbiological treatment. And will also seek to meet criterion 2 (Borehead Security), DWSNZ 2005 (revised 2018) as a barrier.

## 8. System Description

### Source and Catchment:

#### **Manchesters Bore**

The new Manchesters Bore (2018) is a 300mm diameter bore at 83.1 metre deep with the screen set at 79.1 – 83.1m, and is sited on the old railroad embankment, 850 metres off Manchesters Road, Waimate. This new bore (CA19/0055) was installed in 2018, and replaces the older bore (J40/0022) drilled in 1973, which was aging and its integrity and security were questionable.

The new bore was drilled to meet the compliance requirements of the DWSNZ 2005 (revised 2018), and the NZS4411:2001 Drilling Standards, plus grout sealed to 11 metres (Australian Standard [5-10m]) below the ground level to prevent ingress. “Secure Bore” status has not been sought after for this bore, as it is a questionable methodology to prove that the water drawn from it is safe. Instead Council will seek to meet criterion 2 (Borehead Security) DWSNZ 2005 (revised 2018) and provide treatment at the Plant for bacterial and protozoal compliance.

The wider catchment around Manchesters bore is made up of arable cropping, life style blocks (septic tanks), sheep and dairy farming (septic tanks and secondary sewage treatment), plus the urban community of Waimate with a population of 3000, which is 3 km to the West of the bore. The Regional Council’s “Community Drinking Water Protection Zone”, which is a protection zone of 100m radius around bore, totaling 3.1 hectares of land, is an exclusion zone protecting the source. Inside the protection zone, the only activities that occur inside the “Community Drinking Water Protection Zone” are arable cropping and intermittent grazing of sheep (>50), which pose no risk. The bore and plant

are fenced off from livestock access. Manchesters Bore, old and new, has maintained E.coli compliance since 2009, with no E.coli transgressions. However, there were four events of total coliforms (1 MPN/100ml and 2 MPN/100ml in 2013, then again 1 MPN/100ml and 200 MPN/100ml in 2018) from the old bore (J40/0022) with no reason why? Plus one event of total coliforms found in the commisioning sample at >5 MPN/100ml from the new bore (CA19/0055), which could be put down to the activity of drill and developing.

From geological and hydrological reports put out by Environment Canterbury (Regional Council) evidence it indicates that the Manchesters Bore draws water from the Upper Kowai Formation in the Cannington Gravels. The recharge zone is difficult to identify and quantify for the Kowai Formation. Due to its limited outcrop area, it is suspected that the majority of recharge for the Kowai Formation infiltrates from the shallow groundwater system. The ground water from the bore has a mean age of >171 years, and less than 0.005% water less than a year old. This would indicate that Manchesters Bore is not directly influenced by surface activities (See *“Waimate Urban Water Supply Bore Hydrology Report – November 2017”*).

The overall assessment of the Manchesters Bore catchment, plus the impact from human and agricultural activities has no known impacts.

### **Timaru Road Bore**

Timaru Road Bore is a 250mm diameter bore at 110m metre deep with a screen at 105 – 110m, and is sited at 383 Timaru Road, Waimate. The wider catchment is made up of arable cropping, life style blocks (septic tanks), sheep and dairy farming (septic tanks and secondary sewage treatment), plus the urban community of Waimate with a population of 3000, which is 4 km to the Southwest of the bore. The Regional Council’s “Community Drinking Water Protection Zone”, which is a protection zone of 100m radius around bore, totaling 3.1 hectares of land, is an exclusion zone protecting the source. Inside the protection zone the only activities that occur are arable cropping and intermittent grazing of sheep (>50) and beef cattle (>50), which pose no risk. The bore and plant are fenced off from livestock access. Timaru Road Bore has maintained E.coli compliance since 2009, with no E.coli transgressions.

From geological and hydrological reports put out by Environment Canterbury (Regional Council) evidence it indicates that the Timaru Road Bore draws water from the Lower Kowai Formation in the Cannington Gravels. For the Lower Kowai Formation the recharge zone is unknown. At present, record lengths are not long enough to determine any long-term trends to identify area of infiltration and recharge. The ground water from the bore has a mean age of >180 years, and less than 0.005% water less than a year old. This would indicate that Timaru Road Bore is not directly influenced by surface activities (See *“Waimate Urban Water Supply Bore Hydrology Report – November 2017”*).

The overall assessment of the Timaru Road Bore catchment, plus the impact from human and agricultural activities indicates no known impacts, and the bore meets all three current criteria requirement for “Secure Bore” status in providing safe, compliant drinking water to the consumers on Waimate Urban Supply. However the Waimate District Council will not be reapplying for “Secure Bore” status in the future

### Abstraction:

#### **Manchesters Bore**

An 11 kW submersible pump abstracts the source kw water from Manchesters Bore and is controlled by a variable frequency drive (VFD). A maximum / minimum flow rate set points have been set for the protection of the pump and the medium pressure UV reactor. On the bore head, there is Reduced Pressure Zone (RPZ) backflow preventer.

The Manchesters Bore submersible pump is initiated by demand and level transducer in the balance tank.

### **Timaru Road**

A 30 kW submersible pump abstracts source water from Timaru Road Bore. The flow from the bore is currently throttled by valve on the bore head to 44 L/sec, which is the maximum flow rate for the Automatic Valveless Gravity (AVG) Filter. On the bore head there is a Reduced Pressure Zone (RPZ) backflow preventer, plus an air gap at the top of the AVG filter for back flow prevention.

The Timaru Road Bore submersible pump is also initiated by demand and level transducer in one of the two balance tanks.

### Treatment Plants:

#### **Manchesters Bore**

The new Manchesters Bore Treatment Plant is next to the bore head. Next to the plant is a concrete chlorine gas store and dose shed, and a balance tank. The Treatment Plant houses the the medium pressure UV reactor, electrical distribution and control panels, analysers and SCADA.

Once the source water has passed through the RPZ backflow preventer, it enters the building and flows into the medium pressure UV reactor and out to the balance tank. When the treated water is drawn by the 30kW duty reticulation pump, the chlorine gas dose water solution is injected in before the pumps to aid mixing. The dose pump rate is automatically controlled to maintain a Free Available Chlorine (FAC) set-point level as measured and monitored by the chlorine analyser (automated closed loop process controller). The chlorination system operates whenever the reticulation pump is running.

The reticulation pump is initiated by level setpoints on the Mill Road Reservoir. The onsite SCADA PLC's at Mill Road Reservoir and Manchesters Bore provide the control function between the two remote units (RTU) to switch the pump on and off as required to fill the reservoir. This pump control includes Timaru Road Bore Treatment Plant. Manchesters Bore will always turn on first, and off last. If the plant faults, Timaru Road Bore Treatment Plant will continue to supply Waimate Urban.

The present treatment plant has no protozoal treatment barriers or "Secure Bore" status for the bore. To be protozoal compliant under the Drinking Water Standard for New Zealand 2005 (revised 2018), the plant needs log three (3) or four (4) treatment processes to be in place.

#### **Timaru Road**

The Timaru Road Bore is protozoal compliant with the current "Secure Bore" status with chlorine disinfection. Timaru Road Bore treatment plant is on the same site as the bore and consists of the bore headworks, an Automatic Valveless Gravity (AVG) Filter for soluble iron removal, two 30,000 Litre storage tanks, concrete high lift pump chamber with two 92 kW submersible pumps for reticulation delivery. Onsite also is the treatment plant building that houses electrical distribution and control, SCADA plus valving and chlorine treatment equipment (chlorine gas – 1 tonne + 100kg cylinders) for the oxidation of soluble iron and residual chlorine (FAC) for disinfection.

Currently (2021) the plant is being upgraded with UV reactor for protozoal treatment, so the plant does not have to rely on "Secure Bore" status. The new UV reactor will be operational by the end of 2021.

Chlorination at Timaru Road has two functions. One, oxidise the soluble iron into iron precipitate to be filtered out in the AVG filter, and two, residual chlorine (FAC) for disinfection. The chlorine dose is

manually set to allow for enough chlorine to oxidise of the soluble iron and residual chlorine (FAC) for disinfection.

After the RPZ backflow preventer on the bore head the source water is dosed with a gas chlorine solution after the check valve. There is enough contact time and mixing before the AVG filter bed to produce iron oxide precipitate to be removed by the filter. As the filtrate enters the under drain at the base of the AVG filter, the chlorine residual is routinely manually monitored for the ideal FAC residual of 0.7 - 0.8 mg/L. The treated water passes up through the unit into the clear water backwash tank in the AVG filter, and then out into the two 30,000 Litre storage tanks. Level sensors in one of the storage tanks indicate state and are also linked to control setpoints for the 30 kW bore pump to start and stop. Treated water is drawn from the storage tanks into the concrete high lift pump chamber by the duty 92 kW submersible reticulation pump. The reticulation pump is controlled by a variable frequency drive (VFD). A maximum pressure, plus maximum flow rate set points have been set for the protection of the reticulation and alarming for faults.

The duty reticulation pump is initiated by level setpoints on the Mill Road Reservoir. The onsite SCADA PLC's at Mill Road Reservoir and Timaru Road Bore Treatment Plant provide the control function between the two remote units (RTU) to switch the pump on and off as required to fill the reservoir. This pump control includes Manchesters Bore Treatment. Timaru Road Bore Treatment Plant will always turn on second, and off first. If the plant faults, Manchesters Bore will continue to supply Waimate Urban.

#### Distribution:

As mentioned in "Treatment", distribution is initiated by level setpoints on the Mill Road Reservoir and controlled by onsite SCADA PLC's remote units (RTU) at the reservoir and two intake plants.

Distribution in Waimate Urban supply, directly pumps into the supply reticulation with the residual volume overflowing into the Mill Road Reservoir. This requires pressure and flow control at both intakes to protect the reticulation. Manchesters Bore reticulation pump is set at 10.3 Bar, and Timaru Road Bore reticulation pump is also set at 10.2 Bar.

A separate rising main runs from each treatment plant and feeds into the reticulation. Manchesters Rd rising main is a DN200 asbestos cement pipe installed in 1973. Timaru Rd rising main is a DN200 PVC-M pipe installed in 1999.

The Mill Road Reservoir is elevated above the town at 120 metres above sea level on Mill Rd. The reservoir is a lined and covered earth reservoir approximately 4 metres deep with an approximate capacity of 2,600 cubic metres. This storage volume has the potential to supply the township for 36hrs, at a restricted demand, in the event of an emergency. The reservoir lining and roof consist of sections of polyethylene sheets welded to form a water tight seal. The roof and lining are joined together to form a sealed reservoir. There is a separate inlet (high level) and outlet (low level) system to allow cycling of the water in the reservoir. Chlorine FAC residual is also now monitored at this point in the distribution.

The Waimate Urban water supply network and the Hook Waituna network cross at numerous locations. At two such points the supplies are connected at Manchesters Road and Mill Road. Since 2018 the Waimate Urban supply permanently augments the Hook Waituna Rural Water Supply from these two points. This has the effect of boosting the supply into the rural water scheme network. Non-return valves prevent backflow from the rural scheme back into the Waimate Urban supply. The areas augmented are known as Willowbridge and Garlands. Augmentation is required now because the Hook Water Supply under normal demand can not provide enough treated water to all parts of the Hook Waituna reticulation.

## Appendix A:

### Individual System Description & Overview


#### Management and Operation:

The scheme is administered at the main council offices in Queen Street, Waimate and operated and managed by the Council's Utilities Business Unit (UBU) based at Michael Street nearby. Five qualified field staff operate and maintain the rural water scheme plant, fixing leaks etc as generally advised by the public. Water samples are sent to MedLab laboratories for bacteriological testing.

### System Information


System Information – Waimate Urban			
<b>Properties Connected</b>	2,007	<b>Treated Storage (Reservoir)</b>	
- Metered unrestricted	-	Mill Rd	
- Metered restricted	-	Built (yr)	2000
- Unmetered Residential	-	Capacity	2,600 m <sup>3</sup>
		Material	
<b>Water Sources</b>	(Consent volumes)	<b>Treatment</b>	
Manchester Road bore	2,160 m <sup>3</sup> /day	Chlorine	
Timaru Rd bore	3,456 m <sup>3</sup> /day	Filtration & Chlorine	
<b>Resource Consents</b>	Expiry date	To	
CRC000234	19/11/2034	Discharge backwash	Mill Rd
CRC020225	11/09/2036	Discharge backwash	Timaru Rd
CRC992171.1	14/06/2034	Take water	Manchester Rd & Timaru Rd
Replacement Cost	\$30.1 m	Reticulation length	88.6 km

Appendix Figure 1: Scheme Components






**Appendix Figure 2: Water Pipes Diameter Range**




**Appendix Figure 3: Water Pipes Material Length**




Approximately 15% of the Waimate Urban water supply reticulation was installed during 1906 and are 118 years old. The remaining 85% have been installed since 1921 and are aged between 1 and 103 years. The reticulation consists mainly of CI (24%), PVC (26%), AC (14%), PE (22%) and Galv (7%). There is 15m of steel which will be pipes from bore to surface pump stations.

**Appendix Figure 4: Water Pipes Install Year**




**Appendix Figure 5: Remaining Life of all Assets – Long Term**




At present asset useful lives are based primarily on book values with some adjustment for known risk factors. These will be refined by determining evidence-based useful lives using a combination of condition and performance data.


Appendix Figure 6: Water Pipes Replacement (Length) – Long Term




Appendix Figure 7: Water Pipes Replacement Value – Long Term



**Appendix Figure 8: Water Pipes Replacement (Length) - 1 to 30 Years**




**Appendix Figure 9: Water Pipes Replacement Value 1 to 30 Years**



**Appendix Table 1: Plant Replacement Value 1 to 30 Years**

AssetGroup	Remaining Useful Life (5 year groups)							Grand Total
	0 or less	1 - 5	6 - 10	11 - 15	16 - 20	21 - 25	26 - 30	
Disinfection Process	\$8,745		\$107,969	\$65,667				\$182,381
Electrical	\$25,887	\$1,344	\$27,314	\$144,555	\$78,041	\$15,002	\$85,924	\$378,067
Monitoring Control	\$11,660	\$751	\$56,945	\$23,769	\$1,830			\$94,955
Pipework	\$4,188	\$252	\$853	\$18,309	\$5,594	\$12,143	\$28,433	\$69,772
Property						\$33,318		\$33,318
Pump	\$50,698	\$18,371	\$46,159	\$87,615				\$202,843
Structure	\$127,963			\$31,936	\$68,044	\$187,229	\$103,796	\$518,969
Telemetry	\$26,143		\$11,798	\$43,867	\$1,120	\$678		\$83,607
Treatment	\$39,668		\$103,489		\$352,039			\$495,196
<b>Grand Total</b>	<b>\$294,952</b>	<b>\$20,719</b>	<b>\$354,527</b>	<b>\$415,718</b>	<b>\$506,668</b>	<b>\$248,371</b>	<b>\$218,153</b>	<b>\$2,059,108</b>

**Appendix Figure 10: 30 Year Renewal Profile**



The above chart shows the theoretical replacement profile based on asset expected useful lives. It also includes the smoothed 10 year average renewals requirement that indicates a declining average renewals requirement over the thirty year period.

**Appendix Figure 11: Waimate Urban Water Scheme**



## A.2 Cannington Motukaika Water Scheme

### Overview

The Cannington-Motukaika rural water supply scheme is a “small drinking water supply” that supplies water to 48 connections with a total population of about 120. The Waimate District Council target rates 31 properties for the supply of water in this scheme. Some scheme consumers have more than one point of supply connection on their rated property. Each point of supply connection is required to have water storage for 96 hours (four days) in case of interruption of the water supply.

The intake is located in the Mt Nimrod Stream which gravity feeds to a balance/contact tank where chlorine disinfection is undertaken. The treatment plant does not have any protozoal treatment barriers, only a roughing filter and chlorine disinfection. A majority of the reticulation network is gravity fed from this balance/contact tank. Midway in the reticulation a booster pump supplies a reservoir, and reticulation network, in the southwest part of the scheme.

The length of the Cannington-Motukaika reticulation network is approximately 53km over an area of 83 km<sup>2</sup>. The majority of pipe network was installed in 1973 and is 51 years old.

A large proportion of the water produced for the supply is consumed for the purposes of commercial agriculture. About 37 habitable dwellings have access to the water supply. This equates to 14% human consumption of the sold volume (based on 1500L/day/dwelling).

### History

The Cannington Motukaika water supply scheme assets were installed in 1973 and the majority of scheme reticulation is 51 years old. Very few infrastructure have been installed since 1973. A schematic diagram of the scheme follows.

### System Description

#### Source and Catchment:

Raw water is sourced from the Mt Nimrod Stream, which is fed from the surrounding 543 hectare hill catchment. The majority of the catchment is made up of upland pasture, with 71 hectares of native bush and forest above the intake.

The whole 543 hectares of the catchment is protected under the Waimate District Council District Plan “Water Supply Protection Area”. Around the intake weir there is 21.9 hectares of Regional Council “Community Drinking Water Protection Zone”, which is partially overlapped the “Protection Area”.

The upland pasture is made up of pastoral grasses and tussocks. Livestock such as sheep (<100) and beef cattle (<40) intermittently graze in the catchment. There are also small numbers of feral animals like pig, deer and goats in the area. Wallabies are also present and the population can get up to 80 animals. There are regular culling programmes to keep wallaby numbers down.

There are also low volume farm tracks in the upland pastoral area for access. These farm tracks are maintained by the landowner, and grassed to reduce exposed soil.

The native bush and forest above the intake, and around the intake is managed by the Department of Conservation (DoC). This area is known as the Mt Nimrod Reserve. Recreational activities in the Mt Nimrod Reserve are controlled by DoC.

## Appendix A:

### Individual System Description and Overview

In the reserve, there are day walk tracks up around through the bush, with a camping ground 400m below the intake. The track to the intake weir is not a part of the DoC walking tracks.

In the reserve there is “river canyoning” on Mt Nimrod Stream, which is inside the “Water Supply Protection Area” and “Protection Zone”. DoC have granted Big Rock Adventures Ltd from Geraldine concession for 10 years to run this activity in the reserve, which commenced 1 May 2011, and expired 30 April 2021.

Big Rock Adventures Ltd have procedures in place around toileting and protection of the environment that they and their clients must follow. These procedures have been viewed by the Waimate District Council, and are satisfied that any associated risks of contamination are controlled. This is a summertime activity and not all year round, therefore poses minimal risks.

The overall assessment of the catchment, plus the impact from human and agricultural activities, equates to a 4 Log treatment process requirement to provide wholesome, compliant drinking water to the consumers on the Cannington-Motukaika Rural Water Supply.

#### Abstraction:

The raw water is abstracted from Mt Nimrod Stream by an instream weir that diverts water over a roughing filter adjacent to the stream. Surplus flow is diverted back to the stream below the weir.

Maximum consented take is 5.5 L/sec and total volume of 3,325 m<sup>3</sup> per week.

#### Transmission:

Water flows via a 150mm AC gravity pipeline, approximately 1.3km east, to the treatment plants balance / contact tank. Flow into the tank is controlled by a ballcock valve, and is activated by outflow demand.

#### Treatment Plant:

The treatment plant consist of a balance / contact tank that is equipped with an ballcock valve, inline stainless steel mesh filter at the tank inlet, solar electrical system, dose pump and a chlorine solution shed.

Raw water passes through the course inline filter before entering the tank. A flow switch on the inlet pipe detects flow and controls chlorine dosing. When initiated by flow the chlorine pump injects a chlorine solution at an operator input set rate. The ballcock setup is designed to allow for a full flow when open, therefore either on or off. This aids chlorination dosing by keeping the flow relatively constant and free available chlorine (FAC) levels consistent.

The tank also serves as a contact tank for chlorination. At an average outflow of 2.8L/sec, contact time is around an hour to two hours. Minimum contact time is around 30 minutes, at maximum outflow of 5.5L/sec.

Power for the chlorine dose pump is generated by four solar panels, and is stored in four large 12-volt deep cycle batteries. The batteries are for nighttime use and low sun days due to cloud or bad weather.

The present treatment plant has no protozoal treatment barriers. For the plant to be protozoal compliant under the Drinking Water Standard for New Zealand 2005 (revised 2018), the plant needs log four (4) treatment processes to be in place.



## Individual System Description and Overview

Two monitoring samples taken at the treatment plant (during October 2020) showed bacterial transgressions greater than 10 E.coli per 100ml in each sample. This was related to chlorine dosing equipment failure. A permanent boil water notice has been in place since March 2013, mainly due to a lack of digital connectivity, and the ability to monitor changes in the scheme remotely in real-time.

Mains power, monitoring and control, telemetry (SCADA), and a building (to house monitoring, telemetry [SCADA] equipment) have been recently installed at the Cannington Treatment Plant site in 2021. This was installed as a part of an agreement with The Ministry of Health, instead of full upgrade of the treatment plant, to allow for potential changes in legislation and standards (Acceptable Solutions), for rural agricultural water supplies.

Distribution:

The majority of the scheme is gravity supplied from the balance / contact tank. Flow out of the tank is determined by demand.

At the south end of the supply a booster pump station is required. It is known as Pratts pump station, and is situated at the end of Pratts Road. The pump station pumps to a reservoir known as Lambs Reservoir at the west end of Howells Road, and supplies the high level properties in the south west of the supply. The Cannington-Motukaika water supply services an area of approximately 83 km<sup>2</sup>. The supply is the most remote of the six rural water supplies administered by Waimate District Council.

Management and Operation:

The scheme is administered at the main council offices in Queen Street, Waimate and operated and managed by the Council's Utilities Business Unit (UBU) based at Michael Street nearby. Five qualified field staff operate and maintain the rural water scheme plant, fixing leaks etc as generally advised by the public. Water samples are sent to MedLab laboratories for bacteriological testing.

With the age and size of the rural water supply there is limited availability of on-site standby plant within the system. Essential spare equipment is kept at the Council's Michael Street Yard for maintenance and replacement. There is also currently no electronic supervision or control of the system (SCADA).

Even though the Cannington Motukaika is a small and remote water supply, it has a cooperative and pro-active water scheme committee, who participate in the governance of the Cannington Motukaika rural water supply scheme. Under their own initiative they have set up a communication system via phone and email between Council, committee and the community, to aid in notification of issues and events. They have also organised surveys to help in future planning for the scheme.

Currently the Cannington Motukaika rural water supply has a "Permanent Boiled Water Notice". The notice was issued with the agreement of the Drinking water Assessor in September 2014. The notification is regularly advertised in local papers, Waimate District Council's website and Facebook page, along with Rural Delivery mail drops. The local water committee also reminds locals on request. In recent times organisations such as the local Mobile Kindy have helped advertise the "Permanent Boil Water Notice".

A large proportion of the water produced for the supply is consumed for the purposes of commercial agriculture, and the supply could potentially qualify as a rural agricultural drinking water supply. Waimate District Council had previously considered the option of point of use treatment on the rural supplies, and discounted the option at that time because of cost and maintenance issues. The option of "point of use treatment" was looked at again with the release of

## Appendix A:

### Individual System Description and Overview


the Rural Agricultural Drinking Water Supply Guidelines (RADWS) in March 2015. Some questions were raised again about actual cost, pre-treatment, maintenance, responsibility issues and liability. Those questions were investigated by exploring successful examples of private “point of entry treatment” supplies under the RADWS in the Waitaki District Council. However, after the Havelock North Stage 1 Enquiry, the issues and risks of such a system make the RADWS not a viable option.

Council has lobbied Government to review the current legislation and standards for Rural Agricultural Water Supplies. Since then the Department of Internal Affairs (DIA) and the new regulator Taumata Arowai have been, and still currently working on an Acceptable Solution option, using point of use (PoE) treatment, which could be used in rural agricultural water supplies.


### System Information

System Information – Cannington Motukaika			
<b>Connections</b>	48	<b>Treated Water Storage (Reservoir)</b>	
- Metered unrestricted	-	Backline Rd	
- Metered restricted	48	Built (yr)	1973
- Unmetered Residential	-	Capacity	25 m <sup>3</sup>
		Material	
<b>Water Sources</b>	(Consent volumes)	<b>Treatment</b>	
Mt Nimrod Stream	475 m <sup>3</sup> /day	Screen	
		Chlorine	
<b>Resource Consent</b>	Expiry date	To	
CRC092155	1/10/2044	Take water	
<b>Replacement Cost</b>		<b>Reticulation length</b>	
Total Scheme	\$1.2m	52.8 km	

Appendix Figure 12: Scheme Components




Appendix Figure 13: Water Pipes Diameter Range



Appendix A:


Individual System Description and Overview

**Appendix Figure 14: Water Pipes Length and Material**




Approximately 82% of the Cannington Motukaika water supply scheme reticulation were installed during 1973 and are 51 years old. The remaining 10% have been installed since 2001 and are aged between 1-23 years. The reticulation consists mainly of PE (48%) and PVC (48%).

**Appendix Figure 15: Water Pipes Install Year (10 Year Groups)**




**Appendix Figure 16: Remaining Life of all Assets – Long Term**



At present asset useful lives are based primarily on book values with some adjustment for known risk factors. These will be refined by determining evidence-based useful lives using a combination of condition and performance data.


**Appendix Figure 17: Water Pipes Replacement (Length) – Long Term**




Appendix A:

Individual System Description and Overview


Appendix Figure 18: Water Pipes Replacement Value – Long Term



Appendix Figure 19: Water Pipes Replacement (Length) - 1 to 30 Years




**Appendix Figure 20: Water Pipes Replacement Value - 1 to 30 Years**



**Appendix Table 2: Plant Replacement Value 1 to 30 Years**

AssetGroup	Remaining Useful Life (5 year groups) Replacement Costs					Grand Total
	0 or less	1 - 5	6 - 10	21 - 25	26 - 30	
Disinfection Process	\$2,941	\$683				\$3,623
Electrical	\$44,346					\$44,346
Monitoring Control	\$3,527	\$4,614				\$8,141
Pipework	\$13,273		\$207	\$89	\$2,490	\$16,059
Pre-treatment	\$13,029					\$13,029
Pump		\$5,030	\$5,030			\$10,061
Structure	\$34,849		\$1,421			\$36,270
<b>Grand Total</b>	<b>\$111,965</b>	<b>\$10,327</b>	<b>\$6,659</b>	<b>\$89</b>	<b>\$2,490</b>	<b>\$131,530</b>


**Appendix Figure 21: 30 Year Renewal Programme**




The above chart shows the theoretical replacement programme based on asset expected useful lives. It also includes the smoothed 10 year average renewals requirement that indicates a declining average renewals requirement over the thirty year period.



Appendix Figure 22: Cannington Motukaika Schematic



**Appendix Figure 23: Cannington Motukaika Scheme Plan**



## A.3 Hook Waituna Water Scheme

### Overview

The Hook Waituna water supply scheme is a “minor drinking water supply” and supplies water to 532 connections with a total population of about 1,350. Out of those figures there are 54 connections, with a population of 97 on the Hook Water Supply Scheme known as the Willowbridge area. This area is augmented with treated water from Waimate Urban Water Supply (WINZ Code: WAI033, Grading Ab). The Waimate District Council target rate 431 properties for the supply of water in this scheme. Some scheme consumers have more than one point of supply connection on their rated property. Each point of supply connection is required to have water storage for 96 hours (four days) in case of interruption of the water supply.

Water is sourced from an intake on the Hook River approximately 300m upstream of the Upper Hook Road Bridge. The raw water gravitates 220m to the Hook Treatment Plant which was upgraded 2013/14. Due to fine particulate found later in the raw water, the plant does not have any functioning protozoal treatment barriers, only chlorine disinfection. Duty/standby pumps deliver chlorinated water into the reticulation. There are four booster pump stations in the supply distribution.

The length of the Hook-Waituna reticulation network is approximately 252km over an area of 152 km<sup>2</sup>. The majority of pipe network was installed in 1973 and is 51 years old.

There are conditions and issues that limit the options for treatment to treat the fine particulate. Those conditions and issues range from noise, visual impact, use of chemicals, sludge discharge, capital and operational costs, plus consenting of discharge. An option that has the most potential is un-validated membrane filters. Investigation and trailing started in 2017. This form of treatment so far meets the requirements for capital and operational costs, space, visual impact, chemical free, sludge discharge.

### History

The Hook Waituna water supply scheme was established in 1973 and the majority of the scheme reticulation dates from this time. In 1997 a booster pump was installed at the intake site to resolve an air-locking problem in the reticulation going away from the plant. In later years the booster pump was used to boost pressure in the scheme during peak demand times.

Two supply connections from the Waimate urban supply were completed in 2001, to provide better pressure and flow in the lower supply catchment. One connection is at Mill Rd and can supply Garlands Road, down to Uretane Road if required. The second connection is on Manchesters Road and can supply the area around Manchesters Road, up to Timaru and Maytown Road intersection, and around Molloy's Road down to Studholme. It also supplies Mitchells Road down to Hannaton Road.

Later an extension was constructed to service the Willowbridge Community in 2003. This second connection is now known as the Willowbridge line and is permanently on below Molloy's Road to Willowbridge and Nukuroa Hall on Hannatons Road.

The intake gallery intake has been washed out a number of times over the years, with the last time in June 2013

## Appendix A:

### Individual System Description and Overview

In late 2013 with the aid of the Capital Assistance Programme (CAP) funding the Hook Intake Plant was upgraded to comply with the Drinking Water Standards for New Zealand. The plant could not be fully commissioned in early 2014, due to the discovery of fine particulate in the raw water source. The fine particulate affected the filtering processes and rendered the UV reactor inoperable. At present the plant is operating in a reduced state where there is only chlorination.

### **System Description**

#### Source and Catchment:

Hook Waituna Rural Water Supply sources its raw water from an intake on the Hook River approximately 300m upstream of the Upper Hook Road Ford.

Raw water sourced from the Hook River is fed from the surrounding 1,071 hectare hill catchment. Just over half of the catchment at 550 hectares is made up of bush and forest, with the remaining 521 hectares upland pasture and tussock above the intake.

The geology of the soil make up around the Hook River clay and rock. This clay is believed to be the source of the fine particulate that affects the present filtration process.

The whole 1,071 hectares of the catchment is protected under the Waimate District Council District Plan "Water Supply Protection Area". Around the intake gallery and weir there is 12.1 hectares of Regional Council "Community Drinking Water Protection Zone", which is overlapped by the "Protection Area".

The upland pasture is made up of pastoral grasses and tussocks. Livestock such as sheep ( $\leq 500$ ) and intermittently graze in the catchment. There are also small numbers of feral animals like pig ( $\leq 25$ ), deer and goats ( $\leq 25$ ) in the area. Wallabies are also present and there are regular culling programmes to keep wallaby numbers down.

Human impact is minimal, but there are three domestic sewerage systems just inside the protection area. Two are secondary treatment process and the third below the intake, and is an older style septic tank system. There also a fourth domestic sewerage systems just outside the "Protection Area".

The overall assessment of the catchment, plus the impact from human and agricultural activities, equates to a four (4) Log treatment process requirement to provide wholesome, compliant drinking water to the consumers on the Hook-Waituna Rural Water Supply.

#### Abstraction

The intake is an infiltration gallery which comprises a pair of 150mm PVC, slotted (2mm slots) pipes (total length 10m) laid in the river bed behind a weir constructed of rock filled gabion baskets.

#### Transmission:

The raw water flows by gravity through the infiltration gallery, into a 150mm AC pipeline (240m), and down to the treatment plant.

#### Treatment Plant:

The treatment plant consists of pump operation, pre-screening, cartridge filtration, UV irradiation, and chlorination.

## Individual System Description and Overview

At the treatment Plant the raw water quality is monitored for inlet turbidity (NTU). There are set-points for maximum critical turbidity, if reached will shut down the plant, open a bypass to discharge to waste (allowing for continued turbidity monitoring), and initiate an alarm.

When the turbidity is in working range, the raw water is pumped up to a set-point working pressure by two of three inline (duty/standby) VFD controlled centrifugal pumps, for the filters and distribution to function.

The first part of treatment is filtration, starting with 50 micron a pre-screen self-cleaning strainer to remove larger particulate. The raw water proceeds through a cartridge filter in a single housing unit with 3x 1 micron cartridges. The pre-screen strainer and cartridge filter are monitored by a pre and post pressure gauge on each unit to monitor pressure head-increase. A PLC controls the monitored pressure with set-points to protect the filters, and warn of replacement. To protect filters if high pressure differential across the filter housings are reached, the PLC can stop pumps, shut down the plant and discharge to waste, and initiate an alarm.

The post filtered water is continuously sampled for turbidity and transmittance (UVT). Set-points on both analysers control plant operations via PLC, and if critical; shut down the plant, discharge to waste, and initiate an alarm.

When turbidity (NTU) and transmittance (UVT) levels are in working range, the filtered water enters the UV reactor, and is irradiated to disinfect for protozoa.

The filtered/UV irradiated water is then chlorinated to a set-point. Chlorine dose is controlled by the analyser by monitoring flow, Cl<sub>2</sub> residual (set-point) and pH. After chlorination, water enters the distribution system.

Council's SCADA system monitors the Hook treatment plant, recording daily water usage, pump hours, NTU, pressure differential, UVT, chlorine dosage, temperature, pH and outgoing pressure. When parameters are breeched in some of the above and other functions, the SCADA can also send out alarms via txt/sms to all operators. The SCADA system also provides a control function to switch pumps on and off as required.

The maximum output the plant can do is 20 L/sec, and is throttled by an orifice to govern it, so it cannot exceed 20 L/sec.

At present the filtration and UV process is not functioning due to a fine particulate issue in the raw water source. This fine particulate blinds and causes damage to the plant filters and rendered the UV reactor inoperable, by clogging the turbidity meters and UV analyser. Therefore the plant does not have any operable protozoal treatment barriers, only chorine disinfection at present.

Because of the fine particulate issue, the old plant has not been dismantled. This is so it can be used if required due to a failure, and or during the proposed stage two upgrade of the new plant.

Therefore, the raw source water can still flow into the old Hook Plant control tank when required, which is controlled by a ballcock valve. Flow out of the tank is determined by demand. A stainless steel mesh filter is installed at the tank inlet.

The tank serves as a contact tank for chlorination as well as a holding/balancing tank. Chlorine is injected only when flows enter the tank, controlled by a flow switch on the intake. When running, the chlorine pump injects chlorine at an operator input set rate irrespective of the actual flow into the tank.

## Appendix A:

### Individual System Description and Overview

During peak demand, a pump (fixed speed, controlled by tank level measurement and timer [on/off]) located immediately downstream of the tank can be manually operated to boost supplies but the success of this operation is limited by the small capacity (25 m<sup>3</sup>) of the tank. This pump is also used to clear airlocks in the reticulation and restart the supply.

#### Distribution

Four booster pump stations operate on pressure switch and timer control process in the supply distribution. They are located at Brownleas Rd (not in use), Triangle Rd, Waituna School Rd and Garlands Rd.

The Hook Waituna scheme extends to Willowbridge settlement, some 20 km away (as the crow flies) and also encircles urban Waimate. The urban water supply network and the Hook Waituna network cross at numerous locations. At two such points the supplies are connected at Manchesters Road and Mill Road. This has the effect of boosting the supply into the rural water scheme network. Non-return valves prevent backflow from the rural scheme into the urban supply.

The area known as Willowbridge at present is permanently supplied by the Waimate Urban water Supply from the Manchesters Road connection. This is because the Hook Water Supply under normal demand cannot provide enough treated water via the reticulation. In peak high demand periods the Waimate Urban Water Supply can also supply the Studholme and Bathgates Road Area from the Manchesters Road connection. Also Garlands to Uretane Road Area from the Mill Road Connection. The Waimate Water Supply (WINZ Code: WAI033, Grading Ab) has a current Water Safety Plan (Waimate Water Supply Water Safety Plan, Version 2.0 February 2014).

#### Management and Operation:

The scheme is administered at the main council offices in Queen Street, Waimate and operated and managed by the Council's Utilities Services Unit (USU) based at Wilkin Street nearby. Five qualified field staff are appointed to operate and maintain the rural water scheme plant, fixing leaks etc. as generally advised by the public. Water samples are sent to MedLab laboratories for bacteriological testing.

The issue at the time of writing this WSP has been submicron particulate in the raw source water, which has been causing the blinding and damage of the 50 micron screen, and blinding of the 1 micron filter. This has meant that the 50 micron screen, the 1 micron filter and UV reactor are offline due to the submicron particulate issue. The only process still functioning is chlorine disinfection.

Council recognises that the way the treatment plant is functioning does not comply with protozoal compliance under the NZDWS 2005 (rev 2018). Attempts have been made to rectify, such as the aggressive flushing of the transmission line from the intake to the treatment plant with no improvement. The next was the rebuilding of the intake gallery, which was also unsuccessful in the attempt of stopping the submicron particulate entering the treatment process.

A particulate analysis was done to identify the percentage of particulate size and quantity, and from those results it was recognised that it was the submicron particulate that was cause of the blinding and damage issues. It was also recognised because of its size it couldn't be easily stopped from entering the abstraction and treatment process.


The Waimate District Council currently (2021) is putting a request for proposal (RFP) together, using the earlier contractor involvement procurement method for a build design contract. This RFP will also include the DWSNZ 2005 (Revised 2018) upgrade for Lower Waihao. This method of procurement and design build gives greater assurity in achieving functional, reliable and DWSNZ

2005 (Revised 2018) compliant plants that produce safe drinking water for consumers. Both plants historically have had a fine particulate issue. There is also some costing saving benefits where some equipment from Hook Treatment Plant can be used at the upgraded Lower Treatment Plant.

## System Information

System Information – Hook Waituna			
<b>Connections</b>	532	<b>Treated Water Storage (Reservoir)</b>	
- Metered unrestricted	-	<b>Upper Hook Rd</b>	
- Metered restricted	532	Built (yr)	1973
- Unmetered Residential	-	Capacity	25 m <sup>3</sup>
		Material	Concrete
<b>Water Sources</b>	(Consent volumes)	<b>Treatment</b>	
Hook River	1,728 m <sup>3</sup> /day	Screen	
		Chlorine	
<b>Resource Consent</b>	<b>Expiry date</b>	<b>To</b>	
CRC980385	21/05/2034	Construct a rock weir	
CRC980386	21/05/2034	Take water	
<b>Replacement Cost</b>		<b>Reticulation length</b>	
Total Scheme	\$6.6m	252.3 km	


Appendix Figure 24: Scheme Components




Appendix A:

Individual System Description and Overview

**Appendix Figure 25: Water Pipes Diameter Range**




**Appendix Figure 26: Water Pipes Material Length**



Approximately 70% (181km) of the reticulation is PE, of which 113km of pipe will reach its expected economic useful life within 11-15-year window. The remainder of the network consists mainly of PVC (25%) and AC (4%). There is 2m of steel which will be pipes from bore to surface pump.




**Appendix Figure 27: Water Pipes Install Year (10 Year Groups)**

Approximately 73% of the Hook Waituna water supply scheme assets were installed in 1973 and are 51 years old. The remaining 27% have been installed since 2001 and are aged between 1 – 23 years.

Appendix A:


Individual System Description and Overview

**Appendix Figure 28: Remaining Life of all Assets – Long Term**




At present asset useful lives are based primarily on book values with some adjustment for known risk factors. These will be refined by determining evidence-based useful lives using a combination of condition and performance data.


**Appendix Figure 29: Water Pipes Replacement (Length) – Long Term**



Appendix Figure 30: Water Pipes Replacement Value – Long Term




Appendix Figure 31: Water Pipes Replacement (Length) - 1 to 30 Years



Appendix A:

Individual System Description and Overview


**Appendix Figure 32: Water Pipes Replacement Value 1 to 30 Years**



**Appendix Table 3: Plant Replacement Value 1 to 30 Years**


AssetGroup	Remaining Useful Life (5 year groups) Replacement Costs (\$)							Grand Total
	0 or less	1 - 5	6 - 10	11 - 15	16 - 20	21 - 25	26 - 30	
Disinfection Process	\$4,961	\$25,417	\$26,980					\$57,357
Electrical	\$28,356	\$6,498	\$55,933	\$4,081		\$44,062	\$9,514	\$148,443
Monitoring Control	\$11,503	\$17,213	\$7,003		\$82			\$35,801
Pipework	\$25,056	\$497	\$16,190	\$11,220		\$9,588	\$15,183	\$77,734
Pre-treatment	\$14,396							\$14,396
Pump	\$9,351	\$5,030	\$39,534	\$16,555				\$70,471
Structure	\$31,283	\$19,421	\$3,872	\$10,471		\$7,530		\$72,577
Telemetry		\$9,818	\$7,466					\$17,283
<b>Grand Total</b>	<b>\$124,906</b>	<b>\$83,894</b>	<b>\$156,977</b>	<b>\$42,328</b>	<b>\$82</b>	<b>\$61,180</b>	<b>\$24,696</b>	<b>\$494,064</b>

Appendix Figure 33: 30 Year Renewal Profile




The above chart shows the theoretical replacement profile based on asset expected useful lives. It also includes the smoothed 10 year average renewals requirement that indicates a declining average renewals requirement over the thirty year period.

Appendix Figure 34: Hook Waituna Schematic



Appendix Figure 35: Hook Waituna Scheme Plan



## A.4 Lower Waihao Water Scheme

### Overview

The Lower Waihao water supply scheme is a “minor drinking water supply” that supplies water to 225 Lower Waihao Rural Water Scheme connections with a population of about 483. It also supplements 72 Waikakahi Rural Water Scheme connections in the Waikakahi East area, with a population of about 132. This makes a total population of about 615 served by the Lower Waihao water supply scheme. The Waimate District Council target rate 233 properties for the supply of water in this scheme. Some scheme consumers have more than one point of supply connection on their rated property. Each point of supply connection is required to have water storage for 96 hours (four days) in case of interruption of the water supply.

The Lower Waihao sources its water from a shallow 14m bore in the road reserve on Ferry Road, Glenavy, near the Waitaki River. This bore suffers from a fine particulate issue. A submersible pump pumps the water into a balance tank. The treatment plant does not have any protozoal treatment barriers, only chlorine disinfection. The raw water is chlorinated and boosted to a booster pump station, then onto a reservoir located some 4.5 km away at Pikes Point corner. The Lower Waihao augments Waikakahi East via two booster pumps that supply a reservoir in the Waikakahi Scheme

The length of the Lower Waihao reticulation network is approximately 131km over an area of 176 km<sup>2</sup>. The majority of pipe network (60%) was installed in 1978 and is 46 years old.

### History

The Lower Waihao water supply scheme was established in 1978 and the majority of the scheme reticulation dates from this time.

The original shallow bore was found to run dry during Project Aqua low flow regime trials in 2001/02. A new, deeper well was constructed adjacent to the existing well.

Approximately 3.2 km of asbestos-cement pipes was replaced in 2006 (with PVC-U pipe) due to repeated failures occurring in this section.

In 2007 a replacement supply source from the lower Waihao RWS was connected to the Clayton Reservoir serving the eastern portion of the Waikakahi RWS. This effectively joins this supply area to the Lower Waihao scheme. The Clayton Reservoir is no longer supplied from the Waikakahi source.

With the changes in environment, technology and legislation, the upgrading of the Lower Waihao Intake was deemed to be necessary.

Three attempts were made to find a secure bore source. Bores were drilled on Ross Road, Ferry Road and Pikes Point Road. The raw water quality at Ross Road and Ferry Road suffered from fine sand particulate, and raw water quantities (Litres per second) were insufficient. At Pikes Point Road the raw water quality suffered from high hardness (250mg/L), and the cost of treatment made it prohibitive.

The existing site was re-looked at, and the mitigation of the observed risks. It was noted that since the installation of pivot irrigators on the adjacent land owner’s property, and the lining of the stream that passes the intake, favourable effects on the raw water quality at the Intake had been observed.



Owners of the properties inside the Lower Waihao Intake Group or Community Drinking-water Protection Zone (Environment Canterbury) and Water Supply Protection Area (Waimate District Council) were informed of Councils intentions to remain at the existing intake. The two landowners directly affected, were invited to a meeting on the 2 July 2015. Present were Dan Mitchell (WDC Asset Group Manager), Paul Roberts (WDC Water & Waste), Gerardus Vant'Klooster, Joy Burke and her consultant. From that discussion it was agreed that a Water Safety Plan would be drafted to look at the risks for the new plant, and how to mitigate those risks, and then proceed.

On the 7 August 2015 a new shallow bore was drilled and established for the construction of a new treatment plant. The bore is a shallow bore at 14m's deep, with a 273mm diameter 304 stainless steel casing, and a stainless steel wedge wire screen set a 5 - 7m below ground level. The bore is situated approximately 220m from the Waitaki River (on the road reserve of Ferry Road, Glenavy).

After the discovery on 30 March 2016 of a significant groundwater level reduction by 1.7 metres in the two existing wells, and with no signs of recovery. A new submersible pump was installed in the recently established 14m shallow bore, plus a variable speed drive, level switches, balance tank where installed and commissioned on the 14 April 2016, by council staff and contractors. This was successful in ensuring that the scheme continued to meet consumers' expectations. The setup will remain in operation until the Ministry of Health Subsidy Upgrade, where the assets purchased will be re-used in the upgrade.

The Lower Waihao Intake was due in 2015/16 to be upgraded with the aid of the Capital Assistance Programme (CAP) funding to comply with the Drinking Water Standards for New Zealand. Work was put on hold due to the discovery of fine particulate in the raw water source in the new bore. Testing on a 1-micron filter indicated that the fine particulate would cause issue, after blinding and breaking through the 1-micron filter in 5 days. As the fine particulate issue is similar to the Hook Treatment Plant Intake, the option of an un-validated membrane is a possible solution. The Trailing of a small un-validated membrane unit is planned for early 2018.

## **System Description**

### Source and Catchment:

The lower Waihao sources it water from a shallow 14m bore in the road reserve on Ferry Road, Glenavy, near the Waitaki River. Around the bore the land is almost entirely low land pasture used for dairy farming under private ownership. The wider catchment above the Lower Waihao Water Supply the catchment is extensive, and it includes the Waitaki River that extends over 150 km inland to the Main Divide, taking in a wide range of land use activities, including the Waitaki hydroelectric power schemes. Part of that catchment includes the flat terraced land from the Stonewall (SH 82) to Ferry Road. In this area, there is predominantly dairy farming and irrigation used. This equates overall to >7615 hectares of wider catchment.

The nearby catchment around the bore is protected under the Waimate District Council District Plan "Water Supply Protection Area", which runs approximately 2 km north and west of the supply bore. The "Protection Area" is divided into two areas, "Inner" at 83 hectares, and the "Outer" at 330 hectares. The Regional Councils "Community Drinking Water Protection Zone" partially overlaps the "Protection Area" and extends into the Waitaki River at 332 hectares.

Inside the "Inner Protection Area" there is agricultural activity such as dairy farm grazing, irrigation and three silage pits. There is also a consented diverted lined stream that runs down the west side of Ferry Road and across from the shallow bore. In the "Outer Protection Area" there is human and

## Appendix A:

### Individual System Description and Overview

agricultural activities that include dairy farming, irrigation, a dairy shed with effluent pond, wintering over barn, and two dwellings with septic tanks.

In the wider catchment in the low land pasture made up of pastoral grasses, with livestock such as sheep (>100), beef cattle (>100) and dairy cows (>1000) that graze in the catchment. There is also estimated 50 secondary-treated sewage systems, 70 septic tanks, and 8 dairy effluent ponds.

The overall assessment of the catchment, plus the impact from human and agricultural activities, equates to a four (5) Log treatment process requirement to provide wholesome, compliant drinking water to the consumers on the Hook-Waituna Rural Water Supply.

#### Abstraction:

Water is sourced from a single 14m shallow bore in a 273mm diameter, 304 stainless steel casing and with a stainless steel wedge wire screen set a 5 - 7m below ground level. The bore is situated approximately 220m from the Waitaki River in the road reserve of Ferry Road, Glenavy. A VFD controlled submersible pump set at 10 meters below ground level, pumps according to demand, to keep the pre-treatment balance tank to a set point level.

The other two onsite wells for the Lower Waihao Intake plant are unable to produce sufficient quantities of raw water to be useable.

#### Treatment Plant:

The Lower Waihao Intake plant does not have any protozoal treatment barriers, only chlorine disinfection. From the pre-treatment balance tank a single duty 37 kW delivery pump draws off the raw water. Disinfection is by way of chlorine gas injection directly into the suction side of the reticulation delivery pump, on the rising main. The chlorinator dose rate is automatically controlled to maintain a Free Available Chlorine (FAC) set-point level as measured and monitored by a chlorine analyser (automated closed loop process controller). The chlorination system operates whenever the reticulation delivery duty pump is running.

Council's SCADA system monitors the intake and reservoirs recording daily water usage, pump hours, chlorine dosage, and reservoir levels. The onsite SCADA PLC's also provides a control function between the remote units (RTU) at the intake and reservoir to switch pumps on and off as required.

#### Distribution:

The Lower Waihao Intake plant duty pump on Ferry Road, delivers water at a constant rate to a reservoir located some 4.5 km away at 110m above sea level. To boost the supply a single in-line booster pump is installed at the Pikes Point Road pump house approximate 4km from the main pump house but prior to the final 50m of lift to the reservoir. The pumping system is controlled by sensors located within the reservoir. The control system is linked to SCADA.

Water gravitates from the reservoir into the distribution network. A portion of the distribution zone is served from direct connections to the pumped rising main. This means that when the pump is running water is pumped directly to these connections. When the pump is off water gravitates back down the rising main to maintain supply.

The Lower Waihao supply is connected to the Waikakahi Rural supply (WINZ Community Code WAI032). Two booster pumps (Pikes Point Road and Dog Kennel Road) elevate water to Dog Kennel Hill reservoir, serving East Waikakahi connections. An average of 180m<sup>3</sup>/day is supplied.

#### Management and Operation:

## Individual System Description and Overview


The scheme is administered at the main council offices in Queen Street, Waimate and operated and managed by the Council's Utilities Services Unit (USU) based at Wilkin Street nearby. Five qualified field staff are appointed to operate and maintain the rural water scheme plant, fixing leaks etc as generally advised by the public. Water samples are sent to MedLab laboratories for bacteriological testing.

The Waimate District Council currently (2021) is putting a request for proposal (RFP) together, using the earlier contractor involvement procurement method, for a build design contract. This RFP will also include upgrade for Hook Treatment Plant. This method of procurement and design build, gives greater assurity in achieveing functional, reliable and DWSNZ 2005 (Revised 2018) compliant plants that produce safe drinking water for consumers. Both plants historically have had a fine particulate issue. There is also some costing saving benefifits where some equipment from Hook Treatment Plant can be used at the upgraded Lower Treatment Plant.


### System Information

System Information – Lower Waihao			
<b>Connections</b>	225	<b>Treated Water Storage (Reservoir)</b>	
- Metered unrestricted	-	<b>Ferry Rd</b>	
- Metered restricted	-	Built (yr)	1978
- Unmetered Residential	-	Capacity	350 m <sup>3</sup>
		Material	
<b>Water Sources</b>	(Consent volumes)	<b>Treatment</b>	
Waitaki River (bore)	1,633m <sup>3</sup> /day	Chlorine	
<b>Resource Consent</b>	<b>Expiry date</b>	<b>To</b>	
CRC940846	23/02/2029	Take groundwater	
<b>Replacement Cost</b>		<b>Reticulation length</b>	
Total Scheme	\$6.3m	130.9 km	


**Appendix Figure 36: Scheme Components**



**Appendix Figure 37: Water Pipes Diameter Range**




**Appendix Figure 38: Water Pipes Material Length**



Approximately 62% of the Lower Waihao water supply scheme reticulation was installed during the year group 1971-1980 (44 - 53 years old). The remaining pipes have been installed since 2001 and are aged between 1-23 years. The reticulation consists mainly of PVC (51%) and PE (49%).


**Appendix Figure 39: Water Pipes Install Year (10 Year Groups)**



Appendix A:


Individual System Description and Overview

**Appendix Figure 40: Remaining Life of all Assets – Long Term**




At present asset useful lives are based primarily on book values with some adjustment for known risk factors. These will be refined by determining evidence-based useful lives using a combination of condition and performance data.


**Appendix Figure 41: Water Pipes Replacement (Length) – Long Term**



Appendix Figure 42: Water Pipes Replacement Value – Long Term




Appendix Figure 43: Water Pipes Replacement (Length) – 1 to 30 Years



Appendix A:

Individual System Description and Overview

**Appendix Figure 44: Water Pipes Replacement Value 1 to 30 Years**




**Appendix Table 4: Lower Waihao Plant Replacement Value 1 to 30 Years**

AssetGroup	Remaining Useful Life (5 year groups) Replacement Costs							Grand Total
	0 or less	1 - 5	6 - 10	11 - 15	16 - 20	21 - 25	26 - 30	
Disinfection Process	\$26,583	\$13,596		\$34,197	\$15,571		\$53,507	\$143,453
Electrical	\$11,150	\$9,535	\$21,372	\$24,400	\$81,922	\$1,813	\$14,121	\$164,312
Mechanical Process					\$255,297		\$377,363	\$632,660
Monitoring Control	\$3,648	\$4,873	\$31,724	\$101,784	\$52,143			\$194,173
Pipework	\$15,096	\$751	\$7,574	\$767	\$10,700	\$2,173	\$16,135	\$53,196
Pump	\$17,600	\$31,222		\$23,207	\$106,271			\$178,299
Structure	\$31,212	\$760		\$1,410	\$21,337	\$12,646	\$22,043	\$89,409
Telemetry	\$46,206			\$12,434				\$58,640
Treatment	\$2,686				\$6,512			\$9,198
<b>Grand Total</b>	<b>\$154,180</b>	<b>\$60,736</b>	<b>\$60,670</b>	<b>\$198,200</b>	<b>\$549,753</b>	<b>\$16,632</b>	<b>\$483,170</b>	<b>\$1,523,341</b>




Appendix Figure 45: 30 Year Replacement Profile




The above figure shows the theoretical replacement profile based on asset expected useful lives. It also includes the smoothed 10 year average renewals requirement that indicates nibor renewals requirements in the 1-10 year period and 21-30 year period and greater renewals in the 11-20 year period.

Appendix Figure 46: Lower Waihao Schematic



Lower Waihao & Waikakahi East: Schematic

Appendix Figure 47: Lower Waihao Scheme Plan



## A.5 Otaio Makikihi Water Scheme

### Overview

The Otaio Makikihi water supply scheme is a “small drinking water supply” that supplies water to 227 tank connections (170 different owners) with an estimated population of 430. The Waimate District Council target rates 162 properties for the supply of water in this scheme. Some scheme consumers have more than one point of supply connection on their rated property. Each point of supply connection is required to have water storage for 96 hours (four days) in case of interruption of the water supply, and is a requirement of the Rural Water Scheme Policy.

The Otaio-Makikihi rural water supply’s primary source of raw water is from the Tavistock Bore. Currently the bore is “Provisionally Secure” and is protozoal compliant. Ground water is drawn from the bore, chlorinated and pumped into the reticulation. A booster pump station up on Esk Valley Road boost water up towards the old Otaio Reservoir, and back towards to Pakihi Road. There is a second surface water take for the supply that is not used. This source is not protozoal compliant or readily operable due to damage of the gallery from a weather event, but could be made operational if needed.

The approximate length for the reticulation network is 158 km.

### History

The Otaio-Makikihi water supply scheme was established in 1969 and the majority of the scheme reticulation dates from this time. The intake and pumping equipment was upgraded and relocated in 1999. A 10km supply loop upgrade was commissioned in 2004. Treatment control improvements (automatic dosing, chorine analyser, pH monitoring) and SCADA were completed in 2008.

In December 2013 Tavistock Bore and Campbell Forrest Booster were commissioned. Tavistock Bore Intake became the main duty intake as of that time. The Otaio Gorge Intake is now a standby system. The Otaio Gorge Intake is isolated form the distribution network by two valves at the Otaio Reservoir.

The upgrading of Otaio-Makikihi Intake to the new Tavistock Bore came about through the Governments TAP and CAP (Technical Assistance Programme and Capital Assistance Programme, to help communities comply with DWSNZ 2005 [revised 2018], and provide safe drinking water) funding, plus the finding/drilling of a suitable bore on Tavistock Road.

In the winter of 2015 a heavy rain event washed away the Otaio Gorge Intake gallery infiltration bed and wedge wire screen, along with a short section of rising main to the Otaio Reservoir.

On 26 October 2016 >1 E.coli was found in a monthly monitoring sample of raw ground water at Tavistock Bore. The bore lost its “Secure Bore” status and became “Provisionally Secure”. 12months of monitoring started immediately to achieve compliance again with criterion 3 of the DWSNZ 2005(revised 2018) for bore water security. The first three months of weekly monitoring were clear and so was the remaining 9 months of monthly monitoring.

## **System Description**

### Source and Catchment:

Raw water for the Otaio-Makikihi rural water supply can be sourced from two intakes. The primary source is a ground water take called Tavistock Bore on Tavistock Road, and the second/standby source is a surface water take on the Otaio River, called Otaio Gorge Intake.

Tavistock Bore is in road reserve on Tavistock Road near the Sodwall/Horseshoe Bend Road, which is on top of a hill ridge amongst rolling hill country. The surrounding country land use is a mixture of arable cropping, pastoral grasses, sheep and dairy farming. With the bore being 156.3 m deep, it is not directly influenced by the near land use activities. The Regional Council “Community Drinking Water Protection Zone” is a 100m radius circle around the bore at 3.1 hectares. The precise location of the catchment is unknown. It could be somewhere in either the Cannington basin or the upper South Coastal Canterbury area. From bore the logs it would indicate that the bore is drilled in what is known as the Cannington gravels, and most likely drawing from the Lower Kowai Formation. The ground water from the bore has a mean age of 134 years, and less than 0.005% water less than a year old.

The overall assessment of the Tavistock Bore catchment, plus the impact from human and agricultural activities has no known impacts.

Otaio Gorge is the secondary backup source for raw water and not used unless required. The wider catchment around the Otaio Gorge Intake is approximately 4830 hectares. The wider catchment is made up largely of upland pasture grasses and tussock. There are small pockets of bush and forests in the upland area as well. Nearer to the intake there is small proportion of lowland pastures. In the catchment there can be around 200 beef cattle grazing intermittently, and seasonal grazing of about 1000 sheep. In the upland hill catchments there are small numbers of feral pigs, deer, goats and wallabies.

In the catchment only 16% of it is protected. The Waimate District Council District Plan “Water Supply Protection Area” is only 780 hectares and completely overlaps the Regional Council “Community Drinking Water Protection Zone” of 18.2 hectares. In the “Protection Area and Zone”, there are at least two if not three septic tanks. One is at the Department of Conservation Camp ground beside the river. The other one or two around the Otaio Gorge Station Homestead and buildings.

The overall assessment of the Otaio Gorge catchment, plus the impact from human and agricultural activities, equates to a four (4) Log treatment process requirement to provide wholesome, compliant drinking water to the consumers on the Otaio-Makikihi Rural Water Supply.

### Abstraction:

#### **Tavistock Bore**

The raw water for Tavistock Bore is drawn from a 200mm Ø steel cased bore at 156.3m, with 3m stainless steel screen set between 153.6 and 156.3m. A 30 kW submersible pump is set at 132m below ground level to abstract the ground water. Static ground water level is 104m below ground level. The bore is currently is “Provisionally Secure” and is protozoal compliant.

“Secure Bore” status has not been sought after for this bore, as it is a questionable methodology to prove that the water drawn from it is safe. Instead Council will seek to meet criterion 2 (Borehead Security) DWSNZ 2005 (revised 2018) and use treatment at the Plant for bacterial and protozoal compliance.

## Appendix A:

### Individual System Description and Overview

#### **Otaio Gorge**

The Otaio Gorge Intake raw water was sourced from an infiltration gallery consisting of a single 175mm Ø, 9m Stainless Steel wedge wire screen (1mm gaps) located in the bed of the Otaio River. From the gallery the water would enter a shallow well on the north bank of the river. In the shallow well there are two submersible pumps housed within shrouds. However, in the winter of 2015 the gallery infiltration bed and wedge wire screen were washed away, along with a short section of rising main to the Otaio Reservoir. The intake in its current state is inoperable, but could be temporarily made operational if required.

#### Treatment Plant:

#### **Tavistock Bore**

The raw water enters the Tavistock treatment plant and passes through a UV reactor, to treat for protozoa and flows through into a balance tank. A chlorine gas solution is dropped into the balance tank. The chlorine solution is made with chlorine gas via a venturi on the dose water line to the balance tank. The dose is controlled by chlorine analyser monitoring flow, Cl<sub>2</sub> residual (setpoint) and pH.

#### **Otaio Gorge**

The Otaio Gorge plant does not have any protozoal treatment barriers, only coarse filtration and chlorine disinfection. If required a dose pump can pump a chlorine solution (sodium hypochlorite) directly into the rising main at the top of the submersible pump riser when the duty pump was running. The chlorinator dose rate was automatically controlled to maintain a Free Available Chlorine (FAC) set-point level as measured and monitored by a chlorine analyser (automated closed loop process controller). The chlorination system operates whenever the submersible duty pump is running.

Note, this plant is only a back up if there was ever a failure at Tavistock Bore Treatment Plant, and it could not produce water for supply.

#### Distribution:

Tavistock Bore and treatment plant is the primary and current source of water for the Otaio Makikihi supply. Distribution of compliant chlorinated water is drawn from the balance tank, and pumped around the scheme by four VFD surface pumps (duty/standby setup) working to a setpoint line pressure. It is also boosted at Campbell and Forrest Road at the Campbell Forrest Booster. Note the old reservoir is not used in this distribution setup.

If required as a second source of supply, the Otaio Gorge Intake and its submersible pump can deliver water back across the river (if temporarily repaired) at a constant rate to the Otaio Reservoir located some 5.5 km away at 220m above sea level. From there water would gravitate into the distribution network. Booster pumps are not required when the Otaio Gorge Intake is operating. The pump is controlled by sensors located within the reservoir. The control system is linked to SCADA and all inputs are powered by mains electricity. Low level protection for the main pump is provided. As mentioned this is only a back up option if it was required.

Council's SCADA system monitors both intakes and reservoir recording daily water usage, pump hours, chlorine dosage, temperature, pH and reservoir levels. When parameters are breached in some of the above and other functions, the SCADA can also send out alarms via txt/sms to all operators. The SCADA system also provides a control function to switch pumps on and off as required.

#### Management and Operation:


## Individual System Description and Overview

The scheme is administered at the main council offices in Queen Street, Waimate and operated and managed by the Council's Utilities Services Unit (USU) based at Michael Street nearby. Five qualified field staff are appointed to operate and maintain the rural water scheme plant, fixing leaks etc as generally advised by the public. Water samples are sent to MedLab laboratories for bacteriological testing weekly, with results being entered into WINZ database.


## System Information

System Information – Otaio Makikihi			
<b>Connections</b>	227	<b>Treated Water Storage (Reservoir)</b>	
- Metered unrestricted	-	Colliers Rd	
- Metered restricted	227	Built (yr)	1969
- Unmetered Residential	-	Capacity	360m <sup>3</sup>
		Material	
<b>Water Sources</b>	(Consent volumes)	<b>Treatment</b>	
Otaio River	929m <sup>3</sup> /day	Chlorine	
<b>Resource Consent</b>	Expiry date	To	
CRC981876.1	22/04/2034	Take surface water	
CRC992050	22/04/2034	Install & maintain intake	
<b>Replacement Cost</b>		<b>Reticulation length</b>	
Total Scheme	\$6.5m	158.4 km	


Appendix Figure 48: Scheme Components



**Appendix Figure 49: Water Pipes Diameter Range**




**Appendix Figure 50: Water Pipes Material Length**




Approximately 59% of the Otaio Makikihi water supply scheme reticulation were installed during 1969 and are 55 years old. The remaining 41% have been installed since 1971 and are aged between 1-53 years. The reticulation consists mainly of PE (69%) and PVC (27%).



**Appendix Figure 51: Water Pipes Install Year (10 Year Groups)**




**Appendix Figure 52: Remaining Life of all Assets – Long Term**




At present asset useful lives are based primarily on book values with some adjustment for known risk factors. These will be refined by determining evidence-based useful lives using a combination of condition and performance data.

Appendix A:  
Individual System Description and Overview


**Appendix Figure 53: Water Pipes Replacement (Length) – Long Term**




**Appendix Figure 54: Water Pipes Replacement Value – Long Term**



**Appendix Figure 55: Water Pipes Replacement (Length) - 1 to 30 Years**



**Appendix Figure 56: Water Pipes Replacement Value 1 to 30 Years**




Appendix A:  
Individual System Description and Overview

**Appendix Table 7: Otaio Makikihi Plant Replacement Value 1 to 30 Years**


AssetGroup	Remaining Useful Life (5 year groups) Replacement Costs (\$)							Grand Total
	0 or less	1 - 5	6 - 10	11 - 15	16 - 20	21 - 25	26 - 30	
Disinfection Process	\$26,644	\$28,358	\$13,596	\$30,982				\$99,579
Electrical	\$3,360	\$19,213	\$117,477	\$6,077		\$60,364	\$17,579	\$224,070
Monitoring Control	\$3,869	\$7,959	\$63,747					\$75,575
Pipework	\$4,563		\$16,913	\$3,399	\$8,812	\$1,606	\$23,185	\$58,479
Pump	\$36,193	\$1,468	\$120,648					\$158,309
Structure	\$73,083	\$956		\$1,627		\$19,726	\$32,302	\$127,694
Telemetry	\$20,063	\$19,023						\$39,086
<b>Grand Total</b>	<b>\$167,775</b>	<b>\$76,976</b>	<b>\$332,382</b>	<b>\$42,085</b>	<b>\$8,812</b>	<b>\$81,696</b>	<b>\$73,066</b>	<b>\$782,792</b>

**Appendix Figure 57: 30 Year Replacement Profile**




The above figure shows the theoretical replacement profile based on asset expected useful lives. It also includes the smoothed 10 year average renewals requirement that indicates renewals requirements in the 1-10 year period and 21-30 year period and minor renewals in the 11-20 year period.

Appendix Figure 58: Otaio Makikihi Schematic



Appendix A:  
Individual System Description and Overview

**Appendix Figure 59: Otaio Makikihi Scheme Plan**



## A.6 Waihaorunga Water Scheme

### Overview

The Waihaorunga rural water supply scheme is a “small drinking water supply” and supplies water to 42 connections with a total population of about 141 (*WINZ data*). The scheme supplies an area of 105 square km on the north bank of the Waitaki River and to the west of the Waikakahi water supply. The Waimate District Council target rates 30 properties for the supply of water in this scheme. Some scheme consumers have more than one point of supply connection on their rated property. Each point of supply connection is required to have water storage for 96 hours (four day) in case of interruption of the water supply.

The supply has two raw water sources from surface takes. Both sources take water from separate streams via galleries. The Main Intake does not have any protozoal treatment barriers, only chlorine disinfection before pumping up to the Main Reservoir, and into the distribution network. Tavendale also does not have any protozoal treatment barriers, only a pre-treatment roughing filter with chlorine disinfection, then supplies water by a combination of gravity and pumping into the distribution network.

Although the Waihaorunga water supply scheme operates in two separate zones each with separate intakes and treatment, the main pump intake can supply the total scheme area.

The approximate length for the reticulation network is 65km.

A large proportion of the water produced for the supply is consumed for the purposes of commercial agriculture. About 41 habitable dwellings have access to the water supply. This equates to 19% human consumption of the sold volume (based on 1500L/day/dwelling).

### History

The Waihaorunga water supply scheme assets were installed in 1977 and the majority of scheme components are 47 years old. A second gravity source was installed in 1993 and the main pump station was refitted in 2000.

### System Description

#### Sources and Catchment:

#### **Waihaorunga Main**

The Waihaorunga water supply has two raw water sources. The Waihaorunga Main from an infiltration gallery in Waihaorunga Creek, and Tavendale from a shallow gallery in a tributary to Waihaorunga Creek.

Around the Main Intake, the wider catchment is predominately upland pasture with some lowland pasture around the intake, totalling 1519 hectares approximately. 29.9 hectares of that catchment is “Water Supply Protection Area” under the Waimate District Council District Plan, which overlaps the 28.9 hectare Regional Council “Community Drinking Water Protection Zone”. There is some riparian management around the Waihaorunga Creek, upstream from the gallery that is fenced off from stock. The land in the wider catchment is dry stock country and mainly sheep at approximately 1.6 sheep per hectare in the wider catchment. This can mean up to 3000 sheep can be area, or part of rotating through. There are also about 150 beef cattle in the area too, along with pest animals such as wallabies (150 approx.). There are regular culling programmes to reduce wallaby numbers. Also in the wider catchment there are three dwellings with septic tanks, two woolsheds, and a small

## Appendix A:

### Individual System Description and Overview

irrigation dam on one of the tributaries of the Waihaorunga Creek, as well as a dual silage pit that are outside of the “Protection Area” and “Zone”.

#### **Tavendales**

The Tavendale Intake has a much larger catchment of 115 hectares. The District Plan “Water Supply Protection Area” covers the whole area that is the physical catchment for Tavendale, and overlaps the Regional Council “Community Drinking Water Protection Zone”, which is only 17 hectares inside the catchment. This catchment is also predominately upland pasture with some tussock and scrub. Again it is dry stock land with up to 500 head of sheep and 100 beef cattle on and off through the year. This catchment also suffers from pests such as wallabies (100 approx.) 600 square metres approximately has been fenced off around the gallery itself. This protects the gallery and has allowed native scrub to establish itself around the stream, giving it some riparian protection.

The overall assessment of both catchments plus the impact from human and agricultural activities, equates to a four (4) Log treatment process requirement at both sites to provide wholesome, compliant drinking water to the consumers on the Waihaorunga Rural Water Supply.

#### Abstraction:

#### **Waihaorunga Main**

The Waihaorunga Main draws raw water from the infiltration gallery in Waihaorunga Creek. There is about 1 -1.5 metres cover over a perforated pipe. The perforated pipe takes the infiltrate by gravity from the creek to a stilling chamber. Two submersible pumps (duty/standby) in the stilling chamber, pump water into the distribution zone and to the Main Reservoir.

#### **Tavendales**

Tavendale intake shallow gallery has a perforated pipe under a shallow bed of rock and gravels in a gabion mat. The raw water infiltrate enters the perforated pipe and flows away by gravity from the creek to the treatment plant site at the end of Tavendale Road.

#### Transmission:

#### **Waihaorunga Main**

There is no extensive transmission at Waihaorunga Main Treatment Plant as the intake gallery and Treatment Plant are within 30m of each other.

#### **Tavendales**

Tavendale has 1.81 km, 40mm PVC pipeline from the Waihaorunga tributary stream intake gallery to the Tavendale Treatment Plant. The raw water flows under gravity from the stream intake gallery to the Plant.

#### Treatment:

#### **Waihaorunga Main**

Both sources of water for the supply are chlorinated. At the Waihaorunga Main source, the gallery stilling chamber serves as a contact tank for chlorination. Chlorine (sodium hypochlorite solution) is only dosed when the pumps are operating. When running, the chlorine dose pump injects chlorine at an operator set input rate.

#### **Tavendales**

The Tavendale Treatment Plant consists of a small cartridge roughing filter and chlorine disinfection (sodium hypochlorite solution). Water flows into the plant, through the roughing filter, and then chlorine is injected at rate of demand generated by a pulse out of the water meter. The amount



injected by the dose pump is manual set by the operator. The flow rate of water supplied is dictated by the demand from the distribution zone, which is gravity and pump fed.

The present treatment plant has no protozoal treatment barriers. For the plant to be protozoal compliant under the Drinking Water Standard for New Zealand 2005 (revised 2018), the plant needs log four (4) treatment processes to be in place.

Monitoring and control, plus telemetry (SCADA), have been recently installed at the Waihaorunga and Tavendales Treatment Plant sites in 2020 and 2021. This equipment was installed as a part of an agreement with The Ministry of Health, instead of full upgrades of the treatment plants, to allow for potential changes in legislation and standards (Acceptable Solutions), for rural agricultural water supplies.

#### Distribution:

The disinfected water is distributed from both Treatment Plants. They can supply two separate portions of the scheme, or can be linked by valving to augment the other if required.

Waihaorunga Main Intake supplies to the majority of consumer. Two submersible pumps in the gallery stilling chamber pump water into the distribution zone and to the Main Reservoir. From the reservoir a series of pump stations and reservoirs are used to supply the areas at a higher elevation than the Main Reservoir. The Melford pump is located downstream of the Waihaorunga Main reservoir and pumps to the Melford reservoir. The Takitu pump is located downstream of the Melford reservoir and pumps to the Takitu reservoir.

Tavendale Treatment Plant delivers water to the smaller northern portion of the supply around Tavendale Road. The majority of this northern portion is gravity feed from Tavendale Treatment Plant. A booster pump at Tavendale Treatment Plant supplies only two consumer “points of supply” and the Tavendale Reservoir.

There has been in the past limited availability of standby plant within the system. This is being progressively resolved with budgeted capital expenditure, and the purchasing of spare replacement pumps for Takitu and Tavendale pump stations. The Main Intake has always had a duty and standby pump available, and a duty and standby pump at the Melford pump station. Currently there is no electronic supervision or control of the system (SCADA).

#### Management and Operation:

The scheme is administered at the main council offices in Queen Street, Waimate and operated and managed by the Council’s Utilities Business Unit (UBU) based at Michael Street nearby. Five qualified field staff operate and maintain the rural water scheme plant, fixing leaks etc as generally advised by the public. Water samples are sent to MedLab laboratories for bacteriological testing. Currently the Waihaorunga rural water supply has a “Permanent Boil Water Notice”. The notice was issued with the agreement of the Drinking water Assessor in September 2014. The notification is regularly advertised in local papers, Waimate District Council’s website and Facebook page, along with Rural Delivery mail drops. The local water committee also reminds locals on request. In recent times organisations such as the local school and Mobile Kindy have helped advertise the “Permanent Boil Water Notice”.

A large proportion of the water produced for the supply is consumed for the purposes of commercial agriculture, and the supply could potentially qualify as a rural agricultural drinking water supply. Waimate District Council had previously considered the option of point of use treatment on the rural supplies, and discounted the option at that time because of cost and maintenance issues. The option of “point of use treatment” was looked at again with the release of

## Appendix A:

### Individual System Description and Overview


the Rural Agricultural Drinking Water Supply Guidelines (RADWS) in March 2015. Some questions were raised again about actual cost, pre-treatment, maintenance, responsibility issues and liability. Those questions were investigated by exploring successful examples of private “point of entry treatment” supplies under the RADWS in the Waitaki District Council. However, after the Havelock North Stage 1 Enquiry, the issues and risks of such a system make the RADWS not a viable option.

Council has lobbied Government to review the current legislation and standards for Rural Agricultural Water Supplies. Since then the Department of Internal Affairs (DIA) and the new regulator Taumata Arowai have been, and still currently working on an Acceptable Solution option, using point of use (PoE) treatment, which could be used in rural agricultural water supplies.


### System Information

System Information – Waihaorunga			
<b>Connections</b>	<b>42</b>	<b>Treated Water Storage (Reservoir)</b>	
- Metered unrestricted	-	<b>Colliers Rd</b>	
- Metered restricted	42	Built (yr)	1977
- Unmetered Residential	-	Capacity	150 m <sup>3</sup>
		Material	
<b>Water Sources</b>	(Consent volumes)	<b>Treatment</b>	
Waihaorunga Creek	455 m <sup>3</sup> /day	Chlorine	
Tributary of Waihaorunga Creek	121 m <sup>3</sup> /day		
<b>Resource Consent</b>	<b>Expiry date</b>	<b>To</b>	
CRC084608	17/12/2043	Take surface water	
CRC084606	16/12/2043	Take surface water	
<b>Replacement Cost</b>		<b>Reticulation length</b>	
Total Scheme	\$1.4m	65.4 km	

Appendix Figure 60: Scheme Components




Appendix Figure 61: Water Pipes Diameter Range



Appendix A:


Individual System Description and Overview

**Appendix Figure 62: Water Pipes Material Length**




Approximately 86% of the Waihaorunga water supply scheme reticulation were installed during 1977 and are 47 years old. The remaining 14% have been installed since 1991 and are aged between 1-33 years. The reticulation consists of PVC (55%) and PE (45%).

**Appendix Figure 63: Water Pipes Install Year (10 Year Groups)**




**Appendix Figure 64: Remaining Life of all Assets – Long Term**



At present asset useful lives are based primarily on book values with some adjustment for known risk factors. These will be refined by determining evidence-based useful lives using a combination of condition and performance data.


**Appendix Figure 65: Water Pipes Replacement (Length) – Long Term**




Appendix A:

Individual System Description and Overview


Appendix Figure 66: Water Pipes Replacement Value – Long Term



Appendix Figure 67: Water Pipes Replacement (Length) - 1 to 30 Years



Appendix Figure 68: Water Pipes Replacement Value 1 to 30 Years




Appendix A:

Individual System Description and Overview

**Appendix Table 5: Waihaorunga Plant Replacement Value 1 to 30 Years**

AssetGroup	Remaining Useful Life (5 year groups) Replacement Costs (\$)							Grand Total
	0 or less	1 - 5	6 - 10	11 - 15	16 - 20	21 - 25	26 - 30	
Disinfection Process	\$4,211	\$2,941	\$12,650	\$4,878				\$24,679
Electrical	\$57,277	\$6,897	\$9,875	\$4,323	\$488			\$78,861
Monitoring Control	\$14,164	\$929	\$13,742	\$6,777	\$5,937	\$245		\$41,794
Pipework	\$23,949	\$912	\$5,317	\$50	\$5,298	\$1,468	\$7,301	\$44,295
Pre-treatment	\$373				\$769			\$1,141
Pump	\$47,532	\$15,398	\$17,790	\$4,590				\$85,311
Structure	\$44,209				\$3,738		\$13,893	\$61,840
Telemetry			\$10,484					\$10,484
<b>Grand Total</b>	<b>\$191,714</b>	<b>\$27,077</b>	<b>\$69,858</b>	<b>\$20,619</b>	<b>\$16,229</b>	<b>\$1,713</b>	<b>\$21,194</b>	<b>\$348,405</b>


**Appendix Figure 69: 30 Year Replacement Profile**




The above figure shows the theoretical replacement profile based on asset expected useful lives. It also includes the smoothed 10 year average renewals requirement that indicates a declining average renewals requirement over the thirty year period.



Appendix Figure 70: Waihaorunga Schematic



Appendix Figure 71: Waihaorunga Scheme Plan



## A.7 Waikakahi Water Scheme

### Overview

The Waikakahi rural water supply scheme supplies water to 172 connections with a total population of about 360. Of those 172 connections, 57 are in the Waikakahi East area, with a population of about 132. This area is augmented with water from the Lower Waihao rural water supply (WINZ Code: LOW002). The Waimate District Council target rates 121 properties for the supply of water in this scheme. Some scheme consumers have more than one point of supply connection on their rated property. Each point of supply connection is required to have water storage for 96 hours (four days) in case of interruption of the water supply.

The source for the reticulation network is a tributary of the Waitaki River known as the Clear Stream. The intake does not have any protozoal treatment barriers, only pre-treatment roughing filters and chlorine disinfection. Duty/standby pumps deliver chlorinated water to a reservoir 3km away. The reservoir gravity feeds the reticulation network to the west and central part of the scheme. A reservoir that supplies the eastern part of the scheme is supplied via a new rising main from the Lower Waihao Intake via two new booster pumps. This reservoir now receives approximately 180m<sup>3</sup> water per day from the Lower Waihao intake.

The approximate length for the reticulation network is 175km.

A large proportion of the water produced for the supply is consumed for the purposes of commercial agriculture. About 136 habitable dwellings have access to the water supply. This equates to 18% human consumption of the sold volume (based on 1500L/day/dwelling).

### History

The Waikakahi water supply scheme was established in 1973 and the majority of the scheme reticulation dates from this time. Replacements of the larger diameter PVC pipes were carried out in 1980. A connection to the Lower Waihao scheme was completed in 2005 to supply the Waikakahi East area.

### System Description

#### Source and Catchment:

Water is sourced from an intake in a stream originating on the terrace adjacent to the Waitaki River, at the Stonewall site near Ikawai. The stream is known as Clear Stream and the catchment area includes surrounding farmland and the Waitaki River (1562 Ha approx.).

The land use in the catchment around the Waikakahi Intake is mostly upland pasture, with a small percentage of arable cropping, lowland pasture, and riverbed. The activity in the land catchment is predominately dairy, with approximately 1200 dairy cows in the catchment. There is also a small amount of cropping, and bailage. It is important to note that the Waitaki River is also a part of the catchment, and can influence the intake in peak flood times, making the overall catchment very large.

202 hectares of the catchment is protected under the District Plan "Water Supply Protection Area" for Waikakahi rural water supply. This "Area" is mainly in the Waitaki River bed and is overlapped by the Regional Council "Community Drinking Water Protection Zone" (155.5 hectares), with 63.5 hectares inside the "Protection Area", and the other 92 hectares of the "Zone" covers the Waitaki

## Appendix A:

### Individual System Description and Overview

River bed. Inside both the “Protection Area” and “Zone” there is one pre-existing septic tank for a dwelling. Outside the “Protection Area” and “Zone” there are another two known septic tanks for dwellings/buildings in the wider catchment.

In weather events, the tributaries that come off the surrounding farmland and hills can influence Clear Stream. In these conditions, the stream becomes very turbid with debris and organics. With the recent development of farmland to dairying in the catchment, there has been a negative impact on the water quality in the stream. This has led to silt and nutrient loading, which encourages waterweed growth in Clear Stream. A recent Total Organic Carbon (TOC) analyses (May 2017) found 2.1 g/m<sup>3</sup> TOC present in the raw water.

The Waitaki River at high flows can also infiltrate and influence Clear Stream, but has less negative impacts on the Clear Stream source.

Natural occurring iron in the clay, in the catchment area does affect Clear Stream’s chemical content in the form of soluble iron. Levels of iron in the raw water are around Guideline Values (GV) for iron. Because of the iron, it has also been identified that in warm conditions, a species of algae will flourish feeding on the iron. This was identified about 2009 and confirmed by ECan.

The overall assessment of the catchment, plus the impact from human and agricultural activities for the existing source site, equates to a 5 Log treatment process requirement to provide wholesome, compliant drinking water to the consumer on the Waikakahi Rural Water Supply.

#### Abstraction:

The intake comprises a fish screened pipe laid into the stream. Water flows by gravity into the short pipeline and passes through into a roughing filter chamber to remove debris.

#### Pre-treatment:

The roughing filter consist of a 5.7 cubic meter concrete chamber with two course screens

#### Transmission:

From the roughing filter chamber, the pre-treated raw water travels 55 metres via a 200mm PVC pipe to a stilling well inside the Waikakahi (Stonewall) Intake treatment plant.

#### Treatment Plant:

The pre-treated raw water is drawn out of the stilling well by the duty high-lift distribution pump. A gas chlorine solution is dosed into the suction pipe rising out of the stilling well. Chlorine is dosed only when the high-lift distribution pumps are running, and is controlled by a flow switch on the delivery main. When the duty pump is running, chlorine is dosed at a rate controlled by a chlorine analyser at the pump station. At present the chlorine dose is run manually due to the poor raw water quality fouling the chlorine probe.

Because of the iron content in the raw water and the oxidising effect of chlorine, iron precipitate forms during the chlorination process and settles out in the rising main to the reservoir. The rising main is flushed bi-monthly to remove the iron precipitate. It has been observed that the iron precipitate does not appear to go beyond the reservoir.

Due to the algae that feeds on the naturally occurring iron, plus the use of chlorine for disinfection, a disinfection by-products (DBP) for trihalomethanes (THM’s) analyses was done about 2012, and found that DBP levels were negligible and well below MAV. The DBP analyses was redone in July 2017 with the Sum of THM MAV ratios at less than one at 0.065, but the Sum of HAA MAV ratios was 1.5.

## Appendix A:

### Individual System Description and Overview

The present treatment plant has no protozoal treatment barriers. For the plant to be protozoal compliant under the Drinking Water Standard for New Zealand 2005 (revised 2018), the plant needs log five (5) treatment processes to be in place. Or chose another site with four (4) log treatment processes requirement.

Turbidity monitoring and control has been installed at the Waikakahi Treatment Plant site in 2019. This equipment was installed as a part of an agreement with The Ministry of Health, instead of full upgrades of the treatment plants, to allow for potential changes in legislation and standards (Acceptable Solutions), for rural agricultural water supplies.

#### Distribution:

Two high-lift pumps elevate the treated water to the reservoir, which supplies consumers by gravity. Either pump is capable of providing the full flow required by the water supply, and only one pump operates at a time. The onsite SCADA PLC's at the intake and reservoir provide a control function between the two remote units (RTU) to switch pumps on and off as required to fill the reservoir.

The Waikakahi scheme supplies much of the area on the north side of the Waitaki River between the Lower Waihao and Waihaorunga schemes.

A second pumping station, at Claytons Rd, can supply the Waikakahi East area. This pump is no longer in use, as the Waikakahi East area is now supplied from the adjacent Lower Waihao water supply. Two booster pumps, Waikakahi Booster and Dog Kennel Booster stations pump water from the Lower Waihao supply up to the Clayton Reservoir, to supply Waikakahi East. In an emergency the Claytons Rd pump would be able to be used to supply the Waikakahi East area.

#### Management and Operation:

The scheme is administered at the main council offices in Queen Street, Waimate and operated and managed by the Council's Utilities Business Unit (UBU) based at Michael Street nearby. Five qualified field staff operate and maintain the rural water scheme plant, fixing leaks etc as generally advised by the public. Water samples are sent to MedLab laboratories for bacteriological testing.

The main pump station is linked to WDC's SCADA system, which monitors FAC, pH and the flow from the pump station.

A large proportion of the water produced for the supply is consumed for the purposes of commercial agriculture, and the supply could potentially qualify as a rural agricultural drinking water supply. Waimate District Council had previously considered the option of point of use treatment on the rural supplies, and discounted the option at that time because of cost and maintenance issues.

The option of "point of use treatment" was looked at again with the release of the Rural Agricultural Drinking Water Supply Guidelines (RADWS) in March 2015. Some questions were raised again about actual cost, pre-treatment, maintenance, responsibility issues and liability. Those questions were investigated by exploring successful examples of private "point of entry treatment" supplies under the RADWS in the Waitaki District Council. However, after the Havelock North Stage 1 Enquiry, the issues and risks of such a system make the RADWS not a viable option at that time.

Council has lobbied Government to review the current legislation and standards for Rural Agricultural Water Supplies. Since then the Department of Internal Affairs (DIA) and the new regulator Taumata Arowai have been, and still currently working on an Acceptable Solution option, using point of use (PoE) treatment, which could be used in rural agricultural water supplies.

## Appendix A:

### Individual System Description and Overview


Currently the Waikakahi rural water supply has a “Permanent Boiled Water Notice”. The notice was issued with the agreement of the Drinking water Assessor in November 2016. The notification is regularly advertised in local papers, Waimate District Council’s website and Facebook page, along with Rural Delivery mail drops. The local water committee also reminds locals on request. In recent times organisations such as the local school and Mobile Kindy have helped advertise the “Permanent Boil Water Notice”.

In the last WSP (Public Health Risk Management Plan V 1.0 [PHRMP], December 2009), Meridian Energy were in the process of preparatory work on the North Bank Tunnel project for extra power generation. This project would have affected the Waikakahi Intake (Stonewall) site, and it was expected that Meridian Energy were going to pay for the costs for moving intake and plant. But Since the 2010 earthquakes affecting Christchurch, and other economic factors, the project has now been indefinitely postponed. This means the option of a new source of water, and upgraded plant been put back to the reviewing and planning phase.


### System Information

System Information – Waikakahi			
<b>Connections</b>	<b>172</b>	<b>Treated Water Storage (Reservoir)</b>	
- Metered unrestricted	-	<b>Hakataramea Highway</b>	<b>Ikawai</b>
- Metered restricted	172	Built (yr)	1973
- Unmetered Residential	-	Capacity	450m <sup>3</sup>
		Material	
<b>Water Sources</b>	(Consent volumes)	<b>Treatment</b>	
Waitaki River	1,469m <sup>3</sup> /day	Chlorine	
<b>Resource Consent</b>	<b>Expiry date</b>	<b>To</b>	
CRC96254.1	29/05/2031	Take water	
CRC970320	29/05/2031	Maintain a weir	
CRC970321	29/05/2031	Dam water	
<b>Replacement Cost</b>		<b>Reticulation length</b>	
Total Scheme	\$5.3m	174.7km	

**Appendix Figure 72: Scheme Components**




**Appendix Figure 73: Water Pipes Diameter Range**



Appendix A:


Individual System Description and Overview

**Appendix Figure 74: Water Pipes Material Length**




Approximately 72% of the Waikakahi water supply scheme reticulation were installed during 1973 and are 51 years old. The remaining 28% have been installed since 2001 and are aged between 1-23 years. The reticulation consists mainly of PE (54%) and PVC (43%).

**Appendix Figure 75: Water Pipes Install Year (10 Year Groups)**






**Appendix Figure 76: Remaining Life of all Assets – Long Term**



At present asset useful lives are based primarily on book values with some adjustment for known risk factors. These will be refined by determining evidence-based useful lives using a combination of condition and performance data.


**Appendix Figure 77: Water Pipes Replacement (Length) – Long Term**




Appendix A:

Individual System Description and Overview

Appendix Figure 78: Water Pipes Replacement Value – Long Term




Appendix Figure 79: Water Pipes Replacement (Length) - 1 to 30 Years



Appendix A:

Individual System Description and Overview

**Appendix Figure 80: Water Pipes Replacement Value 1 to 30 Years**




Appendix A:

Individual System Description and Overview

**Appendix Table 6: Waikakahi Plant Replacement Value 1 to 30 Years**


AssetGroup	Remaining Useful Life (5 year groups) Replacement Costs (\$)							Grand Total
	0 or less	1 - 5	6 - 10	11 - 15	16 - 20	21 - 25	26 - 30	
Disinfection Process	\$21,223	\$13,596						\$34,819
Electrical	\$14,642	\$74,005	\$2,298		\$23,012	\$5,435	\$571	\$119,962
Monitoring Control	\$13,430	\$5,624	\$14,345					\$33,399
Pipework	\$18,569	\$207	\$12,444	\$1,045	\$3,013	\$5,012	\$589	\$40,879
Pump	\$57,612	\$26,771	\$10,525	\$35,201				\$130,109
Structure	\$76,900	\$853	\$4,144	\$1,626		\$9,253		\$92,776
Telemetry	\$20,949	\$344	\$16,234					\$37,528
<b>Grand Total</b>	<b>\$223,326</b>	<b>\$121,400</b>	<b>\$59,989</b>	<b>\$37,872</b>	<b>\$26,025</b>	<b>\$19,700</b>	<b>\$1,160</b>	<b>\$489,472</b>

**Appendix Figure 81: 30 Year Replacement Programme**




The above figure shows the theoretical replacement programme based on asset expected useful lives. It also includes the smoothed 10 year average renewals requirement that indicates a declining average renewals requirement over the thirty year period.

Appendix Figure 82: Waikakahi Schematic



**Appendix Figure 83: Waikakahi Scheme Plan**



# Appendix B WSP: Minor Projects and Operational Improvements

The following details the Minor Projects and Operational Improvements that are shown in the current and submitted Waimate District rural and urban Water Safety Plans.

Current and submitted Water Safety Plans (WSP).

- Cannington-Motukaika Water Supply Water Safety Plan *Version 2.1 January 2019 (approved)*
- Hook-Waituna Water Supply Water Safety Plan *Version 3.0 November 2020 (submitted)*
- Lower Waihao Water Supply Water Safety Plan *Version 3.0 November 2020 (submitted)*
- Otaio-Makikihi Water Supply Water Safety Plan *Version 3.0 (under development)*
- Waihaorunga Water Supply Water Safety Plan *Version 2.2 December 2019 (approved)*
- Waikakahi Water Supply Water Safety Plan *Version 2.1 December 2019 (approved)*
- Waimate Water Supply Water Safety Plan *Version 3.0 January 2019 (approved)*

**Appendix Table 7: Scheme Improvement Schedule - Minor Projects and Operational Improvements**

Cannington-Motukaika Rural Water Supply Improvement Schedule <i>Cannington-Motukaika Water Supply Water Safety Plan Version 2.1 January 2019 (approved)</i>				Part II: Minor Projects and Operational Improvements			
Priority	Risk Level	Water Supply Area	Reference to Risk Table	Details of Proposed Works	Person Responsible	Expected Cost	Intended date of Completion
1	Extreme	Source	S1.1	Ongoing liaison with landowners in the water supply catchment to raise/maintain awareness of catchment protection. Encourage best practice agricultural activities and riparian management.	WWM	Staff time	Annual Ongoing
1	Extreme	Distribution	D2.1, D2.2, D2.3	Develop and implement lifecycle management plan for pipe maintenance and renewals to minimise breakages and potential for contamination and/or loss of supply.	WWM	\$5000 + staff time	2020/21
1	Extreme	Treatment	P11	Implement and use Univerus Assets (Asset Management System [AMS]) for programming for WSP reviews, manuals and procedures.	WWM	Staff time	2018/19
2	High	Treatment	P7.1	Install chlorine equipment monitoring device with cellular phone link to monitor chlorine dosing.	WWM	\$500 + Staff time	2017/18
2	High	Distribution	D2.2, D2.3	Undertake a criticality analysis of the network to assist renewals planning.	WWM	Staff time	2015/18 <b>In process</b>
2	High	Distribution	D2.2, D2.3	Undertake condition assessment of AC mains.	WWM	\$2000 + staff time	2015/18 <b>In process</b>
2	High	Distribution	D2.1, D2.2, D2.3	Undertake a reservoir condition assessment and plan maintenance/replacement as appropriate.	WWM & UTL	Staff time	2020/21
2	High	Distribution	D2.2, D2.3	Internal audit of flushing points.	WWM & UTL	Staff time	2020/21
2	High	Pre-Treatment	P4.1	Cyanobacteria Monitoring training. Create a Cyanobacteria management plan to be used in an event of a bloom.	WWM	Operational + staff time	2018/21
2	High	Treatment	P7.1	Monitor raw water pH at plant and log	UTL	Staff time	2017/18
3	Moderate	Other	G1	Prepare Operation and Maintenance Manual including routine operation procedures, preventative maintenance task, inspections, monitoring, record keeping, and instrument calibration.	WWM	Staff time	2020/21
3	Moderate	Other	G1	Implement and use Univerus Assets (Asset Management System [AMS]) for programming and monitoring regular maintenance and inspection/ monitoring tasks	WWM	Staff time	2017/18 & onwards



Cannington-Motukaika Rural Water Supply Improvement Schedule				Part II: Minor Projects and Operational Improvements			
Cannington-Motukaika Water Supply Water Safety Plan Version 2.1 January 2019 (approved)							
Priority	Risk Level	Water Supply Area	Reference to Risk Table	Details of Proposed Works	Person Responsible	Expected Cost	Intended date of Completion
3	Moderate	Other	G1	Ensure all plant records – including manuals, drawings, procedure instructions and emergency response plan are available at the plant.	WWM	Staff time	2020/21
3	Moderate	Other	P11	Formalise hygiene procedures for maintenance works. Implement refresher training for hygiene and disinfection procedures	UTL	Staff time	2018/19
3	Moderate	Distribution	D1	Audit reservoir and break tank roof drainage and security. Investigate option of drainage preventable, lockable lids for reservoirs/break tanks.	WWM & UTL	Staff time	2018/19
3	Moderate	Distribution	D2.3	Internal audit of Cannington Motukaika water supply of what areas that need a cleaning programme, e.g. scouring, pigging or flushing for low flow dead end areas.	WWM & UTL	Staff time	2019/20
3	Moderate	Treatment, Distribution	P11, D1, D2.3	Formalise hygiene procedures for maintenance works. Implement refresher training for hygiene and disinfection procedures.	WWM & UTL	Staff time	2018/19
4	Low	Abstraction	P1.1	Contact Department of Conservation to improve signage on walking track to keep walkers on the main track and away from intake.	WWM	Staff time	2018/19
4	Low	Source, Treatment, Distribution	S1.2, P7.1, D2.1, D2.3	Review Priority 2a, 2b and 2c Determinands, which will include heavy metals and plumbosolvency.	WWM	Operational + staff time	2018/19
4	Low	Treatment, Distribution	P1.1, P.2, D1	Promote 96 hour (4 days) point of supply storage policy.	WWM	Staff time	2017/18 & onwards
4	Low	Treatment, Distribution	P7.1, P11, D1	Review generator use, transport and procedures over all the schemes. Create register of generator hire companies.	WWM & UTL	Staff time	2018/19
4	Low	Distribution	D2.4	Backflow Register	UTL	Staff time	2018/19
4	Low	Treatment	P11	Make use of shared digital resources for recording information i.e. pump hours, events, maintenance, etc., via iPads/tablets, Sharepoint.	WWM	\$10,000 + Operational + staff time	2018/19 & onwards
4	Low	Treatment, Distribution	D2.2	Telemetry (SCADA) monitoring and control for Pratts.	WWM	\$16,000	2021/22
4	Low	Treatment, Distribution	P10.2, D2.2	Investigate pump life and reconditioning programme and establish.	WWM & UTL	Staff time	2018/19

<b>Hook Waituna Improvement Schedule Part II: Minor Projects and Operational Improvements</b> <i>Hook-Waituna Water Supply Water Safety Plan Version 3.0 November 2020 (submitted)</i>							
Priority	Risk Level	Water Supply Area	Reference to Risk Table	Details of Proposed Works	Person Responsible	Expected Cost	Intended date of Completion
1	Extreme	Source	S1.1	Ongoing liaison with landowners in the water supply catchment to raise/maintain awareness of catchment protection. Encourage best practice agricultural activities and riparian management.	WWM	Staff time	Ongoing
2	High	Distribution		Undertake condition assessment of AC mains.	WWM	\$4000 + staff time	2015/18 Ongoing annually as required
3	Moderate	Other	G1	Prepare Operation and Maintenance Manual including routine operation procedures, preventative maintenance task, inspections, monitoring, record keeping, and instrument calibration.	WWM	Staff time	2021/22 Completed but plant does not fully meet compliance. <b>Future upgrade still required to make plant compliant</b>
3	Moderate	Other	G1	Implement and use Asset Management System (AMS) for programming and monitoring regular maintenance and inspection/monitoring tasks.	WWM	Staff time	2015/16 & onwards <b>In process but to be improved</b>
3	Moderate	Other	G1	Ensure all plant records – including manuals, drawings, procedure instructions and emergency response plan are available at the plant.	WWM	Staff time	2022/23 Completed but need to align with new plant

Lower Waihao Rural Water Supply Improvement Schedule				Part II: Minor Projects and Operational Improvements			
Lower Waihao Water Supply Water Safety Plan Version 3.0 November 2020 (submitted)							
Priority	Risk Level	Water Supply Area	Reference to Risk Table	Details of Proposed Works	Person Responsible	Expected Cost	Intended date of Completion
1	Extreme	Source	S1.1	Ongoing liaison with landowners in the water supply catchment to raise/maintain awareness of catchment protection. Encourage best practice agricultural activities and riparian management.	WWM	Staff time	Ongoing
1	Moderate	Other	G1	Prepare Operation and Maintenance Manual including routine operation procedures, preventative maintenance task, inspections, monitoring, record keeping, and instrument calibration.	WWM	Staff time	2022/23
1	Moderate	Other	G1	Ensure all plant records – including manuals, drawings, procedure instructions and emergency response plan are available at the plant.	WWM	Staff time	2022/23 <b>Completed</b> but need to align with new plant

Otaio Makikihi Rural Water Supply Improvement Schedule				Part II: Minor Projects and Operational Improvement			
Otaio-Makikihi Water Supply Water Safety Plan Version 3.0 (under development)							
1	Extreme	Source & Source Abstraction	S1.1	Ongoing liaison with landowners in the water supply catchment to raise/maintain awareness of catchment protection. Encourage best practice agricultural activities and riparian management.	WWM	Staff time	Ongoing
2	High	Distribution System	C55	Undertake condition assessment of AC mains. N.B. Assessment are done as required and ongoing i.e. samples taken from pipe failure events.	WWM	\$2000 + staff time	2018/21 <b>In process</b>
4	Low	General Elements	C58	Seek DWA review and approval of DWSNZ monitoring programme.	WWM	Staff time	Ongoing Annually
3	Moderate	General Elements	C59	Prepare Operation and Maintenance Manual including routine operation procedures, preventative maintenance task, inspections, monitoring, record keeping, and instrument calibration.	WWM	Staff time	Ongoing
3	Moderate	General Elements	C59	Implement and use Asset Management System (AMS) for programming and monitoring regular maintenance and inspection/monitoring tasks.	WWM	\$2000 + staff time	Ongoing

Appendix B:

PHRMP: and WSP Minor Projects and Operational Improvements

Otaio Makikihi Rural Water Supply Improvement Schedule								Part II: Minor Projects and Operational Improvement	
Otaio-Makikihi Water Supply Water Safety Plan Version 3.0 (under development)									
3	Moderate	General Elements	C59	Ensure all plant records – including manuals, drawings, procedure instructions and emergency response plan are available at the plant.	WWM	Staff time	Ongoing		

Waihaorunga Rural Water Supply Improvement Schedule								Part I: Major Projects and Capital Works	
Waihaorunga Water Supply Water Safety Plan Version 2.2 December 2019 (approved)									
Priority	Risk Level	Water Supply Area	Reference to Risk Table	Details of Proposed Works	Person Responsible	Expected Cost	Intended date of Completion		
1	Extreme	Source Treatment	S1.1, P1.1, P7.1, P10, P10.2, P11, D2.3	<p>Increase monitoring and control at Waihaorunga Main Treatment Plant as an interim measure before upgrades.</p> <ul style="list-style-type: none"> <li>• Telemetry (SCADA)</li> <li>• FAC &amp; Turbidity monitoring and control</li> <li>• Control – Plant shutdown (selective abstraction)</li> </ul>	WWM	\$36,500 (from the \$1,007,500 LTP budget for Plant upgrade brought forward)	2018/19		
1	Extreme	Source Treatment	S1.1, P1.1, P2, PPT, P7.1, P10, P10.2, P11, D2.3	<p>Increase monitoring and control at Tavendales Treatment Plant as an interim measure before upgrades.</p> <ul style="list-style-type: none"> <li>• Telemetry (SCADA)</li> <li>• FAC &amp; Turbidity monitoring and control</li> <li>• Control – Plant shutdown (selective abstraction)</li> </ul> <p><b>Note:</b> Investigate running the entire supply network off the Main Treatment Plant. If not able to, then increase monitoring and control at Tavendales Treatment Plant.</p>	WWM	\$41,000 (from the \$1,007,500 LTP budget for Plant upgrade brought forward)	2019/20		

Waihaorunga Rural Water Supply Improvement Schedule				Part I: Major Projects and Capital Works			
Waihaorunga Water Supply Water Safety Plan Version 2.2 December 2019 (approved)							
Priority	Risk Level	Water Supply Area	Reference to Risk Table	Details of Proposed Works	Person Responsible	Expected Cost	Intended date of Completion
1	Extreme	Source Treatment	P1.1, P7.1, P10, P10.2, P11, D2.3	<p>Upgrade Waihaorunga Main treatment plant to comply with the DWSNZ 2005 (revised 2008).</p> <ul style="list-style-type: none"> <li>• Upgrade Waihaorunga Main Treatment Plant site to Log 4 treatment. <ul style="list-style-type: none"> <li>○ Add selective abstraction based on turbidity.</li> <li>○ Pre-treatment with an invalidated membrane</li> <li>○ 1µm Filter.</li> <li>○ UV reactor</li> <li>○ Disinfection – Sodium hypochlorite</li> <li>○ Install telemetry for data acquisition and control (SCADA)</li> <li>○ Make provision for a bypass so a granulated activated carbon filter can be added if ever required.</li> </ul> </li> <li>• Abandon Tavendales plant.</li> <li>• Connect Tavendale Intake Gallery to new Waihaorunga Main Treatment Plant, then boost treated water back to Tavendales booster.</li> </ul>	WWM	\$1,007,500	2021
2	High	Source	S1.1	<p>Ongoing investigation into options for alternate sources.</p> <p><b>Note:</b> <i>There are not many options for alternate sources of raw water for Waihaorunga. Work will continue to make sure all options are investigated thoroughly before work starts on the upgrade to existing sites.</i></p>	WWM	Staff time	2019/20 <b>In process</b>

Waikakahi Rural Water Supply Improvement Schedule				Part II: Minor Projects and Operational Improvements			
Waikakahi Water Supply Water Safety Plan Version 2.1 December 2019 (approved)							
Priority	Risk Level	Water Supply Area	Reference to Risk Table	Details of Proposed Works	Person Responsible	Expected Cost	Intended date of Completion
1	Extreme	Treatment	P7.1	Visit treatment plants and adjust chlorine dosing rate if required following a rain event.	WWM	Staff time	As required until 2020/21

Appendix B:

PHRMP: and WSP Minor Projects and Operational Improvements

Waikakahi Rural Water Supply Improvement Schedule				Part II: Minor Projects and Operational Improvements			
<i>Waikakahi Water Supply Water Safety Plan Version 2.1 December 2019 (approved)</i>							
Priority	Risk Level	Water Supply Area	Reference to Risk Table	Details of Proposed Works	Person Responsible	Expected Cost	Intended date of Completion
1	Extreme	Source	S1.1	Ongoing liaison with landowners in the water supply catchment to raise/maintain awareness of catchment protection. Encourage best practice agricultural activities and riparian management.	WWM	Staff time	Annual ongoing
1	Extreme	Treatment	P11	Implement and use Univerus Assets (Asset Management System [AMS]) for programming for WSP reviews, manuals and procedures.	WWM	Staff time	2019/20
2	High	Distribution	D2.2, D2.3	Undertake condition assessment of AC mains. N.B. Assessment are done as required and ongoing i.e. samples taken from pipe failure events.	WWM	\$2000 + staff time	2018/21 In process
2	High	Distribution	D2.1, D2.2, D2.3	Undertake a reservoir condition assessment and plan maintenance/replacement as appropriate.	WWM	Staff time	2020/21
2	High	Distribution	D2.2, D2.3	Internal audit of flushing points.	WWM & UTL	Staff time	2020/21
2	High	Pre-Treatment	P4	Cyanobacteria monitoring training. Design a Cyanobacteria management plan to be used in an event of a bloom.	WWM	\$1000 + Staff time	2019/20
2	High	Treatment	P7.1	Monitor raw water pH at plant and log	UTL	Staff time	2019/20
3	Moderate	Other	G1	Prepare Operation and Maintenance Manual including routine operation procedures, preventative maintenance task, inspections, monitoring, record keeping, and instrument calibration.	WWM	Staff time	2020/21
3	Moderate	Other	G1	Implement and use Univerus Assets (Asset Management System [AMS]) for programming and monitoring regular maintenance and inspection/ monitoring tasks. Including looking at other options i.e. Water Outlook.	WWM	Staff time	2017/18 & onwards
3	Moderate	Other	G1	Ensure all plant records – including manuals, drawings, procedure instructions and emergency response plan are available at the plant.	WWM	Staff time	2020/21
3	Moderate	Distribution	D1	Audit reservoir and break tank roof drainage and security. Investigate option of drainage preventable, lockable lids for reservoirs/break tanks.	WWM & UTL	Staff time	2020/21

Waikakahi Rural Water Supply Improvement Schedule				Part II: Minor Projects and Operational Improvements			
Waikakahi Water Supply Water Safety Plan Version 2.1 December 2019 (approved)							
Priority	Risk Level	Water Supply Area	Reference to Risk Table	Details of Proposed Works	Person Responsible	Expected Cost	Intended date of Completion
3	Moderate	Distribution	D2.3	Internal audit of Waihaorunga water supply of what areas that need a cleaning programme, e.g. scouring, pigging or flushing for low flow dead end areas.	WWM & UTL	Staff time	2020/21
3	Moderate	Distribution	D2.3	Programme of regular backwashing for Waihaorunga Main and Tavendales intake gallery beds.	UTL	Staff time	2019/20
3	Moderate	Source, Treatment, Distribution	S1.2, P7.1, D2.1, D2.3	Review Priority 2a, 2b and 2c Determinands, which will include heavy metals and plumbosolvency.	WWM	Operational + staff time	2018/19 & onwards
3	Moderate	Treatment, Distribution	P11, D1, D2.3	Formalise hygiene procedures for maintenance works. Implement refresher training for hygiene and disinfection procedures.	WWM & UTL	Staff time	2019/20
3	Moderate	Distribution	D1	Review additional post-treatment storage	WWM	Staff time	2021/22
4	Low	Treatment, Distribution	P1.1, P.2, D1	Promote 96 hour (4 days) point of supply storage policy.	WWM	Staff time	2017/18 & onwards
4	Low	Treatment, Distribution	P7.1, P11, D1	Review generator use, transport and procedures over all the schemes. Create register of generator hire companies.	WWM & UTL	Staff time	2020/21
4	Low	Distribution	D2.4	Backflow Register	UTL	Staff time	2020/21
4	Low	Treatment	P11	Make use of shared digital resources for recording information i.e. pump hours, events, maintenance, etc., via iPads/tablets, Sharepoint.	WWM	\$10,000 + Operational + staff time	2018/19 & onwards
4	Low	Treatment, Distribution	P10.2, D2.2	Investigate pump life and reconditioning programme and establish.	WWM & UTL	Staff time	2020/21
4	Low	Distribution	D1	Investigate telemetry (SCADA) options at network reservoir sites.	WWM	Staff time	2021/2024
4	Low	Distribution	D1	Investigate telemetry (SCADA) options at network pumpstations - Melford	WWM	Staff time	2021/2024
4	Low	Distribution	D1	Takitu Pumphouse - New Board and Telemetry (SCADA)	WWM	\$22,000	2022/2023

Waimate Rural Water Supply Improvement Schedule				Part II: Minor Projects and Operational Improvements			
Waimate Water Supply Water Safety Plan Version 3.0 January 2019 (approved)							
Priority	Risk Level	Water Supply Area	Reference to Risk Table	Details of Proposed Works	Person Responsible	Expected Cost	Intended date of Completion
2	High - Extreme	Treatment	P11	Make use of shared digital resources for recording information i.e. pump hours, events, maintenance, etc., via mobile technology i.e. tablets	WWM	Staff time	2019/20
2	High	Distribution	D2.4	Review of Backflow Protection device use on the Waimate Urban Supply.	WWM & UTL	Staff time	2020/21
2	High	Distribution	D2.4	Public Backflow Prevention education	WWM & UTL	Staff time	2020/21
2	High	Source	S1.1	Monthly Constant Composition Testing. Monitoring variances (coefficient and standard) of Conductivity, Chloride and Nitrate at Manchesters Road Bore and Timaru Road Bore. <b>Note: This method of analysis will be used for demonstrating Criterion 1 Bore Security as well as regular monitoring.</b>	WWM	\$980 + staff time Annually	2019/20 onwards
2	High	Source	P1.3, P10, P11	Investigate Emergency alternate water sources i.e. the old town supply at Kelcys Bush.	WWM	Staff time	2018/20
2	High	Treatment	P7.1, P10, P11	Review generator use, transport and procedures over all the schemes. Create register of generator hire companies.	WWM & UTL	Staff time	2018/19
2	High	Waimate WS	C1, C3	Complete Councils Emergency Response Plan. <b>Note: This WSP and all approved Waimate District Council WSP's are part of the Councils Emergency Response Plan.</b>	CDEM	Staff time	<b>ERP in Process. WATER COMPLETED</b>
2	High	Waimate WS	S3, D2.4	Backflow prevention policy – Formalise a BFP policy to define clear requirements for different property types and activities, and required BFP devices testing regimes (also review if a separate policy is required). <b>Note: Existing Backflow prevention Bylaw in Place (Section 1419.1) and other external factors such as the “New Zealand Building Code Clause G12 Water Supplies”, “Acceptable Solutions G12/AS1, Section 3.0” &amp; AS/NZS 3500 Pt 1 2018.</b>	WWM	Internal	<del>Dec 2014</del> <b>Risk Managed</b> 2020/21
3	Moderate	Treatment, Distribution	P1.3, P11, D1, D2.3	Formalise hygiene procedures for maintenance works. Implement refresher training for hygiene and disinfection procedures.	UTL	Staff time	2020/21



# Appendix C Significant Forecasting Assumptions

The following table details the significant forecasting assumptions for the 2025-2034 period.

Appendix C:

Significant Forecasting Assumptions

**Appendix Table 8: Significant Forecasting Assumptions 2025 -2034**

ASSUMPTION	SOURCE	RISK	LEVEL OF UNCERTAINTY	IMPACT OF VARIATION	MANAGEMENT OF RISK	ACTIVITY
<b>POPULATION CHANGE</b>						
The Waimate District population will observe a gradual increase by 4.7% between 2023-2033. It is assumed that this increase will generate a relative impact on population-related metrics, such as the quantity of rateable properties.	Rationale Ltd.	Population growth either significantly exceeds that of the projected percentage or is significantly below the projected percentage.	Low	If population accelerates significantly above the given assumption, existing infrastructure may not be suitable to cope with the extra demand.	Council will monitor population measures provided for the district, and will respond to significant variations to assumptions, where possible.	All activity groups
<b>DEMOGRAPHIC CHANGES</b>						
Between 2020-2030, the district's population retains its comparatively high mean age, while observing a gradual and mild reduction in the mean age level, with the age group of 45-49 years likely to be the most frequent by 2030.	Rationale Ltd.	The demographic make-up of the Waimate District changes significantly.	Low	If the district's demographic changes significantly from the predicted range, the existing infrastructure and services may not meet the needs of the relevant demographic classes.	Council will monitor demographic measures provided for the district and respond to significant variations to assumptions, where possible.	All activity groups
<b>OIL PRICE</b>						
Oil prices are increasingly volatile and more likely to be influenced by global political and economic events. Prices are unlikely to reliably stabilise for any extended length of time.	WDC	There is a risk that fuel demand will be different to that assumed, and that significant changes in market price occur with greater frequency and/or greater severity.	Moderate	Increased fuel costs would have a particular impact on the costs of road maintenance, renewal, and improvement. This may affect Council's ability to carry out planned work without additional funding. It may also increase demand for alternative methods of transport.	Council will monitor the impact of fuel price on spending and aim to optimise spending.	All activity groups

ASSUMPTION	SOURCE	RISK	LEVEL OF UNCERTAINTY	IMPACT OF VARIATION	MANAGEMENT OF RISK	ACTIVITY
<b>CLIMATE CHANGE</b>						
Changes in our climate are projected to continue into the future. Projections indicate that Canterbury should expect warmer temperatures, an increasing number of hot days, and wider temperature ranges. The frequency of extreme weather events is projected to increase along with associated costs to economic, community wellbeing and environmental sustainability as a result.	WDC  Ministry for the Environment  National Institute of Water and Atmospheric Research  Environment Canterbury	Environmental changes may accelerate at a rate higher than predicted, and/or the socio-economic consequences of adaptation measures may exceed the anticipated range.	Moderate	If environmental changes were to accelerate, Council's infrastructure assets would be significantly impacted. This would result in further modifications or more regular repairs to relevant assets.	Council is currently undertaking the development of a climate resilience strategy aimed at consistent monitoring, active mitigation, and pre-emptive adaptation efforts.  This strategy is being built on the foundation of extensive engagement, education, and feedback to address the unique challenges faced by Waimate.  This engagement includes seven community workshops based on key economic, social, environmental, and cultural activities relevant to Waimate's future.	All activity groups
<b>EMISSIONS TRADING SCHEME (ETS)</b>						
The Emissions Trading Scheme (ETS) and the price of New Zealand Units (NZU) will remain relatively stable in response to changes in legislation that affect price certainty and unit limits.	Ministry for the Environment	There is a risk of legislative change, which could result in costs being higher or lower than assumed.	Low	Should the impact of the scheme exceed significantly from the given assumption, budget for additional cost may need to be considered.	Council will monitor the development of relevant legislation and review the impact of any significant changes in the Annual Plan.	Investments and Finance

Appendix C:

Significant Forecasting Assumptions

ASSUMPTION	SOURCE	RISK	LEVEL OF UNCERTAINTY	IMPACT OF VARIATION	MANAGEMENT OF RISK	ACTIVITY
<b>NEW ZEALAND TRANSPORT AGENCY (NZTA) WAKA KOTAHİ REVENUE</b>						
<p>Roading expenditure comprises a significant portion of Waimate District Council’s total expenditure, therefore using a significant portion of Council’s overall rate take. The majority of Council’s expenditure on the district’s roads is eligible to attract an assistance rate from the Waka Kotahi New Zealand Transport Agency (NZTA). The funding assistance rate received by Council for qualifying roading expenditure for maintenance and improvement projects is set at 68% for 2024-27.* It is further assumed that this funding assistance rate will remain unchanged over the life of the Long Term Plan as there is no indication that NZTA will modify the criteria used to establish these rates.</p> <p>Council also assumes that funding priorities indicated in Government Policy Statements on Land Transport will remain consistent through future bids during the life of the plan.</p>	Waka Kotahi NZTA	The subsidy rate may be subject to change, along with any variation in criteria for inclusion in subsidized works programmes.	Moderate	Changes to the funding priorities of NZTA remain outside Council control. Minor variations would impact significantly on forecasted financials.	Any impact of changes to the NZTA funding assistance rate will be applied to the relevant Annual Plan.	Roading and Footpaths
* <a href="https://nzta.govt.nz">Normal funding assistance rates   Waka Kotahi NZ Transport Agency (nzta.govt.nz)</a>						
<b>EMERGENCY EVENT</b>						
<p>Disruptive or destructive emergency events such as earthquakes, extreme weather events, and pandemics may occur to damage, disable, or destroy community infrastructure (for example, district roads, bridges, water supplies, among others), or community activities. It is further assumed that the cost of correcting such damage is met either by Council or its insurance providers, or by possible special government grants.</p>	<p>WDC</p> <p>NEMA National Emergency Management Advisor</p> <p>Ministry for Environment</p>	<p>Inability to recover or continue business following a major event.</p> <p>Inability to provide intended level of service to affected areas.</p>	Moderate	<p>If a major emergency event did occur, Council have some insurance for its infrastructure, and assistance would be offered from Central Government.</p> <p>To pay for additional emergency work not covered by the above, Council would increase internal/external borrowings.</p>	Council undertakes business continuity plans for its own operation and coordinates Civil Defence planning for the district. In doing so, Council attempts to prepare itself and the district for such events.	All activity groups

ASSUMPTION	SOURCE	RISK	LEVEL OF UNCERTAINTY	IMPACT OF VARIATION	MANAGEMENT OF RISK	ACTIVITY
<b>LEGISLATION CHANGES</b>						
Council's operations are guided by central government legislation and policy directives that set the framework for decision making and service delivery. Council operates under the assumption that while minor legislative changes and evolving policy guidance are expected, major changes that could significantly alter Council operations are infrequent. When such changes do occur, they are typically communicated well in advance, allowing time for necessary adjustments.	Central Government  Taituarā	That major legislative changes are introduced on short notice or due to an unforeseen event that would require Council to alter its existing business operations.	Low	Council would need to implement changes at a pace faster than anticipated. Accelerated timeframes would likely result in increased costs of implementation.	Council maintains consistent communication with central government, regulatory bodies, and local government support organisations to ensure that proposed changes that may impact Council operations are identified and anticipated at the earliest stage.	All activity groups
<b>NEW ZEALAND WATER SERVICE DELIVERY</b>						
Delivery of 3 waters assets and infrastructure (water, sewer, and stormwater) remain under Council ownership for the life of the plan.	WDC  Central Government	Legislation changes under urgency in Parliament that must be implemented immediately.	High*	Changes are required to be implemented more quickly than anticipated.	Council closely monitors any and all developments and responds accordingly.	Rural Water Supply, Urban Water Supply, Sewer, Stormwater
* While the uncertainty of this assumption is high, the potential impacts of this uncertainty on financial estimates cannot yet be determined until further information becomes available through the production of a water service delivery plan. The development of a Water Services Delivery Plan and its submission to DIA may provide additional clarity; however, aspects of this uncertainty regarding implementation are likely to continue into the development of the LTP 2027-2037.						
<b>RESOURCE CONSENTS</b>						
The conditions of resource consents held by Council may be changed, and that Council will obtain the necessary resource consents for planned projects.	WDC	There is a risk that resource consent conditions are altered significantly.	Moderate	Advanced warning of likely changes is expected. The financial effect of any change to resource consent requirements would depend on the change.	Council will monitor the development of relevant standards and review the impact of any significant changes.	Roading and Footpaths, Sewerage, Stormwater, Waste Management, Urban Water Supply, Rural Water Supply

Appendix C:

Significant Forecasting Assumptions

ASSUMPTION	SOURCE	RISK	LEVEL OF UNCERTAINTY	IMPACT OF VARIATION	MANAGEMENT OF RISK	ACTIVITY
<b>WATER SCHEMES VIABILITY</b>						
Elevated pricing for rural water schemes, and particularly the stock water element, may result in the relinquishment of water allocations. Sourcing of stock water from existing irrigation schemes may mean that pricing within individual supplies increases as a result.	WDC	Increased cost associated with water allocations under existing and proposed service delivery models	Moderate	No new irrigation schemes are currently planned within the district and the existing command areas only cover a small proportion of the overall footprint of the Waimate District Council Rural Water Supplies.	Council will monitor sold volumes (allocations) and review charging structures if necessary to mitigate the overall risk for the district.  Council is actively engaging with central government to mitigate the impact of this risk.	Rural Water Supply
<b>USEFUL LIVES OF SIGNIFICANT ASSETS AND DEPRECIATION</b>						
The useful lives of significant assets are based on the useful lives as identified in the Statement of Accounting Policies. It is assumed that these useful lives are retained for the nine year period covered by this Long Term Plan. In practice useful lives are re-assessed at a minimum of every three years in line with asset revaluations.	New Zealand Asset Management Support  WDC asset revaluations	There is a risk that assets will wear out more quickly than forecasted and require replacement earlier than planned	Moderate	If assets require replacement earlier than first considered, capital expenditure projects may need to be brought forward.	Regular review of the useful life of each asset category reduces the risk of significant inaccuracies.	Roading and Footpaths, Rural Water Supply, Urban Water Supply
<b>REVALUATION OF NON-CURRENT ASSETS</b>						
Council conducts asset revaluations every three years. The Long Term Plan assumes the following percentage increases to book value, for each of the following class of assets: Land: +10% Buildings: +15% Utilities (Water Schemes, wastewater, stormwater, Sanitation): +8% Roading: +6%	WDC	Revaluations will somewhat differ from those projected carrying values of the assets and depreciation expense.	Moderate	Variation in values is expected to be low unless the valuation methodology changes.	Regular revaluation of non-current assets reduces the risk of significant valuation shifts.	Roading and Footpaths, Rural Water Supply, Urban Water Supply, Sewerage, Property

ASSUMPTION	SOURCE	RISK	LEVEL OF UNCERTAINTY	IMPACT OF VARIATION	MANAGEMENT OF RISK	ACTIVITY
<b>FUNDS FOR FUTURE REPLACEMENT OF SIGNIFICANT ASSETS</b>						
In general, councils have some flexibility in the policies they may set with regard to sources of funds for the future replacement of significant assets. Council's flexibility centers on whether we should collect depreciation monies from ratepayers during the lifetime of the asset to build up a reserve that can fund the replacement of the asset when it comes to the end of its useful life, or when the asset comes to the end of its useful life which would compel Council to rely on borrowed money to replace it. Council considers that the most sensible approach is to collect depreciation during the life of an asset, therefore having reserve funds on hand at the time replacement is needed. See Council's 'Revenue and Financing Policy' and the 'Financial Strategy'.	WDC	Sufficient funds may not be available to pay for planned asset replacement.	Low	Funds may need to be borrowed or rated for, which may be a burden to either the Council or ratepayers in the future.	Council develops Asset Management Plans that determine the timing of asset replacements. Council uses these to forecast and prepare for future funding requirements.	Property, Roothing and Footpaths, Rural Water Supply, Urban Water Supply, Sewerage
<b>RETURN ON INVESTMENT- ALPINE ENERGY</b>						
Alpine Energy's FY2025-2027 Statement of Corporate Intent includes a Dividend Policy whereby the Directors are not indicating any dividends to shareholders for the 3 years of the SCI. It is therefore assumed that the company will not provide a return to shareholders for the duration of the 2025-34 Long-Term Plan.	WDC  Alpine Energy	There is a risk that returns on investments will be higher than forecasted.	Low	Should dividends be received, Council finances will be more favourable than anticipated to the extent of that dividend. This unanticipated income would contribute to the activity reserve balance and may result in positive cash-flow enabling consideration of higher levels of service	No management of this risk is required as any variation will be favourable to Council.	Investments and Finance

Appendix C:

Significant Forecasting Assumptions

ASSUMPTION	SOURCE	RISK	LEVEL OF UNCERTAINTY	IMPACT OF VARIATION	MANAGEMENT OF RISK	ACTIVITY
<b>FORESTRY ASSETS VALUES</b>						
It is assumed that the forestry asset values will increase annually over a rotation cycle of 30 years.	WDC Laurie Forestry Limited	The value of forestry assets may sharply increase or decrease.	Low	A change in the value of the forestry asset will change Council's financial performance in the year of change occurring. However, it will not have a direct impact on the level of rates or expenditure.	Annual revaluation of forestry reduces the risk of significant valuation shifts.	Investments and Finance
<b>CAPITAL DELIVERY</b>						
Council plan to deliver 100% of all capital projects over the life of the Long-Term Plan. The financial model was developed based on this assumption.	WDC	<p>There is a risk that improved levels of service in the Water Supply area will be delayed.</p> <p>There is a risk that the capital projects will not be completed in any given year and carried over to subsequent years.</p>	Moderate	<p>Variation to planned improved levels of service for the Water Supply area, where any delay in projects relating to Drinking Water Standards New Zealand compliance will result in maintaining current levels of service.</p> <p>If projects are not completed on time, or are deferred, there may be reduced operational costs and depreciation expense impacts.</p> <p>There could also be an increase in required budget to complete the project if delayed.</p>	<p>Council is aware of material sourcing and has addressed this issue by sourcing materials early and maintaining stock levels. Procurement is now completed through the Government Electronic Tenders System (GETS), notifying the wider contracting / consulting market of upcoming projects. In anticipation of a large capital programme in Year 1 (2026), a portion of these projects are likely to be tendered by 30 June 2025, or very early in the 2025/26 financial year. Due to the nature of the rates smoothing profile for the Water Supply activity, any delay in project completion will have no effect on the funding and rates required as planned.</p>	Water Supply & all other activities



## Significant Forecasting Assumptions

ASSUMPTION	SOURCE	RISK	LEVEL OF UNCERTAINTY	IMPACT OF VARIATION	MANAGEMENT OF RISK	ACTIVITY
<b>RETURN ON INVESTMENTS - OTHER</b>						
<p>It is assumed that Council's cash investments will generate returns from 2.38% - 3.77% based on the current economic climate.</p> <p>It is further assumed that the returns from Council's forestry investments for the duration of the Long Term Plan will be reflective of market conditions present at the time of preparation of this document.</p>	<p>Bancorp</p> <p>Laurie Forestry Limited</p> <p>WDC</p>	<p>Returns on investments will be higher or lower than forecasted.</p>	<p>Moderate</p>	<p>Higher interest rates received on cash investments or increased investment income could result in positive cash-flow enabling consideration of higher levels of service or reduced expenditure. Council does not heavily rely on interest revenue for running its operations, therefore the impact of lower investment returns on delivery of Council services would be minimal. Similarly, Council does not use its forestry investment returns to fund other Council operations or activities.</p>	<p>Council will manage its external investments to optimise returns (as described in the Council's Investment Policy).</p> <p>Council will monitor the forestry market's conditions and review the impact of any significant change in forecasted returns through each subsequent Annual Plan process.</p>	<p>Investments and Finance</p>

Appendix C:

Significant Forecasting Assumptions

ASSUMPTION	SOURCE	RISK	LEVEL OF UNCERTAINTY	IMPACT OF VARIATION	MANAGEMENT OF RISK	ACTIVITY																																																							
<b>INFLATION</b>																																																													
<p>Council, along with many other New Zealand Councils, calculates and applies inflation factors to its Long-Term Plan budget forecast, using predictions of future inflation levels from New Zealand [economic research company] Business and Economic Research Ltd (BERL).</p> <table border="1"> <thead> <tr> <th>Year</th> <th>Roading</th> <th>3 Waters</th> <th>Other Operational Expenditure</th> <th>Capital Expenditure</th> </tr> <tr> <th></th> <th>%</th> <th>%</th> <th>%</th> <th>%</th> </tr> </thead> <tbody> <tr> <td>June 2026</td> <td>3.0</td> <td>2.5</td> <td>3.2</td> <td>3.4</td> </tr> <tr> <td>June 2027</td> <td>3.1</td> <td>2.8</td> <td>3.2</td> <td>3.3</td> </tr> <tr> <td>June 2028</td> <td>3.0</td> <td>2.5</td> <td>3.0</td> <td>3.2</td> </tr> <tr> <td>June 2029</td> <td>2.7</td> <td>2.1</td> <td>2.7</td> <td>2.9</td> </tr> <tr> <td>June 2030</td> <td>2.6</td> <td>2.0</td> <td>2.6</td> <td>2.8</td> </tr> <tr> <td>June 2031</td> <td>2.5</td> <td>2.0</td> <td>2.4</td> <td>2.5</td> </tr> <tr> <td>June 2032</td> <td>2.4</td> <td>2.0</td> <td>2.3</td> <td>2.4</td> </tr> <tr> <td>June 2033</td> <td>2.4</td> <td>2.0</td> <td>2.2</td> <td>2.2</td> </tr> <tr> <td>June 2034</td> <td>2.2</td> <td>2.0</td> <td>2.1</td> <td>2.1</td> </tr> </tbody> </table>	Year	Roading	3 Waters	Other Operational Expenditure	Capital Expenditure		%	%	%	%	June 2026	3.0	2.5	3.2	3.4	June 2027	3.1	2.8	3.2	3.3	June 2028	3.0	2.5	3.0	3.2	June 2029	2.7	2.1	2.7	2.9	June 2030	2.6	2.0	2.6	2.8	June 2031	2.5	2.0	2.4	2.5	June 2032	2.4	2.0	2.3	2.4	June 2033	2.4	2.0	2.2	2.2	June 2034	2.2	2.0	2.1	2.1	Business and Economic Research Ltd.	Inflation will be higher or lower than anticipated.	Moderate	A difference between the inflation rates experienced and those assumed will change the cost base of Council, and therefore impact funding requirements.	<p>Council has endorsed the rates produced by BERL as the most appropriate basis for accounting for the impact of inflation and preparing the Long Term Plan.</p> <p>In the event of significant changes to the underlying costs supporting work in the activity areas, mitigation planning will feature in the Annual Plan. Activity areas, mitigation planning will feature in the Annual Plan.</p>	All activity groups
Year	Roading	3 Waters	Other Operational Expenditure	Capital Expenditure																																																									
	%	%	%	%																																																									
June 2026	3.0	2.5	3.2	3.4																																																									
June 2027	3.1	2.8	3.2	3.3																																																									
June 2028	3.0	2.5	3.0	3.2																																																									
June 2029	2.7	2.1	2.7	2.9																																																									
June 2030	2.6	2.0	2.6	2.8																																																									
June 2031	2.5	2.0	2.4	2.5																																																									
June 2032	2.4	2.0	2.3	2.4																																																									
June 2033	2.4	2.0	2.2	2.2																																																									
June 2034	2.2	2.0	2.1	2.1																																																									
<b>BORROWING COSTS</b>																																																													
Interest costs are estimated to range between 3.09% - 5.24% This refers to the expected external cost of debt facilities where costs are not known and are required to be projected. Loan repayments are forecast to be repaid on the last day of the financial year, therefore interest is incurred for the full year.	WDC  Bancorp  Local Government Funding Agency	Interest rates will differ significantly from those estimated.	Moderate	If borrowing costs are greater than those assumed, Council may need to increase its rates or reduce its expenditure. Conversely, lower costs may mean rates required to fund Council operations are lower than they would otherwise have been.	Council will monitor its applicable interest rates and adjust through the Annual Plan process to reflect a level best aligned to its actual anticipated external borrowing rate, utilizing the advice of its Treasury Advisors.	Investment and Finance																																																							
<b>UNIDENTIFIED LIABILITIES</b>																																																													
It is assumed that Council does not have any unidentified liabilities.	WDC	There is a risk of an unexpected liability occurring. For example, a claim against Council.	Low	If an unidentified liability arises it may increase Council's expenditure. This risk is mitigated by the Council's Risk Management and Insurance Policies.	Regular review of liabilities reduces against the risk of items being unidentified.	All activity groups																																																							

## Appendix D Risk Summary Table

The following table details the Risk Summary Table that was established in 2011, which identifies risk management strategies to minimise risks associated with the provision of the Water, Wastewater, Stormwater and Solid Wastes services.

For site-specific risk assessment tables see “Risk Tables” in all current and submitted Water Safety Plans (WSP).

- Cannington-Motukaika Water Supply Water Safety Plan *Version 2.1 January 2019 (approved)*
- Hook-Waituna Water Supply Water Safety Plan *Version 3.0 November 2020 (submitted)*
- Lower Waihao Water Supply Water Safety Plan *Version 3.0 November 2020 (submitted)*
- Otaio-Makikihi Water Supply Water Safety Plan *Version 3.0 (under development)*
- Waihaorunga Water Supply Water Safety Plan *Version 2.2 December 2019 (approved)*
- Waikakahi Water Supply Water Safety Plan *Version 2.1 December 2019 (approved)*
- Waimate Water Supply Water Safety Plan *Version 3.0 January 2019 (approved)*

These risk assessment tables are based on the Ministry of Health Water Safety Plan Guides available at <http://www.health.govt.nz/publication/water-safety-plan-guides-drinking-water-supplies> . The risk assessment tables cover risks associated with Source, Treatment Processes, Distribution Systems and General Elements of all the Waimate District Council water supplies. They go into detail about the known risks and the measures in place to control.

Appendix D:

Risk Assessments

Risk Summary Table – all Services

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
1		Higher Level Policies, Procedures and Controls				
1.1	Subdivision Code, District Plan not up to date	Inappropriate development and/or poor design of assets.	Moderate	Subdivision and Development Code up to date and activity to have input to District Plan.	Low	
1.2	Operations Manuals not up-to-date	Failure to supply water or cause adverse health effects due to poor operation of assets.	Moderate	Operating Manuals substantially complete and ensure staff comply with requirements.	Low	The existing operation and maintenance manuals are to be updated where required. Particularly when treatment processes are updated
1.3	Not having clear direction on public consultation	Council in breach of LGA2002 with respect to Public Consultation.	Low	Need ability to get advice from specialist council staff on consultation plan for each project.	Low	
1.4	Districts Bylaws not up to date	Inability to properly control inappropriate behaviour by others.	Low	Bylaws up to date	Low	Bylaws are being updated prior to 30 June 2018
1.5	The Council does not have an acceptable position on the impact of climate change on service delivery	Financial loss due to liability for property damage, loss of asset. Not able to provide service.	Significant	Council needs policy and relevant action plans including relevant design parameters) on Climate Change.	Low	Strategies to implement Councils future policy on the effects of climate change
1.6	Inaccurate growth information or growth not considered	Inappropriate decisions made about development.	Moderate	Growth developed by Council	Low	
2		Financial				
2.1	Lack of long-term financial planning	Higher than necessary financial costs	Significant	Existing network models are up to date and available	Low	
2.2	Service levels vs funding and works not clear	Service levels not being met due to lack of funding as decision makers not aware of implications for Service Levels.	Significant	Set performance targets for next 10 years and monitor and report on performance. Impacts of delayed capital works reported to Council.	Low	

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
2.3	Assumptions for financial forecasting not always understood	Additional costs incurred because assumption/uncertainties not accounted for i.e.: asset valuations, depreciation	Significant	Finance/managers need to be aware of assumptions and uncertainties behind financial forecasting information.	Moderate	
2.4	Unforeseen Additional Costs	Reputation of Council detrimentally affected	Significant	Ensuring AMPs and asset information up to date	Low	
2.5	Valuations not accurate for asset facilities	Fixed Asset Register not reconciling with existing assets causing incorrect valuations and affecting true financial requirements	Low	Asset register reviewed and updated	Low	
2.6	Development Contributions policy not implemented and/or do not have robust system for calculating contributions from developers	Adequate contributions for development not obtained costing the Council more than it should. Council faces legal action if contributions not in line with Section 199 of the LGA 2002.	Moderate	Development Contributions Policy implemented.	Low	Changes to the RMA are likely to impact financial contributions.
2.7	All potential sources of Government and other external funding (Third Party funding) not appreciated or obtained	Higher cost to Council than should have been	Moderate	Identify potential availability of third party funding and apply / take advantage of it.	Low	
2.8	Insurance cover needs review	Insurance not adequate and unnecessary costs incurred	High	Insurance cover reviewed to ensure adequate cover on annual basis.	Low	
3		Organisational Management				
3.1	Lack of Strategic Thinking/ Long-Term planning	Inefficient use of time and money.	Moderate	Implementation of AMP and undertake condition assessments.	Low	
3.2	Failure to act on identified risk - e.g. Water Safety Plans Plans	Possible legal action against Council if event occurs which Council knew about. Public Health adverse affected.	Moderate	WSP's have been carried out and recommendations being implemented	Low	Need to monitor outcomes of Havelock North Enquiry and proposed 3 Waters review

Appendix D:

Risk Assessments

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
3.3	Lifelines Plan not up to date or implemented	Large scale asset failure due to a naturally occurring event resulting in prolonged and substantial loss of service to District	Significant	Ensure Lifelines Plan up-to-date and recommendations implemented that includes having a high level of risk reduction, readiness, response and recovery during and following Civil Defence Emergency.	Significant	Update lifelines plan, engage with regional lifelines group
3.4	Legislative requirements not understood	Council faces legal action because legal requirements are not met	Moderate	Annual reviews	Low	
4		Human Resources				
4.2	Accountabilities not clear	Staff not accountable for actions allowing apparent problems to continue	Moderate	Up-to-date job descriptions. Staff performance monitored and dealt with if not performing.	Low	
4.3	Information in peoples heads or inappropriate recording of information	Organisational knowledge lost with staff leaving	Significant	Ensure staff document and appropriately file everything that is relevant. Ensure good management succession when existing staff leave.	Moderate	Formalise and update maintenance schedules and procedures, contingency and operation and maintenance manuals.
4.4	Insufficient staff or not appropriately skilled	Programmed work not completed due to insufficient staffing or skill levels, having negative impact on service levels and creating public health risk.	High	Skill levels are appropriate	Low	Formal training programme required that includes the use of activity management plans
4.5	Inadequate attention to staff succession	Organisational knowledge lost with staff leaving	High	Implement good staff/management succession plan and document procedures	Moderate	Implement good staff/management succession plan and document procedures
5		Health and Safety				
5.1	Do not have a good health and safety culture	High accident rate	Moderate	Council health and safety procedures implemented, appropriate training undertaken and manuals up-to-date.	Low	
5.2	Health and Safety Risks not identified or managed appropriately	Council faces legal claims for not meeting health and safety obligations	Moderate	Health and Safety manuals up to date and be effectively managed.	Low	
6		Asset Management				

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
6.1	Network modelling, condition assessments not undertaken.	Capital Works programme not optimised. Renewal works not completed due to lack of knowledge causing failure of assets. Future forecasting not accurate.	Significant	Undertake condition assessments of network and develop robust renewals programme based on sound knowledge.	Moderate	Development and maintenance of network model.
6.2	As-built information can be slow or incorrect coming from maintenance staff, Contractors, Consultants	Council faces legal action because of incorrect information provided (particularly with regard to LIMS)	Significant	Ensure As-builts up to-date and on record promptly. Ensure GIS capability	Low	
6.3	Criticality assessment not undertaken	Failure of critical assets resulting environmental damage or not meeting service levels	Significant	Undertake criticality assessment of assets and implement strategy for managing critical assets	Low	Incorporate criticality assessment of reticulated assets, undertake criticality assessment of plant assets and implement strategy for managing critical assets
6.4	Asset Risk Register and Asset Risk Plan not implemented	Council faces legal action because of asset failure or unnecessary costs incurred due to asset failure	Moderate	Maintain Asset Risk Register and Asset Risk Plan	Moderate	Improve risk plan to reduce residual risk
6.5	Asset management systems not up-to-date or completed	Failure to of utility systems because maintenance work not completed or management system not operational.	Significant	Asset Management System in place and updated as required	Moderate	Review AM system practices and processes
6.6	Performance monitoring of service levels not completed	Target Service levels not met resulting in customer dissatisfaction.	Moderate	Monitoring programme established and reviewed regularly.	Low	
6.7	Poor standards of constructed assets due to design and/or construction of infrastructure	Substandard physical works resulting in poor asset performance	Moderate	NZS4404 is updated regularly and Contractors & Consultants are familiar with this. Contractors/Consultants take responsibility for work done.	Low	Perhaps develop Sub-Division Code of Practice

Appendix D:

Risk Assessments

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
6.8	Capital works delayed due to unforeseen circumstances	Programmed Capital Works not completed. Target Service Levels not met	Significant	Staff held accountable for delays & Staff trained in project management.	Moderate	Develop projects process that provides for project plans to be prepared for every approved renewal and capital development item.
6.9	Deferred renewal and maintenance not recorded or not done	Deferred maintenance not recorded causing unexpected, additional costs from asset failure	High	Record all deferred maintenance and renewals	Significant	Ensure all deferred renewals work recorded and management aware of impact on service levels if not funded.
6.10	Not all easements recorded or obtained	Council faces legal action or cannot carry out its activities because it does not have legal right to cross a property	Significant	Keep up-to-date record of easements. Establish clear policy for processes to be followed when easements are required.	Significant	Easement information needs to be improved with all identified easements provided with details of interested part. Legal situation to be clarified.
6.11	Insufficient documentation of escalating process decision making	Response to emergency situations reduced, higher expenditure	Significant	Employment of staff with the appropriate qualifications and skills	Low	
7		Resource Consents and Designations				
7.1	Review of Designations required	Council faces legal action because water assets have not been designated in the District plan	Moderate	Designations reviewed every three years to ensure these are appropriate.	Low	
7.2	Resource Consents	Council faces legal action because resource consents not applied for or conditions not met. Public dissatisfaction with environmental damage being caused.	Moderate	All consents that are required are obtained and consents monitored and reported on as required.	Low	
8		Asset Risks - Water				
8.1	Some treatment plants not capable of meeting drinking water standards	Dissatisfaction of customers from not meeting target water supply gradings due to non compliance with drinking water standards.	Significant	Upgrade of water supplies to meet standards underway with monitoring programme in place.	Low	



No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
8.2	Reticulation - Inaccurate and/or unknown location of main	Asset broken - inability to supply service	Low	Maintain good as-builts that are current via GIS	Low	Update locations as and when data becomes available
8.3	Insufficient reticulation capacity	Low pressure	Low	Maintain reticulation model with updates as required	Low	
8.4	Poor reticulation condition - reduced flows	LoS not achieved	Low	Maintain reticulation model with updates as required. Good renewals programme that understands the issues with the network	Low	
8.5	Insufficient reservoir storage	Fire fighting Code of practice not achieved	Moderate	Maintain reticulation model with updates as required	Low	
8.6	Insufficient Operational Pump Station Capacity	Low pressure/insufficient flow	Low	Good understanding of schemes capacities and ongoing monitoring of usage	Low	
8.7	SCADA Failure	No alarm available, no water	Significant	Back up systems and procedures	Low	Backup system already implemented
8.8	Treatment Plant - Equipment/component Failure	Failure to meet consent conditions, reduced water pressure	Moderate	Early warning via SCADA & site monitoring by staff	Moderate	
8.9	Vandalism at facility	Reduced LoS	Significant	Warning via SCADA of any issue at facilities	Moderate	
8.10	Rising Mains - Insufficient Capacity	Insufficient water during peak usage periods	Significant	Good understanding of schemes capacities and ongoing monitoring of usage	Moderate	
8.11	Operator Error	Failure to achieve consent conditions or facility failure	Significant	Employment of staff with the appropriate qualifications, skills and training	Moderate	Upskill staff when new training becomes available.
8.12	Power failure for extended periods	No water - reservoirs run dry	Significant	Standby generators made available in an event of extended power failure	Moderate	Review generator use if there are changes in level of expectation and or demand
8.13	Fire at facility	Control equipment failure with resulting lack of ability to supply demand	Moderate	Management and operational staff have the skills to manage natural events	Moderate	

Appendix D:  
Risk Assessments

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
8.14	Movement failure caused by, Earthquake, landslide or settlement.	Inability to supply all or majority of demand	Moderate	Management and operational staff have the skills to manage natural events	Moderate	
8.15	Snow and wind	Power failure - see power failure	Significant	Standby generators made available in an event of extended power failure	Moderate	Review generator use if there are changes in level of expectation and or demand
8.16	Flooding	Intakes flooded - poor water quality or inability to pump water	Significant	Management and operational staff have the skills to manage natural events	Moderate	
9		Asset Risks Wastewater				
9.1	Blocked mains occurring on frequent basis	Flooding of roads, health risk	Moderate	Cleaning (via water blasting) those areas most effected on an annual basis	Low	
9.2	Manholes - Insufficient maintenance	Failure leading to blockages - Flooding of roads, health risk	Low	Inspections of key points within network during high rainfall periods	Low	Document and schedule manhole inspections in Univerus Assets
9.3	Reticulation - Inaccurate and/or unknown location of main	Asset broken - inability to supply service	Low	Maintain good as-builts that are current via GIS	Low	
9.4	Insufficient reticulation capacity	Surcharging in wet weather - health issues	Low	Maintain reticulation model with updates as required	Moderate	Address known surcharging.
9.5	Poor reticulation condition (blockages)	Failure leading to blockages - Flooding of roads, health risk	Low	Maintain reticulation model with updates as required. Good renewals programme that understands the issues with the network	Low	Log all blockages in Univerus Assets
9.6	Insufficient grades or flow to achieve self cleansing velocities	Build up of fats - blockages - Flooding of roads, health risk, increased costs for cleaning	Low	Maintain reticulation model with updates as required. Good renewals programme that understands the issues with the network. Known areas within network that have issues are inspected on regular basis	Low	
9.7	Chemical damage of pipes	Decreased asset life - premature replacement	Moderate	Inspections of network CCTV, cleaning etc	Moderate	

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
9.8	Pump Stations - Equipment or component Failure	Wastewater discharges to the environment having an impact on environmental, cultural and health issues. Customer complaints	Moderate	Early warning via SCADA & site monitoring by staff	Moderate	
9.9	Pump Stations - Insufficient Wet Weather Storage Capacity	Insufficient storage or capacity resulting in wastewater discharges to the environment having an impact on environmental and cultural issues	Moderate	Good understanding of schemes capacities and ongoing monitoring of flows	Moderate	
9.10	Pump Stations - Corrosion and sulphur attack of electrical/control equipment	Surcharging in wet weather - health issues	Low	Monitoring of facilities on a regular basis	Low	
9.11	Insufficient Operational Pump Station Capacity	Surcharging in wet weather - health issues	Low	Good understanding of schemes capacities and ongoing monitoring of flows	Low	
9.12	SCADA Failure	No alarm available	Significant	Back up systems and procedures	Low	
9.13	Treatment Plant - Equipment/component Failure	Failure to meet consent conditions.	Moderate	Early warning via SCADA & site monitoring by staff	Moderate	
9.14	Ponds - Overloading of Components Treatment Capacity	Failure to comply with resource consents and Customer complaints.	Moderate	Good understanding of treatment capacities and ongoing testing and monitoring of flows	Moderate	
9.15	Odours at treatment plant, or reticulation		Moderate	Good understanding of treatment capacities	Moderate	
9.16	Vandalism at facility		Moderate	Warning via SCADA of any issue at facilities	Moderate	
9.17	Overloading of Components Treatment Capacity	Discharge of Biosolids to environment. Failure to comply with resource consents. Customer complaints	Moderate	Good understanding of treatment capacities and ongoing testing and monitoring of flows	Moderate	

Appendix D:

Risk Assessments

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
9.18	Rising Mains - Insufficient Capacity	Wastewater discharged to the environment at pump stations having an impact on environmental and cultural issues.	Moderate	Good understanding of scheme capacities and ongoing monitoring of flows	Moderate	
9.19	Operator Error	Failure to achieve consent conditions or facility failure	Moderate	Employment of staff with the appropriate qualifications and skills	Moderate	
9.20	Power failure	Treatment capacity diminished	Low	Standby generators will be made available in an event of power failure if required	Low	Review generator use if there are changes in level of expectation and or demand
9.21	Fire at facility	Control equipment failure with resulting lack of ability to continue service	Moderate	Management and operational staff have the skills to manage natural events	Moderate	
9.22	Movement failure caused by, Earthquake, landslide or settlement.	Inability to supply all or majority of demand	Moderate	Management and operational staff have the skills to manage natural events	Moderate	
9.23	Snow and wind	Power failure - see power failure	Low	Standby generators will be made available in an event of power failure if required	Moderate	Review generator use if there are changes in level of expectation and or demand
10		Asset Risks Stormwater				
10.1	Mains - Blocked mains prior to storm events	Flooding of houses and properties	Moderate	Council staff have good maintenance and monitoring provisions	Moderate	
10.2	Manholes - Insufficient maintenance	Flooding of houses and properties	Moderate	Council staff have good maintenance and monitoring provisions	Moderate	
10.3	Outlets, culverts, Blocked & erosion with insufficient cleaning	Flooding of houses and properties	Moderate	Council staff have good maintenance and monitoring provisions	Moderate	
10.4	insufficient cleaning	Flooding of houses and properties	Moderate	Council staff have good maintenance and monitoring provisions	Moderate	
10.5	Insufficient overland flow paths	Flooding of houses and properties	Significant	Modelling of system will ascertain flow path requirements	Moderate	Complete modelling area to reduce risk and identify overland flow paths to protect.

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
10.6	Overland Flow Paths located on private property - no maintenance (overgrown/built upon)	Flooding of houses and properties	Significant	Council staff have good maintenance and monitoring provisions	Moderate	
10.7	Overland Flow Paths Located on Councils property or roads - no maintenance (overgrown etc.)	Flooding of houses and properties	Significant	Council staff have good maintenance and monitoring provisions	Moderate	
10.8	Power failure	Nil	Low	Management and operational staff have the skills to manage natural events	Low	
10.9	Fire	Nil	Low	Management and operational staff have the skills to manage natural events	Low	
10.10	Movement failure caused by, Earthquake, landslide or settlement.	Inability to supply all or majority of demand	Low	Management and operational staff have the skills to manage natural events	Low	
10.11	Snow and wind	Possible flooding	Moderate	Management and operational staff have the skills to manage natural events	Moderate	
10.12	Hail	Possible flooding	Moderate	Management and operational staff have the skills to manage natural events	Moderate	Utilise good design parameters on pipe entry structures.
11		Asset Risks - Solid Wastes				
11.1	Landfills - Non compliance of consents	Attention by Ecan	Low	Defined post closure procedures	Low	
11.2	Landfills - Erosion of closed land fills by streams or rivers	exposure of old wastes to the environment	Moderate	Watching brief	Moderate	

Appendix D:

Risk Assessments

No.	Weakness or Vulnerability	Risk	Gross Risk	Mitigation Strategies	Residual Risk	Improvement Required
11.3	RRP (resource Recovery Park): Power failure	Nil	Low	Management and operational staff have the skills to manage natural events	Low	
11.4	Fire	Emergency closure	Low	Redirect to temporary site or TDC	Low	
11.5	RRP - Movement failure caused by, Earthquake, landslide or settlement.	Inability to carry out service	Low	Management and operational staff have the skills to manage natural events	Low	
11.6	Snow and wind	Disruption of collection cycle	Low	Management and operational staff have the skills to manage natural events	Low	
11.7	RRP - Major Flood	Short term closure	Low	Redirect to temporary site or TDC	Low	
11.8	RRP - Chemical spill	Short term closure	Moderate	Redirect to temporary site or TDC	Low	
11.9	RRP - Dust & noise nuisance	Reputation of Council detrimentally affected	Low	Good practices and processes carried out on site	Low	
11.10	RRP - Loss of market for recyclables	Build up of recyclables	Significant	Different Markets for each recyclable	Low	Contractor wears this risk
11.11	Bin/bag collection - spillage	Litter over wide area	Moderate	Contract processes	Low	
11.12	Bin/bag collection -Loss of contractor providing service	Collection disruption	Low	Management and operational staff have the skills to manage contractual issues and resolution	Low	

# Appendix E Major Legislation Details

The legislation that has or will have the most effect on the water services is outlined in detail in this Appendix.

## **Civil Defence Emergency Management Act 2002**

The expectations under the CDEM Act 2002 is that Council's services will function at the fullest possible extent during and after an emergency, even though this may be at a reduced level. In addition, Council has established planning and operational relationships with regional CDEM groups to deliver emergency management within our boundaries.

Water and wastewater services are regarded as critical services and are given special consideration within Council emergency management procedures. Every effort will be given to restore services immediately after an event to at least provide adequate water for sanitation and health albeit supply quantity may be limited.

## **Climate Change Response (Zero Carbon) Amendment Act 2019**

The Climate Change Response (Zero Carbon) Amendment Act 2019 provides a framework by which New Zealand can develop and implement clear and stable climate change policies that:

- contribute to the global effort under the Paris Agreement to limit the global average temperature increase to 1.5° Celsius above pre-industrial levels
- allow New Zealand to prepare for, and adapt to, the effects of climate change.

The amendments establish four key items.

1. set a new domestic greenhouse gas emissions reduction target for New Zealand to:
  - a. **reduce net emissions of all greenhouse gases (except biogenic methane) to zero by 2050**
  - b. reduce emissions of biogenic methane to 24–47 per cent below 2017 levels by 2050, including to 10 per cent below 2017 levels by 2030
2. establish a system of emissions budgets to act as stepping stones towards the long-term target
3. require the Government to develop and implement policies for climate change adaptation and mitigation
4. establish a new, independent Climate Change Commission to provide expert advice and monitoring to help keep successive governments on track to meeting long-term goals. See the Climate Change Commission website.

The original proposal was for a separate piece of legislation called the Zero Carbon Bill to be passed into law. In May 2019, the Government decided to introduce it as an amendment to the Climate Change Response Act 2002. The objective was to ensure that all key climate legislation is within one Act.

## **Health Act 1956**

The Health Act 1956 places an obligation on Council to improve, promote and protect public health within the District. The provision of water and wastewater services conserves public health and helps to protect land and waterways from contamination.

### **Fire and Emergency New Zealand Act 2017**

The Fire and Emergency New Zealand Act repeals the 2 Acts governing fire services, the Fire Service Act 1975 and the Forest and Rural Fires Act 1977, to give effect to a single, unified fire services organisation for New Zealand.

The Act establishes Fire and Emergency New Zealand (FENZ) and combines urban and rural fire services.

The Act introduces a range of changes and new measures for the detailed design and operational policy of FENZ, including the following:

- an updated offences and penalties regime, including a new infringement offence scheme
- removal of powers to recover the cost of rural fires
- new powers for managing hazardous substances incidents
- new measures to encourage compliance among levy-payers and to protect the integrity of the levy
- new powers for firefighters to enter premises to investigate the causes of fires and to take a sample or samples of objects for analysis.

The Fire and Emergency New Zealand (Levy) Amendment Act 2019 was passed into legislation on 7 May 2019. The legislation changes the commencement date for new levy provisions in the Fire and Emergency Act 2017 ( Sections 80 to 140) to 1 July 2024.

In addition, two new exemptions will be put into force from 1 July 2019. New Zealand Defence Force property and Art and items in collections of cultural heritage bodies. Fire and Emergency New Zealand have prepared a guideline for the new exemptions which can viewed at <https://www.fireandemergency.nz/assets/Documents/About-FENZ/Levy-and-payment-forms/Guideline-on-additional-exemptions-from-1-July-2019.pdf>.

### **Health and Safety at Work Act 2015**

The Health and Safety at Work Act 2015 (HSWA) was enacted on 4 April 2016 and is part of “Working Safer: a blueprint for health and safety at work” and reforms New Zealand’s health and safety system following the recommendations of the Independent Taskforce on Workplace Health and Safety. Working Safer is aimed at reducing New Zealand’s workplace injury and death toll by 25 per cent by 2020.

The HSWA:

- reinforces proportionality – what a business needs to do depends on its level of risk and what it can control
- shifts from hazard spotting to managing critical risks – actions that reduce workplace harm rather than trivial hazards
- introduces the “reasonably practicable” concept – focusing attention on what’s reasonable for a business to do
- changes the focus from the physical workplace to the conduct of work – what the business actually does and so what it can control
- supports more effective worker engagement and participation – promoting flexibility to suit business size and need.

A guiding principle of the HSWA is that workers and other persons should be given the highest level of protection against harm to their health, safety, and welfare from work risks as is reasonably



practicable. The HSWA shifts the focus from monitoring and recording health and safety incidents to proactively identifying and managing risks so everyone is safe and healthy. The HSWA identifies four duty holders:

persons conducting a business or undertaking (PCBUs) – these may be individuals or organisations	have the primary responsibility for the health and safety of their workers and any other workers they influence or direct. They are also responsible for the health and safety of people at risk from the work of their business
officers	(company directors, partners, board members, chief executives) must do due diligence to make sure the business understands and is meeting its health and safety responsibilities
workers	must take reasonable care for their own health and safety and that their actions don't adversely affect the health and safety of others. They must also follow any reasonable health and safety instruction given to them by the business and cooperate with any reasonable business policy or procedure relating to health and safety in the workplace
other persons at workplaces	who come into the workplace, such as visitors or customers, also have some health and safety duties to ensure that their actions don't adversely affect the health and safety of others

### Heritage New Zealand Pouhere Taonga Act 2014

Describes an archaeological site as “Any place in New Zealand that:

- Was associated with human activity that occurred before 1900
- Is the site of the wreck of any vessel where that wreck occurred before 1900
- Is or may be able through investigation by archaeological methods to provide evidence relating to the history of New Zealand”

It is unlawful to modify, damage or destroy any archaeological site – recorded or not – without an authority from the New Zealand Historic Place Trust.

### Local Government Act 2002

Defines the purpose of local authorities as enabling local decision-making by and on behalf of the community, and allows local authorities the power of general competence. This Act specifically requires Councils to continue to provide water and wastewater services if they do so already.

AMPs are the main method of demonstrating Schedule 10 requirements.

In addition to the general requirements of the Local Government Act there are some specific clauses that apply to water services.

**Table 11-4: Water Services LGA 2002 Clauses**

Section	Details	Applies to
S10	Restores the four aspects of community well-being by requiring local authorities to promote the social, economic, environmental, and cultural well-being of communities in the present and for the future	Water and Waste Services
S17A	Requires that Councils review the cost effectiveness of the way they deliver their services to ensure they meet the needs of communities	All services
S101B	Requires a 30 Year Infrastructure Strategy	Core Services

Section	Details	Applies to
S130	Imposes an obligation to maintain water services and places limitations on the transfer or selling of assets	Divestment of services
S 136	Empowers Councils to enter into Contracts relating to provision of water services for periods not exceeding 35 years whilst maintaining control over the pricing of the service, retain legal responsibility for the service and being responsible for the development of policy related to the water services	Utilities Contract
S 137	Empowers Councils to enter joint local government arrangements and joint arrangements with other entities for the provision of water services, with the same constraints as S136	Utilities and Professional Services provision and procurement
Pt 1 - 2 Pt 3 - 23	Council provides groups of activities for financial, performance and negative effects reporting purposes. The Water and Waste unit will provide Group summaries for water (urban & rural), sewerage and stormwater	Water and Waste Services

### Local Government Act 2002 – Section 17A

To date a formal, documented Section 17A review has not been completed for 3 Waters service delivery. Council informally reviewed 3 Waters service delivery in 2016/17.

Waimate, whilst not unique, is one of few councils that continues to provide maintenance operations “in-house” and resultantly did not have contractual arrangements in place to trigger a review between 2014 and 2017 (the statutory deadline for completing the first round of reviews).

At this point in time, investigations in to the Havelock North incident and subsequent indications that sector reforms were underway meant that the desire to change service delivery arrangements was low. Furthermore, Council was effectively comfortable that the potential benefits of performing a review did not justify the time and expense of completing the exercise. Subsequent acceleration of the reforms has bolstered this position in so far as service delivery is being addressed during the current calendar year (2021) and the impacts for 2021/22 are as yet unknown. Based on Councils decision regarding “opting in or out”, this may trigger a Section 17A review (or not).

### Local Government (Rating) Act 2002

In deciding whether to proceed with universal metering, it is worth noting the flexibility that Councils have under this Act to determine an appropriate water charging mechanism. Targeted water rates may be fixed charges per unit of water sold or according to a scale of charges.

### Resource Management Act 1991

Governs all water takes and discharges. Water takes and discharges to waterways and land occur through the extraction of water from waterways and land. Resource consents obtained for water takes and discharge activities require parameters such as volume and quality to be monitored as well as taking steps to mitigate any adverse effects that may occur through the activity.

There have been numerous amendments to the Resource Management Act over the years with reform a key priority.

### **Resource Management (Natural and Built Environment and Spatial Planning Repeal and interim Fast-track Consenting) Act 2023**

This act commenced on 23 December 2023 and repeals the Natural and Built Environment Act 2023, the Spatial Planning Act 2023 and the Natural and Built Environment (Forms and fees) Regulations 2023

### **Taumata Arowai–the Water Services Regulator Act 2020**

Taumata Arowai – the Water Services Regulator Act establish Taumata Arowai–the Water Services Regulator and provide for its objectives, functions, and governance arrangements.

This Act creates a new regulatory body to oversee, administer and enforce a new and strengthened drinking water regulatory system. It also provides a national oversight role to improve the environmental performance of stormwater and wastewater networks.

The Government is proposing changes to how Taumata Arowai regulates drinking water suppliers. The changes will remove barriers to Taumata Arowai taking a proportionate, cost effective and efficiency approach in its functions and duties. In turn this will reduce the financial burden on both councils and consumers.

### **Water Services Act 2021**

The Water Services Act 2021 commenced 15 November 2021. This Act is part of the previous governments 3 Waters Reforms. It establishes drinking water standards and regulates all persons and organisations that supply drinking water.

The Water Services Act also establishes a framework to provide transparency about the performance of drinking water, wastewater and stormwater networks and network operators; and establishes a framework for the continuous and progressive improvement of the quality of water services in New Zealand.

The Water Services Act was amended in 2023 and 2024 to align with the new governments Local Water Done Well legislative initiatives.

### **Local Government Water Services Preliminary Arrangements Act 2024 clauses:**

**Table 11-4: Water Services LGA 2002 Clauses**

<b>Section</b>	<b>Details</b>	<b>Applies to</b>
S8	<p>(1) Territorial authority must prepare a water services delivery plan within 12 months after Royal assent of the Bill.</p> <p>The plan must:</p> <ul style="list-style-type: none"> <li>a) Identify the current state of the authorities water services;</li> <li>b) Demonstrate publicly its commitment to deliver water services in a way that – <ul style="list-style-type: none"> <li>i. Ensures that the territorial authority will meet all relevant regulatory quality standards for its water services; and</li> <li>ii. Is financially sustainable for the territorial authority; and</li> <li>iii. Ensures that the territorial authority will meet all drinking water quality standards; and</li> </ul> </li> </ul> <p>Supports the territorial authority’s housing growth and urban development as specified in the territorial authority’s long-term plan.</p>	All water services

Appendix F:

References

Section	Details	Applies to
S9	Territorial authorities may submit a joint plan with 1 or more other territorial authorities, in relation to delivering water services in the joint service area covered by a joint arrangement.	All water services
S9A	Explains the extent of a joint arrangement must relate to the delivery of: <ul style="list-style-type: none"> <li>a) All water services for all of the territorial authorities; or</li> <li>b) All water services except for some or all services relating to all the territorial authorities' stormwater networks; or</li> </ul> All water services for some of the territorial authorities, and all water services except for some or all services relating to stormwater networks for the other territorial authorities.	All water services except Stormwater services
S11(1)	Stipulates the contents required in the territorial authorities water services delivery plan: <ul style="list-style-type: none"> <li>a) A description of the current state of the water services network;</li> <li>b) A description of the current levels of service relating to water services provided;</li> <li>c) A description of:               <ul style="list-style-type: none"> <li>i. The areas in the district that receive water services (including a description of any areas in the district that do not receive water services; and</li> <li>ii. The water services infrastructure associated with providing for population growth and development capacity;</li> </ul> </li> <li>d) Whether and to what extent water services –               <ul style="list-style-type: none"> <li>i. Comply with current regulatory requirements</li> <li>ii. Will comply with any anticipated future regulatory requirements;</li> </ul> </li> <li>da) f any water services do not comply with current regulatory requirements or will not comply with any anticipated future regulatory requirements -               <ul style="list-style-type: none"> <li>a. A description of non-compliance; and</li> <li>b. A description of how the anticipated or proposed model or arrangements provided under paragraph (j) will assist to ensure water services will comply;</li> </ul> </li> <li>e) Details of the capital and operational expenditure required –               <ul style="list-style-type: none"> <li>i. To deliver the water services; and</li> <li>ii. To ensure that water services comply with regulatory requirements</li> </ul> </li> <li>f) Financial projections for delivering water services over the period covered by the plan, including –               <ul style="list-style-type: none"> <li>i. The operating costs and revenue required to deliver water services; and</li> <li>ii. Projected capital expenditure on water services infrastructure; and</li> <li>iii. Projected borrowing to deliver water services;</li> </ul> </li> <li>g) An assessment of the current condition, lifespan, and value of the water services networks;</li> <li>h) A description of the asset management approach being used , including capital, maintenance, and operations programmes for delivering water services;</li> <li>i) A description of any issues, constraints, and risks that impact on delivering water services;</li> </ul>	All Water Services

Section	Details	Applies to
	<ul style="list-style-type: none"> <li>j) The anticipation of proposed model or arrangement for delivering water services (including whether the territorial authority is likely to enter into a joint arrangement under section 9 or will continue to deliver water services in its district alone);</li> <li>k) An explanation of how the revenue from, and delivery of, water services will be separated from the territorial authority's other functions and activities;</li> <li>l) A summary of any consultation undertaken as part of developing the information required to be included in the plan under paragraph (j);</li> <li>m) An explanation of what the territorial authority proposes to do to ensure that the delivery of water services will be financially sustainable by 30 June 2028;</li> <li>ma) An implementation plan -               <ul style="list-style-type: none"> <li>i. for delivering the proposed model or arrangements described under paragraph (j); and</li> <li>ii. if a territorial authority is proposing to deliver water services itself and not as part of a joint arrangement for delivering water services, that sets out the action that the territorial authority will take to ensure it delivery of water services will be financially sustainable by 30 June 2028;</li> </ul> </li> <li>n) Any other information prescribed in the rules made by the Secretary under section 14</li> </ul>	
S12	Stipulates the contents of a joint water services delivery plan	All services
S13	<p>Stipulates that a water services delivery plan –</p> <ul style="list-style-type: none"> <li>a) Must cover a period of not less than 10 consecutive financial years, starting with the 20245-25 financial year ; and</li> <li>b) May include information that covers an additional 20 consecutive years, if the information identifies investment requirements –               <ul style="list-style-type: none"> <li>i. For water services infrastructure; or</li> <li>ii. To support future housing growth and urban development.</li> </ul> </li> </ul> <p>A water services plan must provide the required information –</p> <ul style="list-style-type: none"> <li>a) In detailing relation to each of the first 3 financial years covered by the plan; and</li> </ul> <p>In outline in relation to each of the subsequent financial years covered by the plan.</p>	All Water Services
S14	<p>The Secretary of Local Government may make rules in relation to the water services delivery plans –</p> <ul style="list-style-type: none"> <li>a) Specifying additional information that must be included in a plan;</li> <li>b) Specifying the manner and form in which information must be included in a plan</li> </ul> <p>A rule made by the Secretary may require the inclusion of information that –</p> <ul style="list-style-type: none"> <li>a) Improves accountability to a territorial authority's community;</li> <li>b) Provides a basis for regulating the delivery of water services;</li> <li>c) Relates to 1 or more of the following:               <ul style="list-style-type: none"> <li>i. Financial matters (including, for example, revenues, equity levels, debt arrangements, and expenses);</li> </ul> </li> </ul>	All Water Services

## Appendix F:

### References

Section	Details	Applies to	
	<ul style="list-style-type: none"> <li>ii. The assets involved in delivering water services (including, for example, asset management plans and asset replacement policies);</li> <li>iii. Financial and non-financial performance measures;</li> <li>iv. The relevant performance measures and statistics relating to water quality;</li> </ul> Pricing practices, assumptions, policies and methodologies used in the delivering water		
S15	Sets out the process to prepare and adopt water services delivery plan: <ul style="list-style-type: none"> <li>• Must adopt by resolution</li> <li>• Must undertake consultation</li> </ul>	All Services	Water
S16	Water Services delivery plan must be submitted to Secretary for acceptance not later than 1 year after date of : <ul style="list-style-type: none"> <li>• On which section comes into force</li> <li>• On or before a later date specified by the Minister under section 17</li> <li>• Must include certification of compliance to Act and that information in plan is true and accurate.</li> </ul>	All Services	Water
S17	The Minister may grant extension to deadline for submitting water service delivery plan.	All Services	Water
S18	The Secretary must as soon as reasonably practicable consider and accept a water services delivery plan if it is satisfied that it complies with this Act.	All Services	Water
S19	When the Secretary accept the territorial authority's water services delivery plan, the territorial authority must publish the plan on its internet site;	All Services	Water
S19A	A territorial authority must give effect to its water services delivery plan;	All Services	Water
S19B	A territorial authority may amend and resubmit its water services delivery plan to the Secretary.	All Services	Water
S19C	The secretary may require a territorial authority to provide information for monitoring purposes.	All Services	Water
S20	The Minister may appoint a Crown Facilitator for water services delivery plans to a territorial authority or a group of territorial authorities that is proposing to submit, or that has submitted a joint water services delivery plan.	All Services	Water
S22	Describes the role of the appointed Crown facilitator.	All Services	Water
S23	The Minister may appoint a Crown water services specialist for water services delivery plans to a territorial authority or a group of territorial authorities that is proposing to submit, or that has submitted a joint water services delivery plan.	All Services	Water
S25	Describes the role of the appointed Crown water services specialist.	All Services	Water
Pt5	Sets out the amendments to the Water Services Act 2021 and consequential amendments	All Services	Water
S101	Amends Section 138 of the Water Services Act 2021 – (Wastewater environmental performance standards)	All Services	Water

Section	Details	Applies to
S102	Inserts a new section 138A into the Water Services Act 2021 (Repeal of provisions relating to National Policy Statement for Freshwater Management)	All Water Services

### Local Government Water Services Bill

This bill is expected to be introduced to Parliament in December 2024.

Local Water Done Well is the Coalition Government’s plan to address New Zealand’s long-standing water infrastructure challenges. It recognizes the importance of local decision making and flexibility for communities and councils to determine how their water services will be delivered in the future. It will do this while ensuring a strong emphasis on meeting economic, environmental and water quality regulatory requirements.

The proposed Local Government Water Services Bill will establish the enduring settings for the new water services system. Changes are proposed to the water service delivery system and to the water services regulatory system. This is the third piece of legislation in the Government’s three-stage process for implementing Local Water Done Well.

The Bill will provide an expanded range of water services delivery models for councils to choose from. This includes new water organisations that can be owned by councils and/or consumer trusts. They are intended to have the flexibility to be financially independent from their council owners from a credit rating perspective. Councils may design their own alternative arrangements, as long as the arrangements meet minimum requirements.

The Bill also provides new financing options for councils and /or CCO’s.

The bill has a new approach for managing urban stormwater and Councils will retain legal responsibility and control of stormwater services but will have flexibility to choose the arrangements that best suit their circumstances.

Changes are proposed to improve the management of overland flow paths and watercourses in urban areas (an urban area’s natural drainage system). This includes clarifying council and private landowner roles and responsibilities, enabling new planning and regulatory tools, and enabling ‘service agreements’ to support the integrated management of stormwater networks.

There will be new mechanisms for the Minister of Local Government to address issues with local government water service providers. The Minister will be able to appoint a Crown facilitator – water services, and /or Water Services Commissioners, if problems (or potential problems) arise in councils or water organisations.

The legislation will also enable the Minister of Local Government’s powers to be used to help address significant or persistent non-compliance with the economic regulation regime. This would be a last resort option, in situations where the regulatory tools available to the Commerce Commission are insufficient or high cost, and alternative options are required.

There will be a new economic regulation regime for local government water service providers, implemented by the Commerce Commission. The Commerce Commission will have a range of regulatory tools, including mandatory information disclosure, to promote efficient practices and protections for consumers.

The regime will ensure that revenue collected by local government water services providers through rates and water charges is being spent on the level of water infrastructure needed.

The Government is proposing changes to how Taumata Arowai regulates drinking water suppliers. The changes will remove barriers to Taumata Arowai taking a proportionate, cost effective and efficiency approach in its functions and duties. In turn this will reduce the financial burden on both councils and consumers.

### **Utilities Access Act 2010.**

The Utilities Access Act 2010 provides for a coordinated approach to management of the road corridor. The Act requires the Corridor Managers to undertake a planning and access management role, and Utility operators to comply with an approved code of practice. It is an expected that the requirements detailed in the act will be carried out as described in the Code of Practice developed by the New Zealand Utilities Access Group, should it be approved by the relevant Minister of the Crown.

The Code is a mandatory requirement for all road and rail controlling authorities and utility network operators under the Utilities Access Act 2010, and came into effect on the 1st January 2012. The Code was reviewed during 2016.

The initial KPI data identified several issues including a lack of consistency, along with the fact that not all reporting entities had sent in their returns, meaning that any comparisons were incomplete. The situation was exacerbated by the fact that only 1 year's results are available, with any real value to come from analysis of changing trends over time. Refining of the data collection requirements will be a major focus moving forward, resulting in a more comprehensive reporting and analysis to be provided following the receipt of 2016-17 KPI data.



## Appendix F References

The following details reports and other significant reference areas associated with the four utilities

#	Title	Issue Date	Sector	Author /Consultant
1	Water Safety Plans		Water	Paul Roberts Three Waters Manager
	- Cannington-Motukaika	2022		
	- Hook Waituna	2022		
	- Lower Waihao	2022		
	- Otaio-Makikihi	2022		
	- Waihaorunga	2022		
	- Waikakahi	2022		
- Waimate Urban	2022			
2	Waimate Stormwater Investigation – Study Report	May-09	Stormwater	Opus
3	Queen Street Stormwater Issues and Options Report	Jul-17	Stormwater	Opus
4	Cast Iron Pipe Assessments	Mar-11	Water	Opus
5	AC Pipe Evaluation Reports	Ongoing	Water	Opus
6	Pressure Management Study	Jul-09	Waimate Water	Opus
7	Capital Assistance Programme Funding – Otaio-Makikihi	Complete	Water	Dan Mitchell Asset Group Manager
8	Capital Assistance Programme Funding – Lower Waihao	Complete	Water	P Roberts Water & Waste Manager
9	Capital Assistance Programme Funding – Hook Waituna	Complete	Water	P Roberts Water & Waste Manager
10	2020 Valuation	Sep-17	3 Waters	In-house / BECA
11	Disaster Resilience Summary Report	2006	All	COUNCIL Asset Management Group
12	Stormwater AMP 2014	2015	Stormwater	Opus
13	Solid Waste AMP 2014	2015	Solid Waste	Opus
14	Water AMP 2014	2015	Water	Opus
15	Parks and Recreation AMP 2014	2015	Parks and Reserves	Opus
16	Wastewater AMP 2014	2015	Wastewater	Opus
17	Leak Detection programme	Jul-05	Water	Detection Services

## Appendix F:

### References

#	Title	Issue Date	Sector	Author /Consultant
18	Waimate Water Supply Leakage Detection and Analysis Study	Jul-09	Water	Opus
19	Council's Assessment of Water & Sanitary Services	Jun-11	All	M McTigue Water & Waste Manager
20	Leak Detection Programme	Oct-98	Water	Opus
21	Issues & Options for Universal Water Metering	Oct-98	Water	Opus
22	Waimate AMP Compliance Status	Feb-11	All	Waugh Infrastructure Management Ltd